



# JOSEPH H COLE REC LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	JOSEPH H COLE RECREATION CENTER	WS- 005520	9/20/2016	1	Cooler	In hallway between men's and women's restroom High	FT-82016-005520-A	< 1	FT-82016-005520-B	< 1
2	JOSEPH H COLE RECREATION CENTER	WS- 005521	9/20/2016	1	Cooler	In hallway between men's and women's restroom Low	FT-82016-005521-A	< 1	FT-82016-005521-B	< 1
3	JOSEPH H COLE RECREATION CENTER	WS- 005523	9/20/2016	1	Break Room	In multi-purpose room G131/132	FT-82016-005523-A	< 1	FT-82016-005523-B	< 1