



# Joseph H. Cole Recreation Center Lead in Water Test Results

## FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005520	5/2/2022	5/2/2023	1	Cooler	In hallway between men's and women's restroom High Left	WF-05022022-005520	2/17/2023	FT-FY23-02022023-005520-A	<1	FT-FY23-02022023-005520-B	<1
WS- 005521	5/2/2022	5/2/2023	1	Cooler	In hallway between men's and women's restroom Low Right	WF-05022022-005521	2/17/2023	FT-FY23-02022023-005521-A	<1	FT-FY23-02022023-005521-B	<1