



Kalorama RC Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation													
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location			Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012692	6/2/2021	6/2/2022	1	Cooler	In hallway adjacent to main entrance	High	Left	WF-06022021-012692	2/4/2022	FT-FY22-01102022-012692-A	<1	FT-FY22-01102022-012692-B	<1
WS- 012693	6/2/2021	6/2/2022	1	Cooler	In hallway adjacent to main entrance	Low	Right	WF-06022021-012693	2/4/2022	FT-FY22-01102022-012693-A	<1	FT-FY22-01102022-012693-B	<1