



Kalorama Recreation Center Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location			Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012692	5/2/2022	5/2/2023	1	Cooler	In hallway adjacent to main entrance	High	Left	WF-05022022-012692	1/26/2023	FT-FY23-01092023-012692-A	<1	FT-FY23-01092023-012692-B	<1
WS- 012693	5/2/2022	5/2/2023	1	Cooler	In hallway adjacent to main entrance	Low	Right	WF-05022022-012693	1/26/2023	FT-FY23-01092023-012693-A	<1	FT-FY23-01092023-012693-B	<1