



Kennedy RC Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005630	11/6/2019	11/6/2020	1	Cooler	In hallway adjacent to room 128	WF-11062019-005630	3/3/2020	FT-FY20-012020-005630-A	<1	FT-FY20-012020-005630-B	<1
WS- 005631	4/12/2019	4/12/2020	1	Food Prep Sink	In kitchen	WF-04122019-005631	3/3/2020	FT-FY20-012020-005631-A	<1	FT-FY20-012020-005631-B	<1