



# Kennedy Recreation Center Lead in Water Test Results

## FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005627	4/10/2024	4/10/2025	1	Bottle Filler	In hallway adjacent to room 128	WF-04102024-005627	5/2/2024	FT-FY24-04172024-005627-A	<1	FT-FY24-04172024-005627-B	<1
WS- 005630	4/10/2024	4/10/2025	1	Cooler	In hallway adjacent to room 128	WF-04102024-005630	5/2/2024	FT-FY24-04172024-005630-A	<1	FT-FY24-04172024-005630-B	<1