



KENNEDY REC LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	KENNEDY REC CTR	WS- 005630	9/22/2016	1	Cooler	In hallway adjacent to room 128	FT-82016-005630-A	< 1	FT-82016-005630-B	< 1
2	KENNEDY REC CTR	WS- 005631	9/22/2016	1	Food Prep Sink	In kitchen	FT-82016-005631-A	< 1	FT-82016-005631-B	< 1