



Ketcham Elementary School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 009607	9/21/2021	9/21/2022	1	Combo Faucet	In classroom A-101	WF-09212021-009607	2/10/2022	FT-FY22-01182022-009607-A	<1	FT-FY22-01182022-009607-B	<1	
WS- 009608	3/16/2021	3/16/2022	1	Combo Fountain	In classroom A-101	WF-03162021-009608	2/10/2022	FT-FY22-01182022-009608-A	1.3	FT-FY22-01182022-009608-B	<1	
WS- 009610	3/16/2021	3/16/2022	1	Health Suite	In health suite 105	WF-03162021-009610	2/10/2022	FT-FY22-01182022-009610-A	<1	FT-FY22-01182022-009610-B	<1	
WS- 009611	3/16/2021	3/16/2022	1	Cooler	In hallway across from room B-109	WF-03162021-009611	2/10/2022	FT-FY22-01182022-009611-A	<1	FT-FY22-01182022-009611-B	<1	
WS- 009612	3/16/2021	3/16/2022	1	Combo Fountain	In classroom B-109	WF-03162021-009612	2/10/2022	FT-FY22-01182022-009612-A	<1	FT-FY22-01182022-009612-B	<1	
WS- 009613	9/21/2021	9/21/2022	1	Combo Faucet	In classroom B-109	WF-09212021-009613	2/10/2022	FT-FY22-01182022-009613-A	<1	FT-FY22-01182022-009613-B	<1	
WS- 009614	3/16/2021	3/16/2022	1	Combo Fountain	In classroom B-113	WF-03162021-009614	2/10/2022	FT-FY22-01182022-009614-A	<1	FT-FY22-01182022-009614-B	<1	
WS- 009615	9/21/2021	9/21/2022	1	Combo Faucet	In classroom B-113	WF-09212021-009615	2/10/2022	FT-FY22-01182022-009615-A	<1	FT-FY22-01182022-009615-B	<1	
WS- 009616	3/16/2021	3/16/2022	1	Combo Fountain	In classroom B-114	WF-03162021-009616	2/10/2022	FT-FY22-01182022-009616-A	1.8	FT-FY22-01182022-009616-B	<1	
WS- 009617	9/21/2021	9/21/2022	1	Combo Faucet	In classroom B-114	WF-09212021-009617	2/10/2022	FT-FY22-01182022-009617-A	<1	FT-FY22-01182022-009617-B	<1	
WS- 009618	3/16/2021	3/16/2022	1	Combo Fountain	In classroom B-116	WF-03162021-009618	2/10/2022	FT-FY22-01182022-009618-A	<1	FT-FY22-01182022-009618-B	<1	
WS- 009619	9/21/2021	9/21/2022	1	Combo Faucet	In classroom B-116	WF-09212021-009619	2/10/2022	FT-FY22-01182022-009619-A	<1	FT-FY22-01182022-009619-B	<1	
WS- 009622	3/16/2021	3/16/2022	2	Break Room	In staff lounge B-202	WF-03162021-009622	2/10/2022	FT-FY22-01182022-009622-A	<1	FT-FY22-01182022-009622-B	<1	
WS- 009624	3/16/2021	3/16/2022	2	Cooler	In hallway adjacent restroom	WF-03162021-009624	2/10/2022	FT-FY22-01182022-009624-A	<1	FT-FY22-01182022-009624-B	<1	
WS- 009630	3/16/2021	3/16/2022	2	Cooler	In hallway adjacent to conference room 204	WF-03162021-009630	2/10/2022	FT-FY22-01182022-009630-A	<1	FT-FY22-01182022-009630-B	<1	
WS- 009631	3/16/2021	3/16/2022	2	Cooler	In hallway adjacent to room 205	WF-03162021-009631	2/10/2022	FT-FY22-01182022-009631-A	<1	FT-FY22-01182022-009631-B	<1	
WS- 009634	3/16/2021	3/16/2022	3	Break Room	In staff lounge B-302	WF-03162021-009634	2/10/2022	FT-FY22-01182022-009634-A	<1	FT-FY22-01182022-009634-B	<1	
WS- 009636	3/16/2021	3/16/2022	3	Cooler	In hallway adjacent to stairwell 2	WF-03162021-009636	2/10/2022	FT-FY22-01182022-009636-A	<1	FT-FY22-01182022-009636-B	<1	
WS- 009792	3/16/2021	3/16/2022	Ground Floor	Combo Fountain	In classroom B101	WF-03162021-009792	2/10/2022	FT-FY22-01182022-009792-A	<1	FT-FY22-01182022-009792-B	<1	
WS- 009793	3/16/2021	3/16/2022	Ground Floor	Break Room	In break room B109	WF-03162021-009793	2/10/2022	FT-FY22-01182022-009793-A	<1	FT-FY22-01182022-009793-B	<1	
WS- 009794	9/21/2021	9/21/2022	Ground Floor	Combo Faucet	In classroom B104	WF-09212021-009794	2/10/2022	FT-FY22-01182022-009794-A	<1	FT-FY22-01182022-009794-B	<1	
WS- 009795	3/16/2021	3/16/2022	Ground Floor	Combo Fountain	In classroom B104	WF-03162021-009795	2/10/2022	FT-FY22-01182022-009795-A	<1	FT-FY22-01182022-009795-B	<1	
WS- 009796	9/21/2021	9/21/2022	Ground Floor	Combo Faucet	In classroom B103	WF-09212021-009796	2/10/2022	FT-FY22-01182022-009796-A	<1	FT-FY22-01182022-009796-B	<1	
WS- 009797	3/16/2021	3/16/2022	Ground Floor	Combo Fountain	In classroom B103	WF-03162021-009797	2/10/2022	FT-FY22-01182022-009797-A	<1	FT-FY22-01182022-009797-B	<1	
WS- 009798	9/21/2021	9/21/2022	Ground Floor	Combo Faucet	In classroom B101	WF-09212021-009798	2/10/2022	FT-FY22-01182022-009798-A	<1	FT-FY22-01182022-009798-B	<1	
WS- 009799	3/16/2021	3/16/2022	1	Break Room	In staff office room B-117	WF-03162021-009799	2/10/2022	FT-FY22-01182022-009799-A	<1	FT-FY22-01182022-009799-B	<1	
WS- 009800	3/16/2021	3/16/2022	Ground Floor	Bottle Filler	In hallway adjacent to classroom B104	WF-03162021-009800	2/10/2022	FT-FY22-01182022-009800-A	<1	FT-FY22-01182022-009800-B	<1	
WS- 009801	3/16/2021	3/16/2022	Ground Floor	Cooler	In hallway adjacent to classroom B104	High Right	WF-03162021-009801	2/10/2022	FT-FY22-01182022-009801-A	<1	FT-FY22-01182022-009801-B	<1
WS- 009802	3/16/2021	3/16/2022	Ground Floor	Cooler	In hallway adjacent to classroom B104	Low Left	WF-03162021-009802	2/10/2022	FT-FY22-01182022-009802-A	<1	FT-FY22-01182022-009802-B	<1
WS-017023	3/16/2021	3/16/2022	Ground Floor	Bottle Filler	In cafeteria	WF-03162021-017023	2/10/2022	FT-FY22-01182022-017023-A	1.4	FT-FY22-01182022-017023-B	<1	
WS-017024	3/16/2021	3/16/2022	Ground Floor	Cooler	In cafeteria	Low Left	WF-03162021-017024	2/10/2022	FT-FY22-01182022-017024-A	<1	FT-FY22-01182022-017024-B	1.2
WS-017025	3/16/2021	3/16/2022	Ground Floor	Cooler	In cafeteria	High Right	WF-03162021-017025	2/10/2022	FT-FY22-01182022-017025-A	<1	FT-FY22-01182022-017025-B	2.6

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009601	1/11/2022	1/11/2023	Ground Floor	Food Prep Sink	In kitchen on east wall	WF-01112022-009601	2/10/2022	FT-FY22-01182022-009601-A	<1	FT-FY22-01182022-009601-B	<1
WS- 009602	1/11/2022	1/11/2023	Ground Floor	Food Prep Sink	In kitchen on north wall Left	WF-01112022-009602	2/10/2022	FT-FY22-01182022-009602-A	<1	FT-FY22-01182022-009602-B	<1