



Ketcham Elementary School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 009607	9/14/2022	9/14/2023	1	Combo Faucet	In classroom A-101	WF-09142022-009607	11/7/2022	FT-FY23-10102022-009607-A	<1	FT-FY23-10102022-009607-B	<1	
WS- 009608	3/7/2022	3/7/2023	1	Combo Fountain	In classroom A-101	WF-03072022-009608	11/7/2022	FT-FY23-10102022-009608-A	<1	FT-FY23-10102022-009608-B	<1	
WS- 009610	3/7/2022	3/7/2023	1	Health Suite	In health suite 105	WF-03072022-009610	11/7/2022	FT-FY23-10102022-009610-A	<1	FT-FY23-10102022-009610-B	1.5	
WS- 009611	3/7/2022	3/7/2023	1	Cooler	In hallway across from room B-109	WF-03072022-009611	11/7/2022	FT-FY23-10102022-009611-A	<1	FT-FY23-10102022-009611-B	<1	
WS- 009612	3/7/2022	3/7/2023	1	Combo Fountain	In classroom B-109	WF-03072022-009612	11/7/2022	FT-FY23-10102022-009612-A	<1	FT-FY23-10102022-009612-B	<1	
WS- 009613	9/14/2022	9/14/2023	1	Combo Faucet	In classroom B-109	WF-09142022-009613	11/7/2022	FT-FY23-10102022-009613-A	<1	FT-FY23-10102022-009613-B	<1	
WS- 009614	3/7/2022	3/7/2023	1	Combo Fountain	In classroom B-113	WF-03072022-009614	11/7/2022	FT-FY23-10102022-009614-A	<1	FT-FY23-10102022-009614-B	<1	
WS- 009615	9/14/2022	9/14/2023	1	Combo Faucet	In classroom B-113	WF-09142022-009615	11/7/2022	FT-FY23-10102022-009615-A	<1	FT-FY23-10102022-009615-B	<1	
WS- 009618	3/7/2022	3/7/2023	1	Combo Fountain	In classroom B-116	WF-03072022-009618	11/7/2022	FT-FY23-10102022-009618-A	<1	FT-FY23-10102022-009618-B	<1	
WS- 009619	9/14/2022	9/14/2023	1	Combo Faucet	In classroom B-116	WF-09142022-009619	11/7/2022	FT-FY23-10102022-009619-A	<1	FT-FY23-10102022-009619-B	<1	
WS- 009622	3/7/2022	3/7/2023	2	Break Room	In staff lounge B-202	WF-03072022-009622	11/7/2022	FT-FY23-10102022-009622-A	<1	FT-FY23-10102022-009622-B	<1	
WS- 009634	3/7/2022	3/7/2023	3	Break Room	In staff lounge B-302	WF-03072022-009634	11/7/2022	FT-FY23-10102022-009634-A	<1	FT-FY23-10102022-009634-B	<1	
WS- 009636	3/7/2022	3/7/2023	3	Cooler	In hallway adjacent to stairwell 2	WF-03072022-009636	11/7/2022	FT-FY23-10102022-009636-A	<1	FT-FY23-10102022-009636-B	<1	
WS- 009792	3/7/2022	3/7/2023	Ground Floor	Combo Fountain	In classroom B101	WF-03072022-009792	11/7/2022	FT-FY23-10102022-009792-A	<1	FT-FY23-10102022-009792-B	<1	
WS- 009793	3/7/2022	3/7/2023	Ground Floor	Break Room	In break room B109	WF-03072022-009793	11/7/2022	FT-FY23-10102022-009793-A	<1	FT-FY23-10102022-009793-B	<1	
WS- 009794	9/14/2022	9/14/2023	Ground Floor	Combo Faucet	In classroom B104	WF-09142022-009794	11/7/2022	FT-FY23-10102022-009794-A	<1	FT-FY23-10102022-009794-B	<1	
WS- 009795	3/7/2022	3/7/2023	Ground Floor	Combo Fountain	In classroom B104	WF-03072022-009795	11/7/2022	FT-FY23-10102022-009795-A	<1	FT-FY23-10102022-009795-B	<1	
WS- 009798	9/14/2022	9/14/2023	Ground Floor	Combo Faucet	In classroom B101	WF-09142022-009798	11/7/2022	FT-FY23-10102022-009798-A	<1	FT-FY23-10102022-009798-B	1.4	
WS- 009799	3/7/2022	3/7/2023	1	Break Room	In staff office room B-117	WF-03072022-009799	11/7/2022	FT-FY23-10102022-009799-A	1.6	FT-FY23-10102022-009799-B	<1	
WS- 009800	3/7/2022	3/7/2023	Ground Floor	Bottle Filler	In hallway adjacent to classroom B104	WF-03072022-009800	11/7/2022	FT-FY23-10102022-009800-A	1.1	FT-FY23-10102022-009800-B	<1	
WS- 009801	3/7/2022	3/7/2023	Ground Floor	Cooler	In hallway adjacent to classroom B104	High Right	WF-03072022-009801	11/7/2022	FT-FY23-10102022-009801-A	<1	FT-FY23-10102022-009801-B	<1
WS- 009802	3/7/2022	3/7/2023	Ground Floor	Cooler	In hallway adjacent to classroom B104	Low Left	WF-03072022-009802	11/7/2022	FT-FY23-10102022-009802-A	<1	FT-FY23-10102022-009802-B	<1
WS-017023	3/7/2022	3/7/2023	Ground Floor	Bottle Filler	In cafeteria		WF-03072022-017023	11/7/2022	FT-FY23-10102022-017023-A	<1	FT-FY23-10102022-017023-B	<1
WS-017024	3/7/2022	3/7/2023	Ground Floor	Cooler	In cafeteria	Low Left	WF-03072022-017024	11/7/2022	FT-FY23-10102022-017024-A	<1	FT-FY23-10102022-017024-B	<1
WS-017025	3/7/2022	3/7/2023	Ground Floor	Cooler	In cafeteria	High Right	WF-03072022-017025	11/7/2022	FT-FY23-10102022-017025-A	<1	FT-FY23-10102022-017025-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009601	1/11/2022	1/11/2023	Ground Floor	Food Prep Sink	In kitchen on east wall		11/7/2022	FT-FY23-10102022-009601-A	1.1	FT-FY23-10102022-009601-B	<1
WS- 009602	1/11/2022	1/11/2023	Ground Floor	Food Prep Sink	In kitchen on north wall	Left	11/7/2022	FT-FY23-10102022-009602-A	<1	FT-FY23-10102022-009602-B	<1