



Ketcham Elementary School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009607	9/5/2023	9/5/2024	1	Combo Faucet	In classroom A-101	WF-09052023-009607	11/22/2023	FT-FY24-10102023-009607-A	<1	FT-FY24-10102023-009607-B	<1
WS- 009608	2/28/2023	2/28/2024	1	Combo Fountain	In classroom A-101	WF-02282023-009608	11/22/2023	FT-FY24-10102023-009608-A	<1	FT-FY24-10102023-009608-B	<1
WS- 009610	2/28/2023	2/28/2024	1	Health Suite	In health suite 105	WF-02282023-009610	11/22/2023	FT-FY24-10102023-009610-A	<1	FT-FY24-10102023-009610-B	<1
WS- 009612	2/28/2023	2/28/2024	1	Combo Fountain	In classroom B-109	WF-02282023-009612	11/22/2023	FT-FY24-10102023-009612-A	4.0	FT-FY24-10102023-009612-B	<1
WS- 009613	9/5/2023	9/5/2024	1	Combo Faucet	In classroom B-109	WF-09052023-009613	11/22/2023	FT-FY24-10102023-009613-A	<1	FT-FY24-10102023-009613-B	<1
WS- 009614	2/28/2023	2/28/2024	1	Combo Fountain	In classroom B-113	WF-02282023-009614	11/22/2023	FT-FY24-10102023-009614-A	<1	FT-FY24-10102023-009614-B	<1
WS- 009615	9/5/2023	9/5/2024	1	Combo Faucet	In classroom B-113	WF-09052023-009615	11/22/2023	FT-FY24-10102023-009615-A	<1	FT-FY24-10102023-009615-B	<1
WS- 009618	2/28/2023	2/28/2024	1	Combo Fountain	In classroom B-116	WF-02282023-009618	11/22/2023	FT-FY24-10102023-009618-A	<1	FT-FY24-10102023-009618-B	<1
WS- 009619	9/5/2023	9/5/2024	1	Combo Faucet	In classroom B-116	WF-09052023-009619	11/22/2023	FT-FY24-10102023-009619-A	<1	FT-FY24-10102023-009619-B	<1
WS- 009624	2/28/2023	2/28/2024	2	Cooler	In hallway adjacent restroom	WF-02282023-009624	11/22/2023	FT-FY24-10102023-009624-A	<1	FT-FY24-10102023-009624-B	<1
WS- 009792	2/28/2023	2/28/2024	Ground Floor	Combo Fountain	In classroom B101	WF-02282023-009792	11/22/2023	FT-FY24-10102023-009792-A	<1	FT-FY24-10102023-009792-B	<1
WS- 009794	9/5/2023	9/5/2024	Ground Floor	Combo Faucet	In classroom B104	WF-09052023-009794	11/22/2023	FT-FY24-10102023-009794-A	<1	FT-FY24-10102023-009794-B	<1
WS- 009795	2/28/2023	2/28/2024	Ground Floor	Combo Fountain	In classroom B104	WF-02282023-009795	11/22/2023	FT-FY24-10102023-009795-A	<1	FT-FY24-10102023-009795-B	<1
WS- 009796	9/5/2023	9/5/2024	Ground Floor	Combo Faucet	In classroom B103	WF-09052023-009796	11/22/2023	FT-FY24-10102023-009796-A	<1	FT-FY24-10102023-009796-B	<1
WS- 009797	2/28/2023	2/28/2024	Ground Floor	Combo Fountain	In classroom B103	WF-02282023-009797	11/22/2023	FT-FY24-10102023-009797-A	<1	FT-FY24-10102023-009797-B	<1
WS- 009798	9/5/2023	9/5/2024	Ground Floor	Combo Faucet	In classroom B101	WF-09052023-009798	11/22/2023	FT-FY24-10102023-009798-A	<1	FT-FY24-10102023-009798-B	<1
WS- 009799	2/28/2023	2/28/2024	1	Break Room	In staff office room B-117	WF-02282023-009799	11/22/2023	FT-FY24-10102023-009799-A	<1	FT-FY24-10102023-009799-B	<1
WS- 009800	2/28/2023	2/28/2024	Ground Floor	Bottle Filler	In hallway adjacent to classroom B104	WF-02282023-009800	11/22/2023	FT-FY24-10102023-009800-A	<1	FT-FY24-10102023-009800-B	<1
WS- 009801	2/28/2023	2/28/2024	Ground Floor	Cooler	In hallway adjacent to classroom B104 High Right	WF-02282023-009801	11/22/2023	FT-FY24-10102023-009801-A	<1	FT-FY24-10102023-009801-B	<1
WS- 009802	2/28/2023	2/28/2024	Ground Floor	Cooler	In hallway adjacent to classroom B104 Low Left	WF-02282023-009802	11/22/2023	FT-FY24-10102023-009802-A	<1	FT-FY24-10102023-009802-B	<1
WS-017023	2/28/2023	2/28/2024	Ground Floor	Bottle Filler	In cafeteria	WF-02282023-017023	11/22/2023	FT-FY24-10102023-017023-A	<1	FT-FY24-10102023-017023-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009601	12/22/2022	12/22/2023	Ground Floor	Food Prep Sink	In kitchen on east wall	WF-12222022-009601	11/22/2023	FT-FY24-10102023-009601-A	<1	FT-FY24-10102023-009601-B	<1
WS- 009602	12/22/2022	12/22/2023	Ground Floor	Food Prep Sink	In kitchen on north wall Left	WF-12222022-009602	11/22/2023	FT-FY24-10102023-009602-A	<1	FT-FY24-10102023-009602-B	<1