



Ketcham ES Lead Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 009606	4/1/2019	4/1/2020	1	Cooler	In hallway adjacent to room A-102	WF-04012019-009606	10/31/2019	FT-FY20-102019-009606-A	<1	FT-FY20-102019-009606-B	<1	
WS- 009607	10/9/2019	10/9/2020	1	Combo Faucet	In classroom A-101	WF-10092019-009607	10/31/2019	FT-FY20-102019-009607-A	<1	FT-FY20-102019-009607-B	<1	
WS- 009608	4/1/2019	4/1/2020	1	Combo Fountain	In classroom A-101	WF-04012019-009608	10/31/2019	FT-FY20-102019-009608-A	<1	FT-FY20-102019-009608-B	<1	
WS- 009610	4/1/2019	4/1/2020	1	Health Suite	In health suite 105	WF-04012019-009610	10/31/2019	FT-FY20-102019-009610-A	<1	FT-FY20-102019-009610-B	<1	
WS- 009611	4/1/2019	4/1/2020	1	Cooler	In hallway across from room B-109	WF-04012019-009611	10/31/2019	FT-FY20-102019-009611-A	<1	FT-FY20-102019-009611-B	<1	
WS- 009612	4/1/2019	4/1/2020	1	Combo Fountain	In classroom B-109	WF-04012019-009612	10/31/2019	FT-FY20-102019-009612-A	<1	FT-FY20-102019-009612-B	<1	
WS- 009613	10/9/2019	10/9/2020	1	Combo Faucet	In classroom B-109	WF-10092019-009613	10/31/2019	FT-FY20-102019-009613-A	<1	FT-FY20-102019-009613-B	<1	
WS- 009614	4/1/2019	4/1/2020	1	Combo Fountain	In classroom B-113	WF-04012019-009614	10/31/2019	FT-FY20-102019-009614-A	<1	FT-FY20-102019-009614-B	<1	
WS- 009615	10/9/2019	10/9/2020	1	Combo Faucet	In classroom B-113	WF-10092019-009615	10/31/2019	FT-FY20-102019-009615-A	<1	FT-FY20-102019-009615-B	<1	
WS- 009616	4/1/2019	4/1/2020	1	Combo Fountain	In classroom B-114	WF-04012019-009616	10/31/2019	FT-FY20-102019-009616-A	<1	FT-FY20-102019-009616-B	<1	
WS- 009617	10/9/2019	10/9/2020	1	Combo Faucet	In classroom B-114	WF-10092019-009617	10/31/2019	FT-FY20-102019-009617-A	<1	FT-FY20-102019-009617-B	<1	
WS- 009618	4/1/2019	4/1/2020	1	Combo Fountain	In classroom B-116	WF-04012019-009618	10/31/2019	FT-FY20-102019-009618-A	<1	FT-FY20-102019-009618-B	<1	
WS- 009619	10/9/2019	10/9/2020	1	Combo Faucet	In classroom B-116	WF-10092019-009619	10/31/2019	FT-FY20-102019-009619-A	<1	FT-FY20-102019-009619-B	<1	
WS- 009622	4/1/2019	4/1/2020	2	Break Room	In staff lounge B-202	WF-04012019-009622	10/31/2019	FT-FY20-102019-009622-A	<1	FT-FY20-102019-009622-B	<1	
WS- 009624	4/1/2019	4/1/2020	2	Cooler	In hallway adjacent restroom	WF-04012019-009624	10/31/2019	FT-FY20-102019-009624-A	<1	FT-FY20-102019-009624-B	<1	
WS- 009630	4/1/2019	4/1/2020	2	Cooler	In hallway adjacent to conference room 204	WF-04012019-009630	10/31/2019	FT-FY20-102019-009630-A	<1	FT-FY20-102019-009630-B	<1	
WS- 009631	4/1/2019	4/1/2020	2	Cooler	In hallway adjacent to room 205	WF-04012019-009631	10/31/2019	FT-FY20-102019-009631-A	<1	FT-FY20-102019-009631-B	<1	
WS- 009634	4/1/2019	4/1/2020	3	Break Room	In staff lounge B-302	WF-04012019-009634	10/31/2019	FT-FY20-102019-009634-A	<1	FT-FY20-102019-009634-B	<1	
WS- 009636	4/1/2019	4/1/2020	3	Cooler	In hallway adjacent to stairwell 2	WF-04012019-009636	10/31/2019	FT-FY20-102019-009636-A	<1	FT-FY20-102019-009636-B	<1	
WS- 009792	4/1/2019	4/1/2020	Ground Floor	Combo Fountain	In classroom B101	WF-04012019-009792	10/31/2019	FT-FY20-102019-009792-A	<1	FT-FY20-102019-009792-B	<1	
WS- 009793	4/1/2019	4/1/2020	Ground Floor	Break Room	In break room B109	WF-04012019-009793	10/31/2019	FT-FY20-102019-009793-A	<1	FT-FY20-102019-009793-B	<1	
WS- 009794	10/9/2019	10/9/2020	Ground Floor	Combo Faucet	In classroom B104	WF-10092019-009794	10/31/2019	FT-FY20-102019-009794-A	<1	FT-FY20-102019-009794-B	<1	
WS- 009795	4/1/2019	4/1/2020	Ground Floor	Combo Fountain	In classroom B104	WF-04012019-009795	10/31/2019	FT-FY20-102019-009795-A	<1	FT-FY20-102019-009795-B	<1	
WS- 009796	10/9/2019	10/9/2020	Ground Floor	Combo Faucet	In classroom B103	WF-10092019-009796	10/31/2019	FT-FY20-102019-009796-A	<1	FT-FY20-102019-009796-B	<1	
WS- 009797	4/1/2019	4/1/2020	Ground Floor	Combo Fountain	In classroom B103	WF-04012019-009797	10/31/2019	FT-FY20-102019-009797-A	1.4	FT-FY20-102019-009797-B	<1	
WS- 009798	10/9/2019	10/9/2020	Ground Floor	Combo Faucet	In classroom B101	WF-10092019-009798	10/31/2019	FT-FY20-102019-009798-A	1.1	FT-FY20-102019-009798-B	<1	
WS- 009799	4/1/2019	4/1/2020	1	Break Room	In staff office room B-117	WF-04012019-009799	10/31/2019	FT-FY20-102019-009799-A	<1	FT-FY20-102019-009799-B	<1	
WS- 009800	4/1/2019	4/1/2020	Ground Floor	Bottle Filler	In hallway adjacent to classroom B104	High	WF-04012019-009800	10/31/2019	FT-FY20-102019-009800-A	<1	FT-FY20-102019-009800-B	<1
WS- 009801	4/1/2019	4/1/2020	Ground Floor	Cooler	In hallway adjacent to classroom B104	Low Right	WF-04012019-009801	10/31/2019	FT-FY20-102019-009801-A	<1	FT-FY20-102019-009801-B	<1
WS- 009802	4/1/2019	4/1/2020	Ground Floor	Cooler	In hallway adjacent to classroom B104	Left	WF-04012019-009802	10/31/2019	FT-FY20-102019-009802-A	<1	FT-FY20-102019-009802-B	<1
WS-017023	10/16/2019	10/16/2020	Ground Floor	Bottle Filler	In cafeteria	Low	WF-10162019-017023	10/31/2019	FT-FY20-102019-017023-A	<1	FT-FY20-102019-017023-B	<1
WS-017024	10/16/2019	10/16/2020	Ground Floor	Cooler	In cafeteria	High Left	WF-10162019-017024	10/31/2019	FT-FY20-102019-017024-A	<1	FT-FY20-102019-017024-B	<1
WS-017025	10/16/2019	10/16/2020	Ground Floor	Cooler	In cafeteria	Right	WF-10162019-017025	10/31/2019	FT-FY20-102019-017025-A	<1	FT-FY20-102019-017025-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009601	7/11/2019	7/11/2020	Ground Floor	Food Prep Sink	In kitchen on east wall	WF-07112019-009601	10/31/2019	FT-FY20-102019-009601-A	<1	FT-FY20-102019-009601-B	<1
WS- 009602	7/11/2019	7/11/2020	Ground Floor	Food Prep Sink	In kitchen on north wall Left	WF-07112019-009602	10/31/2019	FT-FY20-102019-009602-A	<1	FT-FY20-102019-009602-B	<1