



KETCHAM LEAD WATER TEST RESULTS

May 16th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009599	Utility	Ground Floor	Boiler Room	WT-042916-9616- A	2	WT-042916-9616- B	< 1				
2	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009600	Other	Ground Floor	Sink in hallway adjacent to Boys bathroom	WT-042916-9617- A	< 1	WT-042916-9617- B	< 1				
3	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009601	Kitchen	Ground Floor	In east wall	WT-042916-9618- A	< 1	WT-042916-9618- B	< 1				
4	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009602	Kitchen	Ground Floor	In kitchen north wall Left	WT-042916-9619- A	< 1	WT-042916-9619- B	< 1				
5	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009604	Fountain	Ground Floor	In dining room	WT-042916-9621- A	< 1	WT-042916-9621- B	< 1				
6	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009605	Cooler	Ground Floor	In hallway next to girls room	WT-042916-9622- A	< 1	WT-042916-9622- B	< 1				
7	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009606	Cooler	1	In hallway adjacent to room A-102	WT-042916-9623- A	< 1	WT-042916-9623- B	< 1				
8	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009607	Classroom	1	In room A-101	WT-042916-9624- A	< 1	WT-042916-9624- B	< 1				
9	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009608	Fountain	1	In room A-101	WT-042916-9625- A	< 1	WT-042916-9625- B	< 1				
10	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009609	Classroom	1	In room B-107	WT-042916-9626- A	< 1	WT-042916-9626- B	< 1				
11	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009610	Health Suite	1	In health 105 suite sink	WT-042916-9627- A	< 1	WT-042916-9627- B	< 1				
12	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009611	Cooler	1	In hallway across from room B-109	WT-042916-9628- A	2	WT-042916-9628- B	3				
13	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009612	Fountain	1	In room 109-B	WT-042916-9629- A	3	WT-042916-9629- B	1				
14	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009613	Classroom	1	In room 109-B	WT-042916-9630- A	1	WT-042916-9630- B	< 1				
15	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009614	Fountain	1	In room 113	WT-042916-9631- A	33	WT-042916-9631- B	4	Filtered	7/1/2016	<1	<1
16	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009615	Classroom	1	In room 113	WT-042916-9632- A	< 1	WT-042916-9632- B	< 1				
17	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009616	Fountain	1	In room B-114	WT-042916-9633- A	2	WT-042916-9633- B	< 1				
18	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009617	Classroom	1	In room B-114	WT-042916-9634- A	< 1	WT-042916-9634- B	< 1				
19	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009618	Classroom	1	In room B-116	WT-042916-9635- A	< 1	WT-042916-9635- B	< 1				
20	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009619	Classroom	1	In room B-116	WT-042916-9636- A	< 1	WT-042916-9636- B	< 1				
21	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009620	Classroom	2	In room 216-B	WT-042916-9637- A	< 1	WT-042916-9637- B	< 1				
22	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009621	Classroom	2	In room 217-B	WT-042916-9638- A	< 1	WT-042916-9638- B	< 1				
23	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009622	Break Room	2	In break room sink	WT-042916-9639- A	< 1	WT-042916-9639- B	< 1				
24	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009623	Classroom	2	In room 207-B	WT-042916-9640- A	< 1	WT-042916-9640- B	< 1				
25	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009624	Cooler	2	In hallway adjacent room B-207	WT-042916-9641- A	< 1	WT-042916-9641- B	< 1				
26	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009625	Classroom	2	In room 211-B Right	WT-042916-9642- A	< 1	WT-042916-9642- B	< 1				
27	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009626	Classroom	2	In B211 Left	WT-042916-9643- A	2	WT-042916-9643- B	< 1				
28	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009627	Classroom	2	In classroom B213	WT-042916-9644- A	< 1	WT-042916-9644- B	< 1				
29	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009628	Classroom	2	In room 214-B	WT-042916-9645- A	< 1	WT-042916-9645- B	< 1				
30	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009629	Classroom	2	In classroom 214 conference room	WT-042916-9646- A	4	WT-042916-9646- B	2				
31	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009630	Cooler	2	In hallway adjacent to 214 conference room	WT-042916-9647- A	144	WT-042916-9647- B	34	Filtered	7/1/2016	<1	<1
32	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009631	Cooler	2	In hallway adjacent to room 205	WT-042916-9648- A	6	WT-042916-9648- B	4				
33	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009632	Classroom	3	In room B-316	WT-042916-9649- A	< 1	WT-042916-9649- B	< 1				
34	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009633	Classroom	3	In classroom B317	WT-042916-9650- A	< 1	WT-042916-9650- B	< 1				
35	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009634	Break Room	3	In 302-B break room	WT-042916-9651- A	< 1	WT-042916-9651- B	< 1				
36	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009635	Classroom	3	In classroom B309	WT-042916-9652- A	< 1	WT-042916-9652- B	< 1				
37	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009636	Cooler	3	In hallway adjacent to stairwell 2	WT-042916-9653- A	< 1	WT-042916-9653- B	< 1				
38	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009637	Classroom	3	In classroom B312	WT-042916-9654- A	< 1	WT-042916-9654- B	< 1				
39	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009638	Classroom	3	In room 313-B	WT-042916-9655- A	< 1	WT-042916-9655- B	< 1				
40	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009639	Classroom	3	In classroom B315	WT-042916-9656- A	< 1	WT-042916-9656- B	< 1				
41	KETCHAM ELEMENTARY SCHOOL	5/12/2016	WS- 009640	Classroom	2	In room B-208	WT-042916-9657- A	2	WT-042916-9657- B	3				

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.