



# KETCHAM ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	KETCHAM ELEMENTARY SCHOOL	WS- 009602	8/24/2016	Ground Floor	Food Prep Sink	In kitchen on north wall Left	FT-72016-009602-A	< 1	FT-72016-009602-B	< 1
2	KETCHAM ELEMENTARY SCHOOL	WS- 009604	8/24/2016	Ground Floor	Cooler	In cafeteria	FT-72016-009604-A	< 1	FT-72016-009604-B	< 1
3	KETCHAM ELEMENTARY SCHOOL	WS- 009605	8/24/2016	Ground Floor	Cooler	In hallway adjacent to girls' restroom	FT-72016-009605-A	< 1	FT-72016-009605-B	< 1
4	KETCHAM ELEMENTARY SCHOOL	WS- 009606	8/24/2016	1	Cooler	In hallway adjacent to room A-102	FT-72016-009606-A	< 1	FT-72016-009606-B	< 1
5	KETCHAM ELEMENTARY SCHOOL	WS- 009608	8/24/2016	1	Fountain	In classroom A-101	FT-72016-009608-A	< 1	FT-72016-009608-B	< 1
6	KETCHAM ELEMENTARY SCHOOL	WS- 009610	8/24/2016	1	Health Suite	In health suite 105	FT-72016-009610-A	< 1	FT-72016-009610-B	< 1
7	KETCHAM ELEMENTARY SCHOOL	WS- 009611	8/24/2016	1	Cooler	In hallway across from room B-109	FT-72016-009611-A	< 1	FT-72016-009611-B	< 1
8	KETCHAM ELEMENTARY SCHOOL	WS- 009612	8/24/2016	1	Fountain	In classroom B-109	FT-72016-009612-A	< 1	FT-72016-009612-B	< 1
9	KETCHAM ELEMENTARY SCHOOL	WS- 009614	8/24/2016	1	Fountain	In classroom B-113	FT-72016-009614-A	< 1	FT-72016-009614-B	< 1
10	KETCHAM ELEMENTARY SCHOOL	WS- 009616	8/24/2016	1	Fountain	In classroom B-114	FT-72016-009616-A	< 1	FT-72016-009616-B	< 1
11	KETCHAM ELEMENTARY SCHOOL	WS- 009618	8/24/2016	1	Fountain	In classroom B-116	FT-72016-009618-A	< 1	FT-72016-009618-B	< 1
12	KETCHAM ELEMENTARY SCHOOL	WS- 009624	8/24/2016	2	Cooler	In hallway adjacent restroom	FT-82016-009624-A	< 1	FT-82016-009624-B	< 1
13	KETCHAM ELEMENTARY SCHOOL	WS- 009630	8/24/2016	2	Cooler	In hallway adjacent to conference room 214	FT-72016-009630-A	< 1	FT-72016-009630-B	< 1
14	KETCHAM ELEMENTARY SCHOOL	WS- 009631	8/24/2016	2	Cooler	In hallway adjacent to room B-205	FT-72016-009631-A	< 1	FT-72016-009631-B	< 1
15	KETCHAM ELEMENTARY SCHOOL	WS- 009636	8/24/2016	3	Cooler	In hallway adjacent to stairwell 2	FT-72016-009636-A	< 1	FT-72016-009636-B	< 1