



KETCHAM ES LEAD WATER TEST RESULTS



Initial Filter Test After Installation

	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	KETCHAM ELEMENTARY SCHOOL	WS- 009622	12/21/2016	2	Break Room	In staff lounge B-202	FT-102016-009622-A	< 1	FT-102016-009622-B	< 1
2	KETCHAM ELEMENTARY SCHOOL	WS- 009634	12/21/2016	3	Break Room	In staff lounge B-302	FT-102016-009634-A	< 1	FT-102016-009634-B	< 1
3	KETCHAM ELEMENTARY SCHOOL	WS- 009799	12/21/2016	1	Break Room	In staff office room B-117	FT-122016-009799-A	< 1	FT-122016-009799-B	< 1
4	KETCHAM ELEMENTARY SCHOOL	WS- 009619	12/21/2016	1	Combo Faucet	In classroom B-116	FT-122016-009619-A	< 1	FT-122016-009619-B	< 1
5	KETCHAM ELEMENTARY SCHOOL	WS- 009617	12/21/2016	1	Combo Faucet	In classroom B-114	FT-122016-009617-A	< 1	FT-122016-009617-B	< 1
6	KETCHAM ELEMENTARY SCHOOL	WS- 009607	12/21/2016	1	Combo Faucet	In classroom A-101	FT-122016-009607-A	< 1	FT-122016-009607-B	< 1
7	KETCHAM ELEMENTARY SCHOOL	WS- 009613	12/21/2016	1	Combo Faucet	In classroom B-109	FT-122016-009613-A	< 1	FT-122016-009613-B	< 1
8	KETCHAM ELEMENTARY SCHOOL	WS- 009615	12/21/2016	1	Combo Faucet	In classroom B-113	FT-122016-009615-A	< 1	FT-122016-009615-B	< 1

Note :

Filter re-tests are only performed to devices that have sampling results greater than 1 ppb