



# Key ES Lead in Water Test Results



## FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-001454	5/7/2019	5/7/2020	Basement	Bottle Filler	In lobby adjacent to restrooms (bottle filler)	WF-05072019-001454	12/17/2019	FT-FY20-112019-001454-A	<1	FT-FY20-112019-001454-B	<1	
WS-001455	5/7/2019	5/7/2020	1	Health Suite	In health suite	Mid	WF-05072019-001455	12/17/2019	FT-FY20-112019-001455-A	<1	FT-FY20-112019-001455-B	<1
WS-001457	5/7/2019	5/7/2020	Basement	Cooler	In lobby adjacent to restrooms	WF-05072019-001457	12/17/2019	FT-FY20-112019-001457-A	<1	FT-FY20-112019-001457-B	<1	
WS-001458	9/16/2019	9/16/2020	1	Combo Faucet	In classroom 106	Left	WF-09162019-001458	12/17/2019	FT-FY20-112019-001458-A	<1	FT-FY20-112019-001458-B	<1
WS-001459	5/7/2019	5/7/2020	1	Combo Fountain	In classroom 106	Right	WF-05072019-001459	12/17/2019	FT-FY20-112019-001459-A	<1	FT-FY20-112019-001459-B	<1
WS-001460	5/7/2019	5/7/2020	1	Cooler	In hallway adjacent to room 104	WF-05072019-001460	12/17/2019	FT-FY20-112019-001460-A	<1	FT-FY20-112019-001460-B	<1	
WS-001461	5/7/2019	5/7/2020	1	Cooler	In hallway adjacent to room 103	WF-05072019-001461	12/17/2019	FT-FY20-112019-001461-A	<1	FT-FY20-112019-001461-B	<1	
WS-001462	9/16/2019	9/16/2020	1	Combo Faucet	In classroom 104	Left	WF-09162019-001462	12/17/2019	FT-FY20-112019-001462-A	<1	FT-FY20-112019-001462-B	<1
WS-001463	5/7/2019	5/7/2020	1	Combo Fountain	In classroom 104	Right	WF-05072019-001463	12/17/2019	FT-FY20-112019-001463-A	<1	FT-FY20-112019-001463-B	<1
WS-001464	9/16/2019	9/16/2020	1	Combo Faucet	In classroom 102	Right	WF-09162019-001464	12/17/2019	FT-FY20-112019-001464-A	<1	FT-FY20-112019-001464-B	<1
WS-001465	5/7/2019	5/7/2020	1	Combo Fountain	In classroom 102	Right	WF-05072019-001465	12/17/2019	FT-FY20-112019-001465-A	<1	FT-FY20-112019-001465-B	<1
WS-001466	9/16/2019	9/16/2020	1	Combo Faucet	In classroom 101	Left	WF-09162019-001466	12/17/2019	FT-FY20-112019-001466-A	<1	FT-FY20-112019-001466-B	<1
WS-001467	5/7/2019	5/7/2020	1	Combo Fountain	In classroom 101	Right	WF-05072019-001467	12/17/2019	FT-FY20-112019-001467-A	<1	FT-FY20-112019-001467-B	<1
WS-001468	9/16/2019	9/16/2020	1	Combo Faucet	In classroom 103	Left	WF-09162019-001468	12/17/2019	FT-FY20-112019-001468-A	<1	FT-FY20-112019-001468-B	<1
WS-001469	5/7/2019	5/7/2020	1	Combo Fountain	In classroom 103	Right	WF-05072019-001469	12/17/2019	FT-FY20-112019-001469-A	<1	FT-FY20-112019-001469-B	<1
WS-001470	9/16/2019	9/16/2020	1	Combo Faucet	In classroom 105	Left	WF-09162019-001470	12/17/2019	FT-FY20-112019-001470-A	<1	FT-FY20-112019-001470-B	<1
WS-001471	5/7/2019	5/7/2020	1	Combo Fountain	In classroom 105	Right	WF-05072019-001471	12/17/2019	FT-FY20-112019-001471-A	<1	FT-FY20-112019-001471-B	<1
WS-001472	5/7/2019	5/7/2020	2	Break Room	In staff lounge	Mid	WF-05072019-001472	12/17/2019	FT-FY20-112019-001472-A	<1	FT-FY20-112019-001472-B	<1
WS-001473	5/7/2019	5/7/2020	2	Cooler	In hallway across from janitor closet	WF-05072019-001473	12/17/2019	FT-FY20-112019-001473-A	<1	FT-FY20-112019-001473-B	<1	
WS-001474	9/16/2019	9/16/2020	2	Combo Faucet	In classroom 208	Left	WF-09162019-001474	12/17/2019	FT-FY20-112019-001474-A	<1	FT-FY20-112019-001474-B	<1
WS-001475	5/7/2019	5/7/2020	2	Combo Fountain	In classroom 208	Right	WF-05072019-001475	12/17/2019	FT-FY20-112019-001475-A	<1	FT-FY20-112019-001475-B	<1
WS-001476	9/16/2019	9/16/2020	2	Combo Faucet	In classroom 212	Left	WF-09162019-001476	12/17/2019	FT-FY20-112019-001476-A	<1	FT-FY20-112019-001476-B	<1
WS-001477	5/7/2019	5/7/2020	2	Combo Fountain	In classroom 212	Right	WF-05072019-001477	12/17/2019	FT-FY20-112019-001477-A	<1	FT-FY20-112019-001477-B	<1
WS-001478	9/16/2019	9/16/2020	2	Combo Faucet	In classroom 211	Left	WF-09162019-001478	12/17/2019	FT-FY20-112019-001478-A	<1	FT-FY20-112019-001478-B	<1
WS-001479	5/7/2019	5/7/2020	2	Combo Fountain	In classroom 211	Right	WF-05072019-001479	12/17/2019	FT-FY20-112019-001479-A	<1	FT-FY20-112019-001479-B	<1
WS-001480	9/16/2019	9/16/2020	2	Combo Faucet	In classroom 207	Left	WF-09162019-001480	12/17/2019	FT-FY20-112019-001480-A	<1	FT-FY20-112019-001480-B	<1
WS-001481	5/7/2019	5/7/2020	2	Combo Fountain	In classroom 207	Right	WF-05072019-001481	12/17/2019	FT-FY20-112019-001481-A	<1	FT-FY20-112019-001481-B	<1
WS-001482	9/16/2019	9/16/2020	2	Combo Faucet	In classroom 210	Left	WF-09162019-001482	12/17/2019	FT-FY20-112019-001482-A	<1	FT-FY20-112019-001482-B	<1
WS-001483	5/7/2019	5/7/2020	2	Combo Fountain	In Classroom 210	Right	WF-05072019-001483	12/17/2019	FT-FY20-112019-001483-A	<1	FT-FY20-112019-001483-B	<1
WS-001484	9/16/2019	9/16/2020	2	Combo Faucet	In classroom 209	Left	WF-09162019-001484	12/17/2019	FT-FY20-112019-001484-A	<1	FT-FY20-112019-001484-B	<1
WS-001485	5/7/2019	5/7/2020	2	Combo Fountain	In Classroom 209	Right	WF-05072019-001485	12/17/2019	FT-FY20-112019-001485-A	<1	FT-FY20-112019-001485-B	<1

WS- 001486	9/16/2019	9/16/2020	2	Combo Faucet	In classroom 206	Left	WF-09162019-001486	12/17/2019	FT-FY20-112019-001486-A	<1	FT-FY20-112019-001486-B	<1
WS- 001487	5/7/2019	5/7/2020	2	Combo Fountain	In classroom 206	Left	WF-05072019-001487	12/17/2019	FT-FY20-112019-001487-A	<1	FT-FY20-112019-001487-B	<1
WS- 001488	9/16/2019	9/16/2020	2	Combo Faucet	In classroom 206	Right	WF-09162019-001488	12/17/2019	FT-FY20-112019-001488-A	<1	FT-FY20-112019-001488-B	<1
WS- 001489	5/7/2019	5/7/2020	2	Combo Fountain	In classroom 206	Right	WF-05072019-001489	12/17/2019	FT-FY20-112019-001489-A	<1	FT-FY20-112019-001489-B	<1
WS- 001490	9/16/2019	9/16/2020	2	Combo Faucet	In classroom 205		WF-09162019-001490	12/17/2019	FT-FY20-112019-001490-A	<1	FT-FY20-112019-001490-B	<1
WS- 001491	5/7/2019	5/7/2020	2	Combo Fountain	In classroom 205		WF-05072019-001491	12/17/2019	FT-FY20-112019-001491-A	<1	FT-FY20-112019-001491-B	<1
WS- 001492	5/7/2019	5/7/2020	2	Cooler	In hallway adjacent to room 204		WF-05072019-001492	12/17/2019	FT-FY20-112019-001492-A	<1	FT-FY20-112019-001492-B	<1
WS- 001493	9/16/2019	9/16/2020	2	Combo Faucet	In classroom 203	Left	WF-09162019-001493	12/17/2019	FT-FY20-112019-001493-A	<1	FT-FY20-112019-001493-B	<1
WS- 001494	5/7/2019	5/7/2020	2	Combo Fountain	In classroom 203	Right	WF-05072019-001494	12/17/2019	FT-FY20-112019-001494-A	<1	FT-FY20-112019-001494-B	<1
WS- 001495	9/16/2019	9/16/2020	2	Combo Faucet	In classroom 204	Left	WF-09162019-001495	12/17/2019	FT-FY20-112019-001495-A	<1	FT-FY20-112019-001495-B	<1
WS- 001496	5/7/2019	5/7/2020	2	Combo Fountain	In classroom 204	Right	WF-05072019-001496	12/17/2019	FT-FY20-112019-001496-A	<1	FT-FY20-112019-001496-B	<1
WS- 001497	9/16/2019	9/16/2020	2	Combo Faucet	In classroom 201	Left	WF-09162019-001497	12/17/2019	FT-FY20-112019-001497-A	<1	FT-FY20-112019-001497-B	<1
WS- 001498	5/7/2019	5/7/2020	2	Combo Fountain	In classroom 201	Right	WF-05072019-001498	12/17/2019	FT-FY20-112019-001498-A	<1	FT-FY20-112019-001498-B	<1
WS- 001499	9/16/2019	9/16/2020	2	Combo Faucet	In classroom 202	Left	WF-09162019-001499	12/17/2019	FT-FY20-112019-001499-A	<1	FT-FY20-112019-001499-B	<1
WS- 001500	5/7/2019	5/7/2020	2	Combo Fountain	In classroom 202	Right	WF-05072019-001500	12/17/2019	FT-FY20-112019-001500-A	<1	FT-FY20-112019-001500-B	<1
WS- 001503	9/16/2019	9/16/2020	1	Bathroom	In classroom 101 in bathroom		WF-09162019-001503	12/17/2019	FT-FY20-112019-001503-A	<1	FT-FY20-112019-001503-B	<1
WS- 001504	9/16/2019	9/16/2020	1	Bathroom	In classroom 102 in bathroom		WF-09162019-001504	12/17/2019	FT-FY20-112019-001504-A	<1	FT-FY20-112019-001504-B	<1
WS- 001505	9/16/2019	9/16/2020	1	Bathroom	In classroom 103 in bathroom		WF-09162019-001505	12/17/2019	FT-FY20-112019-001505-A	<1	FT-FY20-112019-001505-B	<1
WS- 001506	9/16/2019	9/16/2020	1	Bathroom	In classroom 104 in bathroom		WF-09162019-001506	12/17/2019	FT-FY20-112019-001506-A	<1	FT-FY20-112019-001506-B	<1
WS- 001507	9/16/2019	9/16/2020	1	Bathroom	In classroom 105 in bathroom		WF-09162019-001507	12/17/2019	FT-FY20-112019-001507-A	<1	FT-FY20-112019-001507-B	<1
WS- 001508	9/16/2019	9/16/2020	1	Bathroom	In classroom 106 in bathroom		WF-09162019-001508	12/17/2019	FT-FY20-112019-001508-A	<1	FT-FY20-112019-001508-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 001450	7/9/2019	7/9/2020	Basement	Food Prep Sink	In kitchen second clockwise from entry door	Mid	WF-07092019-001450	12/17/2019	FT-FY20-112019-001450-A	<1	FT-FY20-112019-001450-B	<1