



Key Elementary School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 001455	5/26/2021	5/26/2022	1	Health Suite	In health suite	Mid	WF-05262021-001455	12/9/2021	FT-FY22-11222021-001455-A	<1	FT-FY22-11222021-001455-B	<1
WS- 001458	8/30/2021	8/30/2022	1	Combo Faucet	In classroom 106	Left	WF-08302021-001458	12/9/2021	FT-FY22-11222021-001458-A	<1	FT-FY22-11222021-001458-B	<1
WS- 001459	5/26/2021	5/26/2022	1	Combo Fountain	In classroom 106	Right	WF-05262021-001459	12/9/2021	FT-FY22-11222021-001459-A	<1	FT-FY22-11222021-001459-B	<1
WS- 001460	5/26/2021	5/26/2022	1	Cooler	In hallway adjacent to room 104		WF-05262021-001460	12/9/2021	FT-FY22-11222021-001460-A	<1	FT-FY22-11222021-001460-B	<1
WS- 001461	5/26/2021	5/26/2022	1	Cooler	In hallway adjacent to room 103		WF-05262021-001461	12/9/2021	FT-FY22-11222021-001461-A	<1	FT-FY22-11222021-001461-B	<1
WS- 001462	8/30/2021	8/30/2022	1	Combo Faucet	In classroom 104	Left	WF-08302021-001462	12/9/2021	FT-FY22-11222021-001462-A	<1	FT-FY22-11222021-001462-B	<1
WS- 001463	5/26/2021	5/26/2022	1	Combo Fountain	In classroom 104	Right	WF-05262021-001463	12/9/2021	FT-FY22-11222021-001463-A	<1	FT-FY22-11222021-001463-B	<1
WS- 001464	8/30/2021	8/30/2022	1	Combo Faucet	In classroom 102	Right	WF-08302021-001464	12/9/2021	FT-FY22-11222021-001464-A	<1	FT-FY22-11222021-001464-B	<1
WS- 001465	5/26/2021	5/26/2022	1	Combo Fountain	In classroom 102	Right	WF-05262021-001465	12/9/2021	FT-FY22-11222021-001465-A	<1	FT-FY22-11222021-001465-B	<1
WS- 001466	8/30/2021	8/30/2022	1	Combo Faucet	In classroom 101	Left	WF-08302021-001466	12/9/2021	FT-FY22-11222021-001466-A	<1	FT-FY22-11222021-001466-B	<1
WS- 001467	5/26/2021	5/26/2022	1	Combo Fountain	In classroom 101	Right	WF-05262021-001467	12/9/2021	FT-FY22-11222021-001467-A	<1	FT-FY22-11222021-001467-B	<1
WS- 001468	8/30/2021	8/30/2022	1	Combo Faucet	In classroom 103	Left	WF-08302021-001468	12/9/2021	FT-FY22-11222021-001468-A	<1	FT-FY22-11222021-001468-B	<1
WS- 001469	5/26/2021	5/26/2022	1	Combo Fountain	In classroom 103	Right	WF-05262021-001469	12/9/2021	FT-FY22-11222021-001469-A	<1	FT-FY22-11222021-001469-B	<1
WS- 001470	8/30/2021	8/30/2022	1	Combo Faucet	In classroom 105	Left	WF-08302021-001470	12/9/2021	FT-FY22-11222021-001470-A	<1	FT-FY22-11222021-001470-B	<1
WS- 001471	5/26/2021	5/26/2022	1	Combo Fountain	In classroom 105	Right	WF-05262021-001471	12/9/2021	FT-FY22-11222021-001471-A	<1	FT-FY22-11222021-001471-B	<1
WS- 001472	5/26/2021	5/26/2022	2	Break Room	In staff lounge	Mid	WF-05262021-001472	12/9/2021	FT-FY22-11222021-001472-A	<1	FT-FY22-11222021-001472-B	<1
WS- 001474	8/30/2021	8/30/2022	2	Combo Faucet	In classroom 208	Left	WF-08302021-001474	12/9/2021	FT-FY22-11222021-001474-A	<1	FT-FY22-11222021-001474-B	<1
WS- 001475	5/26/2021	5/26/2022	2	Combo Fountain	In classroom 208	Right	WF-05262021-001475	12/9/2021	FT-FY22-11222021-001475-A	<1	FT-FY22-11222021-001475-B	<1
WS- 001476	8/30/2021	8/30/2022	2	Combo Faucet	In classroom 212	Left	WF-08302021-001476	12/9/2021	FT-FY22-11222021-001476-A	<1	FT-FY22-11222021-001476-B	<1
WS- 001477	5/26/2021	5/26/2022	2	Combo Fountain	In classroom 212	Right	WF-05262021-001477	12/9/2021	FT-FY22-11222021-001477-A	<1	FT-FY22-11222021-001477-B	<1
WS- 001478	8/30/2021	8/30/2022	2	Combo Faucet	In classroom 211	Left	WF-08302021-001478	12/9/2021	FT-FY22-11222021-001478-A	<1	FT-FY22-11222021-001478-B	<1
WS- 001479	5/26/2021	5/26/2022	2	Combo Fountain	In classroom 211	Right	WF-05262021-001479	12/9/2021	FT-FY22-11222021-001479-A	<1	FT-FY22-11222021-001479-B	<1
WS- 001480	8/30/2021	8/30/2022	2	Combo Faucet	In classroom 207	Left	WF-08302021-001480	12/9/2021	FT-FY22-11222021-001480-A	<1	FT-FY22-11222021-001480-B	<1
WS- 001481	5/26/2021	5/26/2022	2	Combo Fountain	In classroom 207	Right	WF-05262021-001481	12/9/2021	FT-FY22-11222021-001481-A	<1	FT-FY22-11222021-001481-B	<1
WS- 001482	8/30/2021	8/30/2022	2	Combo Faucet	In classroom 210	Left	WF-08302021-001482	12/9/2021	FT-FY22-11222021-001482-A	<1	FT-FY22-11222021-001482-B	<1
WS- 001483	5/26/2021	5/26/2022	2	Combo Fountain	In Classroom 210	Right	WF-05262021-001483	12/9/2021	FT-FY22-11222021-001483-A	<1	FT-FY22-11222021-001483-B	<1
WS- 001484	8/30/2021	8/30/2022	2	Combo Faucet	In classroom 209	Left	WF-08302021-001484	12/9/2021	FT-FY22-11222021-001484-A	<1	FT-FY22-11222021-001484-B	<1
WS- 001485	5/26/2021	5/26/2022	2	Combo Fountain	In Classroom 209	Right	WF-05262021-001485	12/9/2021	FT-FY22-11222021-001485-A	<1	FT-FY22-11222021-001485-B	<1
WS- 001486	8/30/2021	8/30/2022	2	Combo Faucet	In classroom 206	Left	WF-08302021-001486	12/9/2021	FT-FY22-11222021-001486-A	<1	FT-FY22-11222021-001486-B	<1
WS- 001487	5/26/2021	5/26/2022	2	Combo Fountain	In classroom 206	Left	WF-05262021-001487	12/9/2021	FT-FY22-11222021-001487-A	<1	FT-FY22-11222021-001487-B	<1
WS- 001488	8/30/2021	8/30/2022	2	Combo Faucet	In classroom 206	Right	WF-08302021-001488	12/9/2021	FT-FY22-11222021-001488-A	<1	FT-FY22-11222021-001488-B	<1
WS- 001489	5/26/2021	5/26/2022	2	Combo Fountain	In classroom 206	Right	WF-05262021-001489	12/9/2021	FT-FY22-11222021-001489-A	<1	FT-FY22-11222021-001489-B	<1
WS- 001490	8/30/2021	8/30/2022	2	Combo Faucet	In classroom 205		WF-08302021-001490	12/9/2021	FT-FY22-11222021-001490-A	<1	FT-FY22-11222021-001490-B	<1
WS- 001491	5/26/2021	5/26/2022	2	Combo Fountain	In classroom 205		WF-05262021-001491	12/9/2021	FT-FY22-11222021-001491-A	<1	FT-FY22-11222021-001491-B	<1
WS- 001493	8/30/2021	8/30/2022	2	Combo Faucet	In classroom 203	Left	WF-08302021-001493	12/9/2021	FT-FY22-11222021-001493-A	<1	FT-FY22-11222021-001493-B	<1

WS- 001494	5/26/2021	5/26/2022	2	Combo Fountain	In classroom 203	Right	WF-05262021-001494	12/9/2021	FT-FY22-11222021-001494-A	<1	FT-FY22-11222021-001494-B	<1
WS- 001495	8/30/2021	8/30/2022	2	Combo Faucet	In classroom 204	Left	WF-08302021-001495	12/9/2021	FT-FY22-11222021-001495-A	<1	FT-FY22-11222021-001495-B	<1
WS- 001496	5/26/2021	5/26/2022	2	Combo Fountain	In classroom 204	Right	WF-05262021-001496	12/9/2021	FT-FY22-11222021-001496-A	<1	FT-FY22-11222021-001496-B	<1
WS- 001497	8/30/2021	8/30/2022	2	Combo Faucet	In classroom 201	Left	WF-08302021-001497	12/9/2021	FT-FY22-11222021-001497-A	<1	FT-FY22-11222021-001497-B	<1
WS- 001498	5/26/2021	5/26/2022	2	Combo Fountain	In classroom 201	Right	WF-05262021-001498	12/9/2021	FT-FY22-11222021-001498-A	<1	FT-FY22-11222021-001498-B	<1
WS- 001499	8/30/2021	8/30/2022	2	Combo Faucet	In classroom 202	Left	WF-08302021-001499	12/9/2021	FT-FY22-11222021-001499-A	<1	FT-FY22-11222021-001499-B	<1
WS- 001500	5/26/2021	5/26/2022	2	Combo Fountain	In classroom 202	Right	WF-05262021-001500	12/9/2021	FT-FY22-11222021-001500-A	<1	FT-FY22-11222021-001500-B	<1
WS- 001503	8/30/2021	8/30/2022	1	Bathroom	In classroom 101 in bathroom		WF-08302021-001503	12/9/2021	FT-FY22-11222021-001503-A	<1	FT-FY22-11222021-001503-B	<1
WS- 001504	8/30/2021	8/30/2022	1	Bathroom	In classroom 102 in bathroom		WF-08302021-001504	12/9/2021	FT-FY22-11222021-001504-A	<1	FT-FY22-11222021-001504-B	<1
WS- 001505	8/30/2021	8/30/2022	1	Bathroom	In classroom 103 in bathroom		WF-08302021-001505	12/9/2021	FT-FY22-11222021-001505-A	<1	FT-FY22-11222021-001505-B	<1
WS- 001506	8/30/2021	8/30/2022	1	Bathroom	In classroom 104 in bathroom		WF-08302021-001506	12/9/2021	FT-FY22-11222021-001506-A	<1	FT-FY22-11222021-001506-B	<1
WS- 001507	8/30/2021	8/30/2022	1	Bathroom	In classroom 105 in bathroom		WF-08302021-001507	12/9/2021	FT-FY22-11222021-001507-A	<1	FT-FY22-11222021-001507-B	<1
WS- 001508	8/30/2021	8/30/2022	1	Bathroom	In classroom 106 in bathroom		WF-08302021-001508	12/9/2021	FT-FY22-11222021-001508-A	<1	FT-FY22-11222021-001508-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 001450	1/25/2021	1/25/2022	Basement	Food Prep Sink	In kitchen second clockwise from entry door	Mid	WF-01252021-001450	12/9/2021	FT-FY22-11222021-001450-A	<1	FT-FY22-11222021-001450-B	<1