



# Key Elementary School Lead in Water Test Results



## FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-001455	6/23/2020	6/23/2021	1	Health Suite	In health suite Mid	WF-06232020-001455	2/12/2021	FT-FY21-022021-001455-A	<1	FT-FY21-022021-001455-B	<1
WS-001458	9/9/2020	9/9/2021	1	Combo Faucet	In classroom 106 Left	WF-09092020-001458	2/12/2021	FT-FY21-022021-001458-A	<1	FT-FY21-022021-001458-B	<1
WS-001459	6/23/2020	6/23/2021	1	Combo Fountain	In classroom 106 Right	WF-06232020-001459	2/12/2021	FT-FY21-022021-001459-A	<1	FT-FY21-022021-001459-B	<1
WS-001460	6/23/2020	6/23/2021	1	Cooler	In hallway adjacent to room 104	WF-06232020-001460	2/12/2021	FT-FY21-022021-001460-A	<1	FT-FY21-022021-001460-B	<1
WS-001461	6/23/2020	6/23/2021	1	Cooler	In hallway adjacent to room 103	WF-06232020-001461	2/12/2021	FT-FY21-022021-001461-A	<1	FT-FY21-022021-001461-B	<1
WS-001462	9/9/2020	9/9/2021	1	Combo Faucet	In classroom 104 Left	WF-09092020-001462	2/12/2021	FT-FY21-022021-001462-A	<1	FT-FY21-022021-001462-B	<1
WS-001463	6/23/2020	6/23/2021	1	Combo Fountain	In classroom 104 Right	WF-06232020-001463	2/12/2021	FT-FY21-022021-001463-A	<1	FT-FY21-022021-001463-B	<1
WS-001464	9/9/2020	9/9/2021	1	Combo Faucet	In classroom 102 Right	WF-09092020-001464	2/12/2021	FT-FY21-022021-001464-A	<1	FT-FY21-022021-001464-B	<1
WS-001465	6/23/2020	6/23/2021	1	Combo Fountain	In classroom 102 Right	WF-06232020-001465	2/12/2021	FT-FY21-022021-001465-A	<1	FT-FY21-022021-001465-B	<1
WS-001466	9/9/2020	9/9/2021	1	Combo Faucet	In classroom 101 Left	WF-09092020-001466	2/12/2021	FT-FY21-022021-001466-A	<1	FT-FY21-022021-001466-B	<1
WS-001467	6/23/2020	6/23/2021	1	Combo Fountain	In classroom 101 Right	WF-06232020-001467	2/12/2021	FT-FY21-022021-001467-A	<1	FT-FY21-022021-001467-B	<1
WS-001468	9/9/2020	9/9/2021	1	Combo Faucet	In classroom 103 Left	WF-09092020-001468	2/12/2021	FT-FY21-022021-001468-A	<1	FT-FY21-022021-001468-B	<1
WS-001469	6/23/2020	6/23/2021	1	Combo Fountain	In classroom 103 Right	WF-06232020-001469	2/12/2021	FT-FY21-022021-001469-A	<1	FT-FY21-022021-001469-B	<1
WS-001470	9/9/2020	9/9/2021	1	Combo Faucet	In classroom 105 Left	WF-09092020-001470	2/12/2021	FT-FY21-022021-001470-A	<1	FT-FY21-022021-001470-B	<1
WS-001471	6/23/2020	6/23/2021	1	Combo Fountain	In classroom 105 Right	WF-06232020-001471	2/12/2021	FT-FY21-022021-001471-A	<1	FT-FY21-022021-001471-B	<1
WS-001472	6/23/2020	6/23/2021	2	Break Room	In staff lounge Mid	WF-06232020-001472	2/12/2021	FT-FY21-022021-001472-A	<1	FT-FY21-022021-001472-B	<1
WS-001474	9/9/2020	9/9/2021	2	Combo Faucet	In classroom 208 Left	WF-09092020-001474	2/12/2021	FT-FY21-022021-001474-A	<1	FT-FY21-022021-001474-B	<1
WS-001475	6/23/2020	6/23/2021	2	Combo Fountain	In classroom 208 Right	WF-06232020-001475	2/12/2021	FT-FY21-022021-001475-A	<1	FT-FY21-022021-001475-B	<1
WS-001476	9/9/2020	9/9/2021	2	Combo Faucet	In classroom 212 Left	WF-09092020-001476	2/12/2021	FT-FY21-022021-001476-A	<1	FT-FY21-022021-001476-B	<1
WS-001477	6/23/2020	6/23/2021	2	Combo Fountain	In classroom 212 Right	WF-06232020-001477	2/12/2021	FT-FY21-022021-001477-A	<1	FT-FY21-022021-001477-B	<1
WS-001478	9/9/2020	9/9/2021	2	Combo Faucet	In classroom 211 Left	WF-09092020-001478	2/12/2021	FT-FY21-022021-001478-A	<1	FT-FY21-022021-001478-B	<1
WS-001479	6/23/2020	6/23/2021	2	Combo Fountain	In classroom 211 Right	WF-06232020-001479	2/12/2021	FT-FY21-022021-001479-A	<1	FT-FY21-022021-001479-B	<1
WS-001480	9/9/2020	9/9/2021	2	Combo Faucet	In classroom 207 Left	WF-09092020-001480	2/12/2021	FT-FY21-022021-001480-A	<1	FT-FY21-022021-001480-B	<1
WS-001481	6/23/2020	6/23/2021	2	Combo Fountain	In classroom 207 Right	WF-06232020-001481	2/12/2021	FT-FY21-022021-001481-A	<1	FT-FY21-022021-001481-B	<1
WS-001482	9/9/2020	9/9/2021	2	Combo Faucet	In classroom 210 Left	WF-09092020-001482	2/12/2021	FT-FY21-022021-001482-A	<1	FT-FY21-022021-001482-B	<1
WS-001483	6/23/2020	6/23/2021	2	Combo Fountain	In Classroom 210 Right	WF-06232020-001483	2/12/2021	FT-FY21-022021-001483-A	<1	FT-FY21-022021-001483-B	<1
WS-001484	9/9/2020	9/9/2021	2	Combo Faucet	In classroom 209 Left	WF-09092020-001484	2/12/2021	FT-FY21-022021-001484-A	<1	FT-FY21-022021-001484-B	<1
WS-001485	6/23/2020	6/23/2021	2	Combo Fountain	In Classroom 209 Right	WF-06232020-001485	2/12/2021	FT-FY21-022021-001485-A	<1	FT-FY21-022021-001485-B	<1
WS-001486	9/9/2020	9/9/2021	2	Combo Faucet	In classroom 206 Left	WF-09092020-001486	2/12/2021	FT-FY21-022021-001486-A	<1	FT-FY21-022021-001486-B	<1
WS-001487	6/23/2020	6/23/2021	2	Combo Fountain	In classroom 206 Left	WF-06232020-001487	2/12/2021	FT-FY21-022021-001487-A	<1	FT-FY21-022021-001487-B	<1
WS-001488	9/9/2020	9/9/2021	2	Combo Faucet	In classroom 206 Right	WF-09092020-001488	2/12/2021	FT-FY21-022021-001488-A	<1	FT-FY21-022021-001488-B	<1
WS-001489	6/23/2020	6/23/2021	2	Combo Fountain	In classroom 206 Right	WF-06232020-001489	2/12/2021	FT-FY21-022021-001489-A	<1	FT-FY21-022021-001489-B	<1

WS- 001490	9/9/2020	9/9/2021	2	Combo Faucet	In classroom 205		WF-09092020-001490	2/12/2021	FT-FY21-022021-001490-A	<1	FT-FY21-022021-001490-B	<1
WS- 001491	6/23/2020	6/23/2021	2	Combo Fountain	In classroom 205		WF-06232020-001491	2/12/2021	FT-FY21-022021-001491-A	<1	FT-FY21-022021-001491-B	<1
WS- 001492	7/7/2020	7/7/2021	2	Cooler	In hallway adjacent to room 204		WF-07072020-001492	2/12/2021	FT-FY21-022021-001492-A	<1	FT-FY21-022021-001492-B	<1
WS- 001493	9/9/2020	9/9/2021	2	Combo Faucet	In classroom 203	Left	WF-09092020-001493	2/12/2021	FT-FY21-022021-001493-A	<1	FT-FY21-022021-001493-B	<1
WS- 001494	6/23/2020	6/23/2021	2	Combo Fountain	In classroom 203	Right	WF-06232020-001494	2/12/2021	FT-FY21-022021-001494-A	<1	FT-FY21-022021-001494-B	<1
WS- 001495	9/9/2020	9/9/2021	2	Combo Faucet	In classroom 204	Left	WF-09092020-001495	2/12/2021	FT-FY21-022021-001495-A	<1	FT-FY21-022021-001495-B	<1
WS- 001496	6/23/2020	6/23/2021	2	Combo Fountain	In classroom 204	Right	WF-06232020-001496	2/12/2021	FT-FY21-022021-001496-A	<1	FT-FY21-022021-001496-B	<1
WS- 001497	9/9/2020	9/9/2021	2	Combo Faucet	In classroom 201	Left	WF-09092020-001497	2/12/2021	FT-FY21-022021-001497-A	<1	FT-FY21-022021-001497-B	<1
WS- 001498	6/23/2020	6/23/2021	2	Combo Fountain	In classroom 201	Right	WF-06232020-001498	2/12/2021	FT-FY21-022021-001498-A	<1	FT-FY21-022021-001498-B	<1
WS- 001499	9/9/2020	9/9/2021	2	Combo Faucet	In classroom 202	Left	WF-09092020-001499	2/12/2021	FT-FY21-022021-001499-A	<1	FT-FY21-022021-001499-B	<1
WS- 001500	6/23/2020	6/23/2021	2	Combo Fountain	In classroom 202	Right	WF-06232020-001500	2/12/2021	FT-FY21-022021-001500-A	<1	FT-FY21-022021-001500-B	<1
WS- 001503	9/9/2020	9/9/2021	1	Bathroom	In classroom 101 in bathroom		WF-09092020-001503	2/12/2021	FT-FY21-022021-001503-A	1.6	FT-FY21-022021-001503-B	<1
WS- 001504	9/9/2020	9/9/2021	1	Bathroom	In classroom 102 in bathroom		WF-09092020-001504	2/12/2021	FT-FY21-022021-001504-A	<1	FT-FY21-022021-001504-B	<1
WS- 001505	9/9/2020	9/9/2021	1	Bathroom	In classroom 103 in bathroom		WF-09092020-001505	2/12/2021	FT-FY21-022021-001505-A	<1	FT-FY21-022021-001505-B	<1
WS- 001506	9/9/2020	9/9/2021	1	Bathroom	In classroom 104 in bathroom		WF-09092020-001506	2/12/2021	FT-FY21-022021-001506-A	1.3	FT-FY21-022021-001506-B	<1
WS- 001507	9/9/2020	9/9/2021	1	Bathroom	In classroom 105 in bathroom		WF-09092020-001507	2/12/2021	FT-FY21-022021-001507-A	2.8	FT-FY21-022021-001507-B	<1
WS- 001508	9/9/2020	9/9/2021	1	Bathroom	In classroom 106 in bathroom		WF-09092020-001508	2/12/2021	FT-FY21-022021-001508-A	<1	FT-FY21-022021-001508-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 001450	1/25/2021	1/25/2022	Basement	Food Prep Sink	In kitchen second clockwise from entry door	Mid	WF-01252021-001450	2/12/2021	FT-FY21-022021-001450-A	<1	FT-FY21-022021-001450-B	<1