



# Key Elementary School Lead in Water Test Results

## FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 001454	5/16/2022	5/16/2023	Basement	Bottle Filler	In lobby adjacent to restrooms (bottle filler)	WF-05162022-001454	1/4/2023	FT-FY23-11182022-001454-A	<1	FT-FY23-11182022-001454-B	<1	
WS- 001455	5/16/2022	5/16/2023	1	Health Suite	In health suite	Mid	WF-05162022-001455	1/4/2023	FT-FY23-11182022-001455-A	<1	FT-FY23-11182022-001455-B	<1
WS- 001457	5/16/2022	5/16/2023	Basement	Cooler	In lobby adjacent to restrooms		WF-05162022-001457	1/4/2023	FT-FY23-11182022-001457-A	<1	FT-FY23-11182022-001457-B	<1
WS- 001458	8/23/2022	8/23/2023	1	Combo Faucet	In classroom 106	Left	WF-08232022-001458	1/4/2023	FT-FY23-11182022-001458-A	<1	FT-FY23-11182022-001458-B	<1
WS- 001459	5/16/2022	5/16/2023	1	Combo Fountain	In classroom 106	Right	WF-05162022-001459	1/4/2023	FT-FY23-11182022-001459-A	<1	FT-FY23-11182022-001459-B	<1
WS- 001460	5/16/2022	5/16/2023	1	Cooler	In hallway adjacent to room 104		WF-05162022-001460	1/4/2023	FT-FY23-11182022-001460-A	<1	FT-FY23-11182022-001460-B	<1
WS- 001461	5/16/2022	5/16/2023	1	Cooler	In hallway adjacent to room 103		WF-05162022-001461	1/4/2023	FT-FY23-11182022-001461-A	<1	FT-FY23-11182022-001461-B	<1
WS- 001462	8/23/2022	8/23/2023	1	Combo Faucet	In classroom 104	Left	WF-08232022-001462	1/4/2023	FT-FY23-11182022-001462-A	<1	FT-FY23-11182022-001462-B	<1
WS- 001463	5/16/2022	5/16/2023	1	Combo Fountain	In classroom 104	Right	WF-05162022-001463	1/4/2023	FT-FY23-11182022-001463-A	<1	FT-FY23-11182022-001463-B	<1
WS- 001464	8/23/2022	8/23/2023	1	Combo Faucet	In classroom 102	Right	WF-08232022-001464	1/4/2023	FT-FY23-11182022-001464-A	1.1	FT-FY23-11182022-001464-B	1.9
WS- 001465	5/16/2022	5/16/2023	1	Combo Fountain	In classroom 102	Right	WF-05162022-001465	1/4/2023	FT-FY23-11182022-001465-A	<1	FT-FY23-11182022-001465-B	<1
WS- 001466	8/23/2022	8/23/2023	1	Combo Faucet	In classroom 101	Left	WF-08232022-001466	1/4/2023	FT-FY23-11182022-001466-A	<1	FT-FY23-11182022-001466-B	<1
WS- 001467	5/16/2022	5/16/2023	1	Combo Fountain	In classroom 101	Right	WF-05162022-001467	1/4/2023	FT-FY23-11182022-001467-A	<1	FT-FY23-11182022-001467-B	2.0
WS- 001468	8/23/2022	8/23/2023	1	Combo Faucet	In classroom 103	Left	WF-08232022-001468	1/4/2023	FT-FY23-11182022-001468-A	<1	FT-FY23-11182022-001468-B	<1
WS- 001469	5/16/2022	5/16/2023	1	Combo Fountain	In classroom 103	Right	WF-05162022-001469	1/4/2023	FT-FY23-11182022-001469-A	<1	FT-FY23-11182022-001469-B	<1
WS- 001470	8/23/2022	8/23/2023	1	Combo Faucet	In classroom 105	Left	WF-08232022-001470	1/4/2023	FT-FY23-11182022-001470-A	<1	FT-FY23-11182022-001470-B	<1
WS- 001471	5/16/2022	5/16/2023	1	Combo Fountain	In classroom 105	Right	WF-05162022-001471	1/4/2023	FT-FY23-11182022-001471-A	<1	FT-FY23-11182022-001471-B	<1
WS- 001472	5/16/2022	5/16/2023	2	Break Room	In staff lounge	Mid	WF-05162022-001472	1/4/2023	FT-FY23-11182022-001472-A	<1	FT-FY23-11182022-001472-B	<1
WS- 001473	5/16/2022	5/16/2023	2	Cooler	In hallway across from janitor closet		WF-05162022-001473	1/4/2023	FT-FY23-11182022-001473-A	<1	FT-FY23-11182022-001473-B	<1
WS- 001474	8/23/2022	8/23/2023	2	Combo Faucet	In classroom 208	Left	WF-08232022-001474	1/4/2023	FT-FY23-11182022-001474-A	<1	FT-FY23-11182022-001474-B	<1
WS- 001475	5/16/2022	5/16/2023	2	Combo Fountain	In classroom 208	Right	WF-05162022-001475	1/4/2023	FT-FY23-11182022-001475-A	<1	FT-FY23-11182022-001475-B	<1
WS- 001476	8/23/2022	8/23/2023	2	Combo Faucet	In classroom 212	Left	WF-08232022-001476	1/4/2023	FT-FY23-11182022-001476-A	<1	FT-FY23-11182022-001476-B	<1
WS- 001477	5/16/2022	5/16/2023	2	Combo Fountain	In classroom 212	Right	WF-05162022-001477	1/4/2023	FT-FY23-11182022-001477-A	<1	FT-FY23-11182022-001477-B	<1
WS- 001478	8/23/2022	8/23/2023	2	Combo Faucet	In classroom 211	Left	WF-08232022-001478	1/4/2023	FT-FY23-11182022-001478-A	<1	FT-FY23-11182022-001478-B	<1
WS- 001479	5/16/2022	5/16/2023	2	Combo Fountain	In classroom 211	Right	WF-05162022-001479	1/4/2023	FT-FY23-11182022-001479-A	<1	FT-FY23-11182022-001479-B	1.4
WS- 001480	8/23/2022	8/23/2023	2	Combo Faucet	In classroom 207	Left	WF-08232022-001480	1/4/2023	FT-FY23-11182022-001480-A	<1	FT-FY23-11182022-001480-B	<1
WS- 001481	5/16/2022	5/16/2023	2	Combo Fountain	In classroom 207	Right	WF-05162022-001481	1/4/2023	FT-FY23-11182022-001481-A	<1	FT-FY23-11182022-001481-B	<1
WS- 001482	8/23/2022	8/23/2023	2	Combo Faucet	In classroom 210	Left	WF-08232022-001482	1/4/2023	FT-FY23-11182022-001482-A	<1	FT-FY23-11182022-001482-B	<1
WS- 001483	5/16/2022	5/16/2023	2	Combo Fountain	In Classroom 210	Right	WF-05162022-001483	1/4/2023	FT-FY23-11182022-001483-A	<1	FT-FY23-11182022-001483-B	<1
WS- 001484	8/23/2022	8/23/2023	2	Combo Faucet	In classroom 209	Left	WF-08232022-001484	1/4/2023	FT-FY23-11182022-001484-A	<1	FT-FY23-11182022-001484-B	<1
WS- 001485	5/16/2022	5/16/2023	2	Combo Fountain	In Classroom 209	Right	WF-05162022-001485	1/4/2023	FT-FY23-11182022-001485-A	<1	FT-FY23-11182022-001485-B	<1
WS- 001486	8/23/2022	8/23/2023	2	Combo Faucet	In classroom 206	Left	WF-08232022-001486	1/4/2023	FT-FY23-11182022-001486-A	<1	FT-FY23-11182022-001486-B	<1
WS- 001487	5/16/2022	5/16/2023	2	Combo Fountain	In classroom 206	Left	WF-05162022-001487	1/4/2023	FT-FY23-11182022-001487-A	<1	FT-FY23-11182022-001487-B	<1
WS- 001488	8/23/2022	8/23/2023	2	Combo Faucet	In classroom 206	Right	WF-08232022-001488	1/4/2023	FT-FY23-11182022-001488-A	<1	FT-FY23-11182022-001488-B	<1
WS- 001489	5/16/2022	5/16/2023	2	Combo Fountain	In classroom 206	Right	WF-05162022-001489	1/4/2023	FT-FY23-11182022-001489-A	<1	FT-FY23-11182022-001489-B	<1

WS-001490	8/23/2022	8/23/2023	2	Combo Faucet	In classroom 205		WF-08232022-001490	1/4/2023	FT-FY23-11182022-001490-A	<1	FT-FY23-11182022-001490-B	<1
WS-001491	5/16/2022	5/16/2023	2	Combo Fountain	In classroom 205		WF-05162022-001491	1/4/2023	FT-FY23-11182022-001491-A	<1	FT-FY23-11182022-001491-B	<1
WS-001492	5/16/2022	5/16/2023	2	Cooler	In hallway adjacent to room 204		WF-05162022-001492	1/4/2023	FT-FY23-11182022-001492-A	<1	FT-FY23-11182022-001492-B	<1
WS-001493	8/23/2022	8/23/2023	2	Combo Faucet	In classroom 203	Left	WF-08232022-001493	1/4/2023	FT-FY23-11182022-001493-A	<1	FT-FY23-11182022-001493-B	<1
WS-001494	5/16/2022	5/16/2023	2	Combo Fountain	In classroom 203	Right	WF-05162022-001494	1/4/2023	FT-FY23-11182022-001494-A	<1	FT-FY23-11182022-001494-B	<1
WS-001495	8/23/2022	8/23/2023	2	Combo Faucet	In classroom 204	Left	WF-08232022-001495	1/4/2023	FT-FY23-11182022-001495-A	<1	FT-FY23-11182022-001495-B	<1
WS-001496	5/16/2022	5/16/2023	2	Combo Fountain	In classroom 204	Right	WF-05162022-001496	1/4/2023	FT-FY23-11182022-001496-A	<1	FT-FY23-11182022-001496-B	<1
WS-001497	8/23/2022	8/23/2023	2	Combo Faucet	In classroom 201	Left	WF-08232022-001497	1/4/2023	FT-FY23-11182022-001497-A	<1	FT-FY23-11182022-001497-B	<1
WS-001498	5/16/2022	5/16/2023	2	Combo Fountain	In classroom 201	Right	WF-05162022-001498	1/4/2023	FT-FY23-11182022-001498-A	<1	FT-FY23-11182022-001498-B	<1
WS-001499	8/23/2022	8/23/2023	2	Combo Faucet	In classroom 202	Left	WF-08232022-001499	1/4/2023	FT-FY23-11182022-001499-A	<1	FT-FY23-11182022-001499-B	<1
WS-001500	5/16/2022	5/16/2023	2	Combo Fountain	In classroom 202	Right	WF-05162022-001500	1/4/2023	FT-FY23-11182022-001500-A	<1	FT-FY23-11182022-001500-B	<1
WS-001503	8/23/2022	8/23/2023	1	Bathroom	In classroom 101 in bathroom		WF-08232022-001503	1/4/2023	FT-FY23-11182022-001503-A	<1	FT-FY23-11182022-001503-B	<1
WS-001504	8/23/2022	8/23/2023	1	Bathroom	In classroom 102 in bathroom		WF-08232022-001504	1/4/2023	FT-FY23-11182022-001504-A	<1	FT-FY23-11182022-001504-B	<1
WS-001505	8/23/2022	8/23/2023	1	Bathroom	In classroom 103 in bathroom		WF-08232022-001505	1/4/2023	FT-FY23-11182022-001505-A	<1	FT-FY23-11182022-001505-B	<1
WS-001506	8/23/2022	8/23/2023	1	Bathroom	In classroom 104 in bathroom		WF-08232022-001506	1/4/2023	FT-FY23-11182022-001506-A	<1	FT-FY23-11182022-001506-B	<1
WS-001507	8/23/2022	8/23/2023	1	Bathroom	In classroom 105 in bathroom		WF-08232022-001507	1/4/2023	FT-FY23-11182022-001507-A	<1	FT-FY23-11182022-001507-B	<1
WS-001508	8/23/2022	8/23/2023	1	Bathroom	In classroom 106 in bathroom		WF-08232022-001508	1/4/2023	FT-FY23-11182022-001508-A	<1	FT-FY23-11182022-001508-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-001450	1/18/2022	1/18/2023	Basement	Food Prep Sink	In kitchen second clockwise from entry door	Mid	WF-01182022-001450	1/4/2023	FT-FY23-11182022-001450-A	<1	FT-FY23-11182022-001450-B	<1