



Key Elementary School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 001454	5/8/2023	5/8/2024	Basement	Bottle Filler	In lobby adjacent to restrooms (bottle filler)	WF-05082023-001454	11/1/2023	FT-FY24-09282023-001454-A	<1	FT-FY24-09282023-001454-B	1.9	
WS- 001455	5/8/2023	5/8/2024	1	Health Suite	In health suite	Mid	WF-05082023-001455	11/1/2023	FT-FY24-09282023-001455-A	<1	FT-FY24-09282023-001455-B	<1
WS- 001457	5/8/2023	5/8/2024	Basement	Cooler	In lobby adjacent to restrooms	WF-05082023-001457	11/1/2023	FT-FY24-09282023-001457-A	<1	FT-FY24-09282023-001457-B	<1	
WS- 001458	8/15/2023	8/15/2024	1	Combo Faucet	In classroom 106	Left	WF-08152023-001458	11/1/2023	FT-FY24-09282023-001458-A	2.8	FT-FY24-09282023-001458-B	<1
WS- 001459	5/8/2023	5/8/2024	1	Combo Fountain	In classroom 106	Right	WF-05082023-001459	11/1/2023	FT-FY24-09282023-001459-A	<1	FT-FY24-09282023-001459-B	<1
WS- 001460	5/8/2023	5/8/2024	1	Cooler	In hallway adjacent to room 104	WF-05082023-001460	11/1/2023	FT-FY24-09282023-001460-A	<1	FT-FY24-09282023-001460-B	<1	
WS- 001461	5/8/2023	5/8/2024	1	Cooler	In hallway adjacent to room 103	WF-05082023-001461	11/1/2023	FT-FY24-09282023-001461-A	<1	FT-FY24-09282023-001461-B	<1	
WS- 001462	8/15/2023	8/15/2024	1	Combo Faucet	In classroom 104	Left	WF-08152023-001462	11/1/2023	FT-FY24-09282023-001462-A	<1	FT-FY24-09282023-001462-B	<1
WS- 001463	5/8/2023	5/8/2024	1	Combo Fountain	In classroom 104	Right	WF-05082023-001463	11/1/2023	FT-FY24-09282023-001463-A	<1	FT-FY24-09282023-001463-B	<1
WS- 001464	8/15/2023	8/15/2024	1	Combo Faucet	In classroom 102	Right	WF-08152023-001464	11/1/2023	FT-FY24-09282023-001464-A	<1	FT-FY24-09282023-001464-B	<1
WS- 001465	5/8/2023	5/8/2024	1	Combo Fountain	In classroom 102	Right	WF-05082023-001465	11/1/2023	FT-FY24-09282023-001465-A	1.0	FT-FY24-09282023-001465-B	<1
WS- 001466	8/15/2023	8/15/2024	1	Combo Faucet	In classroom 101	Left	WF-08152023-001466	11/1/2023	FT-FY24-09282023-001466-A	<1	FT-FY24-09282023-001466-B	<1
WS- 001467	5/8/2023	5/8/2024	1	Combo Fountain	In classroom 101	Right	WF-05082023-001467	11/1/2023	FT-FY24-09282023-001467-A	<1	FT-FY24-09282023-001467-B	<1
WS- 001468	8/15/2023	8/15/2024	1	Combo Faucet	In classroom 103	Left	WF-08152023-001468	11/1/2023	FT-FY24-09282023-001468-A	2.7	FT-FY24-09282023-001468-B	<1
WS- 001469	5/8/2023	5/8/2024	1	Combo Fountain	In classroom 103	Right	WF-05082023-001469	11/1/2023	FT-FY24-09282023-001469-A	<1	FT-FY24-09282023-001469-B	<1
WS- 001470	8/15/2023	8/15/2024	1	Combo Faucet	In classroom 105	Left	WF-08152023-001470	11/1/2023	FT-FY24-09282023-001470-A	1.2	FT-FY24-09282023-001470-B	<1
WS- 001471	5/8/2023	5/8/2024	1	Combo Fountain	In classroom 105	Right	WF-05082023-001471	11/1/2023	FT-FY24-09282023-001471-A	<1	FT-FY24-09282023-001471-B	<1
WS- 001472	5/8/2023	5/8/2024	2	Break Room	In staff lounge	Mid	WF-05082023-001472	11/1/2023	FT-FY24-09282023-001472-A	<1	FT-FY24-09282023-001472-B	<1
WS- 001473	5/8/2023	5/8/2024	2	Cooler	In hallway across from janitor closet	WF-05082023-001473	11/1/2023	FT-FY24-09282023-001473-A	<1	FT-FY24-09282023-001473-B	<1	
WS- 001474	8/15/2023	8/15/2024	2	Combo Faucet	In classroom 208	Left	WF-08152023-001474	11/1/2023	FT-FY24-09282023-001474-A	1.7	FT-FY24-09282023-001474-B	<1
WS- 001475	5/8/2023	5/8/2024	2	Combo Fountain	In classroom 208	Right	WF-05082023-001475	11/1/2023	FT-FY24-09282023-001475-A	<1	FT-FY24-09282023-001475-B	<1
WS- 001476	8/15/2023	8/15/2024	2	Combo Faucet	In classroom 212	Left	WF-08152023-001476	11/1/2023	FT-FY24-09282023-001476-A	1.3	FT-FY24-09282023-001476-B	<1
WS- 001477	5/8/2023	5/8/2024	2	Combo Fountain	In classroom 212	Right	WF-05082023-001477	11/1/2023	FT-FY24-09282023-001477-A	<1	FT-FY24-09282023-001477-B	<1
WS- 001478	8/15/2023	8/15/2024	2	Combo Faucet	In classroom 211	Left	WF-08152023-001478	11/1/2023	FT-FY24-09282023-001478-A	2.9	FT-FY24-09282023-001478-B	<1
WS- 001479	5/8/2023	5/8/2024	2	Combo Fountain	In classroom 211	Right	WF-05082023-001479	11/1/2023	FT-FY24-09282023-001479-A	<1	FT-FY24-09282023-001479-B	<1
WS- 001480	8/15/2023	8/15/2024	2	Combo Faucet	In classroom 207	Left	WF-08152023-001480	11/1/2023	FT-FY24-09282023-001480-A	2.0	FT-FY24-09282023-001480-B	<1
WS- 001481	5/8/2023	5/8/2024	2	Combo Fountain	In classroom 207	Right	WF-05082023-001481	11/1/2023	FT-FY24-09282023-001481-A	<1	FT-FY24-09282023-001481-B	<1
WS- 001483	5/8/2023	5/8/2024	2	Combo Fountain	In Classroom 210	Right	WF-05082023-001483	11/1/2023	FT-FY24-09282023-001483-A	<1	FT-FY24-09282023-001483-B	<1
WS- 001485	5/8/2023	5/8/2024	2	Combo Fountain	In Classroom 209	Right	WF-05082023-001485	11/1/2023	FT-FY24-09282023-001485-A	<1	FT-FY24-09282023-001485-B	<1
WS- 001486	8/15/2023	8/15/2024	2	Combo Faucet	In classroom 206	Left	WF-08152023-001486	11/1/2023	FT-FY24-09282023-001486-A	1.8	FT-FY24-09282023-001486-B	<1
WS- 001488	8/15/2023	8/15/2024	2	Combo Faucet	In classroom 206	Right	WF-08152023-001488	11/1/2023	FT-FY24-09282023-001488-A	<1	FT-FY24-09282023-001488-B	<1
WS- 001490	8/15/2023	8/15/2024	2	Combo Faucet	In classroom 205	WF-08152023-001490	11/1/2023	FT-FY24-09282023-001490-A	<1	FT-FY24-09282023-001490-B	<1	
WS- 001491	5/8/2023	5/8/2024	2	Combo Fountain	In classroom 205	WF-05082023-001491	11/1/2023	FT-FY24-09282023-001491-A	<1	FT-FY24-09282023-001491-B	<1	
WS- 001492	5/8/2023	5/8/2024	2	Cooler	In hallway adjacent to room 204	WF-05082023-001492	11/1/2023	FT-FY24-09282023-001492-A	<1	FT-FY24-09282023-001492-B	<1	
WS- 001493	8/15/2023	8/15/2024	2	Combo Faucet	In classroom 203	Left	WF-08152023-001493	11/1/2023	FT-FY24-09282023-001493-A	<1	FT-FY24-09282023-001493-B	<1

WS-001494	5/8/2023	5/8/2024	2	Combo Fountain	In classroom 203	Right	WF-05082023-001494	11/1/2023	FT-FY24-09282023-001494-A	<1	FT-FY24-09282023-001494-B	<1
WS-001495	8/15/2023	8/15/2024	2	Combo Faucet	In classroom 204	Left	WF-08152023-001495	11/1/2023	FT-FY24-09282023-001495-A	<1	FT-FY24-09282023-001495-B	<1
WS-001496	5/8/2023	5/8/2024	2	Combo Fountain	In classroom 204	Right	WF-05082023-001496	11/1/2023	FT-FY24-09282023-001496-A	<1	FT-FY24-09282023-001496-B	<1
WS-001497	8/15/2023	8/15/2024	2	Combo Faucet	In classroom 201	Left	WF-08152023-001497	11/1/2023	FT-FY24-09282023-001497-A	1.1	FT-FY24-09282023-001497-B	<1
WS-001498	5/8/2023	5/8/2024	2	Combo Fountain	In classroom 201	Right	WF-05082023-001498	11/1/2023	FT-FY24-09282023-001498-A	<1	FT-FY24-09282023-001498-B	<1
WS-001499	8/15/2023	8/15/2024	2	Combo Faucet	In classroom 202	Left	WF-08152023-001499	11/1/2023	FT-FY24-09282023-001499-A	<1	FT-FY24-09282023-001499-B	<1
WS-001500	5/8/2023	5/8/2024	2	Combo Fountain	In classroom 202	Right	WF-05082023-001500	11/1/2023	FT-FY24-09282023-001500-A	<1	FT-FY24-09282023-001500-B	<1
WS-001503	8/15/2023	8/15/2024	1	Bathroom	In classroom 101 in bathroom		WF-08152023-001503	11/1/2023	FT-FY24-09282023-001503-A	<1	FT-FY24-09282023-001503-B	<1
WS-001504	8/15/2023	8/15/2024	1	Bathroom	In classroom 102 in bathroom		WF-08152023-001504	11/1/2023	FT-FY24-09282023-001504-A	<1	FT-FY24-09282023-001504-B	<1
WS-001505	8/15/2023	8/15/2024	1	Bathroom	In classroom 103 in bathroom		WF-08152023-001505	11/1/2023	FT-FY24-09282023-001505-A	<1	FT-FY24-09282023-001505-B	<1
WS-001506	8/15/2023	8/15/2024	1	Bathroom	In classroom 104 in bathroom		WF-08152023-001506	11/1/2023	FT-FY24-09282023-001506-A	<1	FT-FY24-09282023-001506-B	<1
WS-001508	8/15/2023	8/15/2024	1	Bathroom	In classroom 106 in bathroom		WF-08152023-001508	11/1/2023	FT-FY24-09282023-001508-A	<1	FT-FY24-09282023-001508-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-001450	12/28/2022	12/28/2023	Basement	Food Prep Sink	In kitchen second clockwise from entry door	Mid	WF-12282022-001450	11/1/2023	FT-FY24-09282023-001450-A	2.8	FT-FY24-09282023-001450-B	1.9

FY24 Filter Test

Greater than 5ppb - Devices requiring remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-001482	8/15/2023	8/15/2024	2	Combo Faucet	In classroom 210	Left	WF-08152023-001482	11/1/2023	FT-FY24-09282023-001482-A	5.5	FT-FY24-09282023-001482-B	<1
WS-001484	8/15/2023	8/15/2024	2	Combo Faucet	In classroom 209	Left	WF-08152023-001484	11/1/2023	FT-FY24-09282023-001484-A	5.8	FT-FY24-09282023-001484-B	<1