



Key Elementary School Lead in Water Test Results

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-001454	4/30/2024	4/30/2025	Basement	Bottle Filler	In lobby adjacent to restrooms (bottle filler)	WF-04302024-001454	11/5/2024	FT-FY25-10082024-001454-A	<2	FT-FY25-10082024-001454-B	<2	
WS-001455	4/30/2024	4/30/2025	1	Health Suite	In health suite	Mid	WF-04302024-001455	11/5/2024	FT-FY25-10082024-001455-A	<2	FT-FY25-10082024-001455-B	<2
WS-001457	4/30/2024	4/30/2025	Basement	Cooler	In lobby adjacent to restrooms	WF-04302024-001457	11/5/2024	FT-FY25-10082024-001457-A	<2	FT-FY25-10082024-001457-B	<2	
WS-001458	8/13/2024	8/13/2025	1	Combo Faucet	In classroom 106	Left	WF-08132024-001458	11/5/2024	FT-FY25-10082024-001458-A	<2	FT-FY25-10082024-001458-B	<2
WS-001459	4/30/2024	4/30/2025	1	Combo Fountain	In classroom 106	Right	WF-04302024-001459	11/5/2024	FT-FY25-10082024-001459-A	<2	FT-FY25-10082024-001459-B	<2
WS-001460	4/30/2024	4/30/2025	1	Cooler	In hallway adjacent to room 104	WF-04302024-001460	11/5/2024	FT-FY25-10082024-001460-A	<2	FT-FY25-10082024-001460-B	<2	
WS-001461	4/30/2024	4/30/2025	1	Cooler	In hallway adjacent to room 103	WF-04302024-001461	11/5/2024	FT-FY25-10082024-001461-A	<2	FT-FY25-10082024-001461-B	<2	
WS-001462	8/13/2024	8/13/2025	1	Combo Faucet	In classroom 104	Left	WF-08132024-001462	11/5/2024	FT-FY25-10082024-001462-A	<2	FT-FY25-10082024-001462-B	<2
WS-001463	4/30/2024	4/30/2025	1	Combo Fountain	In classroom 104	Right	WF-04302024-001463	11/5/2024	FT-FY25-10082024-001463-A	<2	FT-FY25-10082024-001463-B	<2
WS-001464	8/13/2024	8/13/2025	1	Combo Faucet	In classroom 102	Right	WF-08132024-001464	11/5/2024	FT-FY25-10082024-001464-A	<2	FT-FY25-10082024-001464-B	<2
WS-001465	4/30/2024	4/30/2025	1	Combo Fountain	In classroom 102	Right	WF-04302024-001465	11/5/2024	FT-FY25-10082024-001465-A	<2	FT-FY25-10082024-001465-B	<2
WS-001466	8/13/2024	8/13/2025	1	Combo Faucet	In classroom 101	Left	WF-08132024-001466	11/5/2024	FT-FY25-10082024-001466-A	<2	FT-FY25-10082024-001466-B	<2
WS-001467	4/30/2024	4/30/2025	1	Combo Fountain	In classroom 101	Right	WF-04302024-001467	11/5/2024	FT-FY25-10082024-001467-A	<2	FT-FY25-10082024-001467-B	<2
WS-001468	8/13/2024	8/13/2025	1	Combo Faucet	In classroom 103	Left	WF-08132024-001468	11/5/2024	FT-FY25-10082024-001468-A	<2	FT-FY25-10082024-001468-B	<2
WS-001469	4/30/2024	4/30/2025	1	Combo Fountain	In classroom 103	Right	WF-04302024-001469	11/5/2024	FT-FY25-10082024-001469-A	<2	FT-FY25-10082024-001469-B	<2
WS-001470	8/13/2024	8/13/2025	1	Combo Faucet	In classroom 105	Left	WF-08132024-001470	11/5/2024	FT-FY25-10082024-001470-A	<2	FT-FY25-10082024-001470-B	<2
WS-001471	4/30/2024	4/30/2025	1	Combo Fountain	In classroom 105	Right	WF-04302024-001471	11/5/2024	FT-FY25-10082024-001471-A	<2	FT-FY25-10082024-001471-B	<2
WS-001472	4/30/2024	4/30/2025	2	Break Room	In staff lounge	Mid	WF-04302024-001472	11/5/2024	FT-FY25-10082024-001472-A	<2	FT-FY25-10082024-001472-B	<2
WS-001473	4/30/2024	4/30/2025	2	Cooler	In hallway across from janitor closet	WF-04302024-001473	11/5/2024	FT-FY25-10082024-001473-A	<2	FT-FY25-10082024-001473-B	<2	
WS-001474	8/13/2024	8/13/2025	2	Combo Faucet	In classroom 208	Left	WF-08132024-001474	11/5/2024	FT-FY25-10082024-001474-A	4.0	FT-FY25-10082024-001474-B	<2
WS-001475	4/30/2024	4/30/2025	2	Combo Fountain	In classroom 208	Right	WF-04302024-001475	11/5/2024	FT-FY25-10082024-001475-A	<2	FT-FY25-10082024-001475-B	<2
WS-001476	8/13/2024	8/13/2025	2	Combo Faucet	In classroom 212	Left	WF-08132024-001476	11/5/2024	FT-FY25-10082024-001476-A	<2	FT-FY25-10082024-001476-B	<2
WS-001477	4/30/2024	4/30/2025	2	Combo Fountain	In classroom 212	Right	WF-04302024-001477	11/5/2024	FT-FY25-10082024-001477-A	<2	FT-FY25-10082024-001477-B	<2
WS-001478	8/13/2024	8/13/2025	2	Combo Faucet	In classroom 211	Left	WF-08132024-001478	11/5/2024	FT-FY25-10082024-001478-A	2.6	FT-FY25-10082024-001478-B	<2
WS-001479	4/30/2024	4/30/2025	2	Combo Fountain	In classroom 211	Right	WF-04302024-001479	11/5/2024	FT-FY25-10082024-001479-A	<2	FT-FY25-10082024-001479-B	<2
WS-001480	8/13/2024	8/13/2025	2	Combo Faucet	In classroom 207	Left	WF-08132024-001480	11/5/2024	FT-FY25-10082024-001480-A	<2	FT-FY25-10082024-001480-B	<2
WS-001481	4/30/2024	4/30/2025	2	Combo Fountain	In classroom 207	Right	WF-04302024-001481	11/5/2024	FT-FY25-10082024-001481-A	<2	FT-FY25-10082024-001481-B	<2
WS-001483	4/30/2024	4/30/2025	2	Combo Fountain	In Classroom 210	Right	WF-04302024-001483	11/5/2024	FT-FY25-10082024-001483-A	<2	FT-FY25-10082024-001483-B	<2
WS-001484	8/13/2024	8/13/2025	2	Combo Faucet	In classroom 209	Left	WF-08132024-001484	11/5/2024	FT-FY25-10082024-001484-A	<2	FT-FY25-10082024-001484-B	<2
WS-001485	4/30/2024	4/30/2025	2	Combo Fountain	In Classroom 209	Right	WF-04302024-001485	11/5/2024	FT-FY25-10082024-001485-A	<2	FT-FY25-10082024-001485-B	<2
WS-001486	8/13/2024	8/13/2025	2	Combo Faucet	In classroom 206	Left	WF-08132024-001486	11/5/2024	FT-FY25-10082024-001486-A	<2	FT-FY25-10082024-001486-B	<2
WS-001488	8/13/2024	8/13/2025	2	Combo Faucet	In classroom 206	Right	WF-08132024-001488	11/5/2024	FT-FY25-10082024-001488-A	<2	FT-FY25-10082024-001488-B	<2
WS-001490	8/13/2024	8/13/2025	2	Combo Faucet	In classroom 205	WF-08132024-001490	11/5/2024	FT-FY25-10082024-001490-A	2.0	FT-FY25-10082024-001490-B	<2	

WS-001491	4/30/2024	4/30/2025	2	Combo Fountain	In classroom 205		WF-04302024-001491	11/5/2024	FT-FY25-10082024-001491-A	<2	FT-FY25-10082024-001491-B	<2
WS-001492	4/30/2024	4/30/2025	2	Cooler	In hallway adjacent to room 204		WF-04302024-001492	11/5/2024	FT-FY25-10082024-001492-A	<2	FT-FY25-10082024-001492-B	<2
WS-001493	8/13/2024	8/13/2025	2	Combo Faucet	In classroom 203	Left	WF-08132024-001493	11/5/2024	FT-FY25-10082024-001493-A	<2	FT-FY25-10082024-001493-B	<2
WS-001494	4/30/2024	4/30/2025	2	Combo Fountain	In classroom 203	Right	WF-04302024-001494	11/5/2024	FT-FY25-10082024-001494-A	<2	FT-FY25-10082024-001494-B	<2
WS-001495	8/13/2024	8/13/2025	2	Combo Faucet	In classroom 204	Left	WF-08132024-001495	11/5/2024	FT-FY25-10082024-001495-A	2.4	FT-FY25-10082024-001495-B	<2
WS-001496	4/30/2024	4/30/2025	2	Combo Fountain	In classroom 204	Right	WF-04302024-001496	11/5/2024	FT-FY25-10082024-001496-A	<2	FT-FY25-10082024-001496-B	<2
WS-001497	8/13/2024	8/13/2025	2	Combo Faucet	In classroom 201	Left	WF-08132024-001497	11/5/2024	FT-FY25-10082024-001497-A	3.2	FT-FY25-10082024-001497-B	<2
WS-001498	4/30/2024	4/30/2025	2	Combo Fountain	In classroom 201	Right	WF-04302024-001498	11/5/2024	FT-FY25-10082024-001498-A	<2	FT-FY25-10082024-001498-B	<2
WS-001499	8/13/2024	8/13/2025	2	Combo Faucet	In classroom 202	Left	WF-08132024-001499	11/5/2024	FT-FY25-10082024-001499-A	<2	FT-FY25-10082024-001499-B	<2
WS-001500	4/30/2024	4/30/2025	2	Combo Fountain	In classroom 202	Right	WF-04302024-001500	11/5/2024	FT-FY25-10082024-001500-A	<2	FT-FY25-10082024-001500-B	<2
WS-001503	8/13/2024	8/13/2025	1	Bathroom	In classroom 101 in bathroom		WF-08132024-001503	11/5/2024	FT-FY25-10082024-001503-A	<2	FT-FY25-10082024-001503-B	<2
WS-001504	8/13/2024	8/13/2025	1	Bathroom	In classroom 102 in bathroom		WF-08132024-001504	11/5/2024	FT-FY25-10082024-001504-A	<2	FT-FY25-10082024-001504-B	<2
WS-001505	8/13/2024	8/13/2025	1	Bathroom	In classroom 103 in bathroom		WF-08132024-001505	11/5/2024	FT-FY25-10082024-001505-A	<2	FT-FY25-10082024-001505-B	<2
WS-001506	8/13/2024	8/13/2025	1	Bathroom	In classroom 104 in bathroom		WF-08132024-001506	11/5/2024	FT-FY25-10082024-001506-A	<2	FT-FY25-10082024-001506-B	<2
WS-001507	8/13/2024	8/13/2025	1	Bathroom	In classroom 105 in bathroom		WF-08132024-001507	11/5/2024	FT-FY25-10082024-001507-A	<2	FT-FY25-10082024-001507-B	<2
WS-001508	8/13/2024	8/13/2025	1	Bathroom	In classroom 106 in bathroom		WF-08132024-001508	11/5/2024	FT-FY25-10082024-001508-A	<2	FT-FY25-10082024-001508-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-001450	11/27/2023	11/27/2024	Basement	Food Prep Sink	In kitchen second clockwise from entry door	Mid	WF-11272023-001450	11/5/2024	FT-FY25-10082024-001450-A	<2	FT-FY25-10082024-001450-B	<2

FY25 Filter Test

Greater than 5ppb - Devices requiring remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-001482	8/13/2024	8/13/2025	2	Combo Faucet	In classroom 210	Left	WF-08132024-001482	11/5/2024	FT-FY25-10082024-001482-A	6.1	FT-FY25-10082024-001482-B	<2

First Re-test (After Plumbing Check)

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-001482	11/6/2024	11/6/2025	2	Combo Faucet	In classroom 210	Left	WF-11062024-001482	11/15/2024	FT-FY25-11072024-001482-A	2.6	FT-FY25-11072024-001482-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.