



# KEY ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	KEY ELEMENTARY SCHOOL	WS- 001450	8/20/2016	Basement	Food Prep Sink	In kitchen second clockwise from entry door Mid	FT-72016-001450-A	< 1	FT-72016-001450-B	< 1
2	KEY ELEMENTARY SCHOOL	WS- 001451	8/20/2016	Basement	Food Prep Sink	In kitchen third clockwise from entry door Low Mid	FT-72016-001451-A	< 1	FT-72016-001451-B	< 1
3	KEY ELEMENTARY SCHOOL	WS- 001452	8/20/2016	Basement	Food Prep Sink	In kitchen fourth clockwise from entry door Mid	FT-72016-001452-A	< 1	FT-72016-001452-B	< 1
4	KEY ELEMENTARY SCHOOL	WS- 001454	8/20/2016	Basement	Bottle Filler	In lobby adjacent to restrooms (bottle filler) High Left	FT-82016-001454-A	< 1	FT-82016-001454-B	< 1
5	KEY ELEMENTARY SCHOOL	WS- 001455	8/20/2016	1	Health Suite	In health suite Mid	FT-72016-001455-A	< 1	FT-72016-001455-B	< 1
6	KEY ELEMENTARY SCHOOL	WS- 001457	8/20/2016	Basement	Cooler	In lobby adjacent to restrooms Right	FT-72016-001457-A	< 1	FT-72016-001457-B	< 1
7	KEY ELEMENTARY SCHOOL	WS- 001459	8/20/2016	1	Fountain	In classroom 106 Right	FT-72016-001459-A	< 1	FT-72016-001459-B	< 1
8	KEY ELEMENTARY SCHOOL	WS- 001460	8/20/2016	1	Cooler	In hallway adjacent to room 104	FT-72016-001460-A	< 1	FT-72016-001460-B	< 1
9	KEY ELEMENTARY SCHOOL	WS- 001461	8/20/2016	1	Cooler	In hallway adjacent to room 103	FT-72016-001461-A	< 1	FT-72016-001461-B	< 1
10	KEY ELEMENTARY SCHOOL	WS- 001463	8/20/2016	1	Fountain	In classroom 104 Right	FT-72016-001463-A	< 1	FT-72016-001463-B	< 1
11	KEY ELEMENTARY SCHOOL	WS- 001465	8/20/2016	1	Fountain	In classroom 102 Right	FT-72016-001465-A	< 1	FT-72016-001465-B	< 1
12	KEY ELEMENTARY SCHOOL	WS- 001467	8/20/2016	1	Fountain	In classroom 101 Right	FT-72016-001467-A	< 1	FT-72016-001467-B	< 1
13	KEY ELEMENTARY SCHOOL	WS- 001469	8/20/2016	1	Fountain	In classroom 103 Right	FT-72016-001469-A	< 1	FT-72016-001469-B	< 1
14	KEY ELEMENTARY SCHOOL	WS- 001471	8/20/2016	1	Fountain	In classroom 105 Right	FT-72016-001471-A	< 1	FT-72016-001471-B	< 1
15	KEY ELEMENTARY SCHOOL	WS- 001473	8/20/2016	2	Cooler	In hallway across from janitor closet Mid	FT-72016-001473-A	< 1	FT-72016-001473-B	< 1
16	KEY ELEMENTARY SCHOOL	WS- 001475	8/20/2016	2	Fountain	In classroom 208 Right	FT-72016-001475-A	< 1	FT-72016-001475-B	< 1
17	KEY ELEMENTARY SCHOOL	WS- 001477	8/20/2016	2	Fountain	In classroom 212 Right	FT-72016-001477-A	< 1	FT-72016-001477-B	< 1
18	KEY ELEMENTARY SCHOOL	WS- 001479	8/20/2016	2	Fountain	In classroom 211 Right	FT-72016-001479-A	< 1	FT-72016-001479-B	< 1
19	KEY ELEMENTARY SCHOOL	WS- 001481	8/20/2016	2	Fountain	In classroom 207 Right	FT-72016-001481-A	< 1	FT-72016-001481-B	< 1
20	KEY ELEMENTARY SCHOOL	WS- 001483	8/20/2016	2	Fountain	In Classroom 210 Right	FT-72016-001483-A	< 1	FT-72016-001483-B	< 1
21	KEY ELEMENTARY SCHOOL	WS- 001485	8/20/2016	2	Fountain	In Classroom 209 Right	FT-72016-001485-A	< 1	FT-72016-001485-B	< 1
22	KEY ELEMENTARY SCHOOL	WS- 001487	8/20/2016	2	Fountain	In classroom 206 Left	FT-72016-001487-A	< 1	FT-72016-001487-B	< 1
23	KEY ELEMENTARY SCHOOL	WS- 001489	8/20/2016	2	Fountain	In classroom 206 Right	FT-72016-001489-A	< 1	FT-72016-001489-B	< 1
24	KEY ELEMENTARY SCHOOL	WS- 001491	8/20/2016	2	Fountain	In classroom 205	FT-72016-001491-A	< 1	FT-72016-001491-B	< 1
25	KEY ELEMENTARY SCHOOL	WS- 001492	8/20/2016	2	Cooler	In hallway adjacent to room 204	FT-72016-001492-A	< 1	FT-72016-001492-B	< 1
26	KEY ELEMENTARY SCHOOL	WS- 001494	8/20/2016	2	Fountain	In classroom 203 Right	FT-72016-001494-A	< 1	FT-72016-001494-B	< 1
27	KEY ELEMENTARY SCHOOL	WS- 001496	8/20/2016	2	Fountain	In classroom 204 Right	FT-72016-001496-A	< 1	FT-72016-001496-B	< 1
28	KEY ELEMENTARY SCHOOL	WS- 001498	8/20/2016	2	Fountain	In classroom 201 Right	FT-72016-001498-A	< 1	FT-72016-001498-B	< 1
29	KEY ELEMENTARY SCHOOL	WS- 001500	8/20/2016	2	Fountain	In classroom 202 Right	FT-72016-001500-A	< 1	FT-72016-001500-B	< 1