



# KEY LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001502	Utility	Basement	In fire pump room water inlet to the school (water source)	Right	WT-042916-1519-A	258	WT-042916-1519-B	22.5	Non-drinking water source – Not accessible to children		
2 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001501	Fountain	Basement	Exterior	Right	WT-042916-1518-A	< 1	WT-042916-1518-B	< 1			
3 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001500	Fountain	2	In classroom 202	Right	WT-042916-1517-A	< 1	WT-042916-1517-B	< 1			
4 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001499	Classroom	2	In classroom 202	Left	WT-042916-1516-A	< 1	WT-042916-1516-B	< 1			
5 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001498	Fountain	2	In classroom 201	Right	WT-042916-1515-A	< 1	WT-042916-1515-B	< 1			
6 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001497	Classroom	2	In classroom 201	Left	WT-042916-1514-A	< 1	WT-042916-1514-B	< 1			
7 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001496	Fountain	2	In classroom 204	Right	WT-042916-1513-A	< 1	WT-042916-1513-B	< 1			
8 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001495	Classroom	2	In classroom 204	Left	WT-042916-1512-A	< 1	WT-042916-1512-B	< 1			
9 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001494	Fountain	2	In classroom 203	Right	WT-042916-1511-A	< 1	WT-042916-1511-B	< 1			
10 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001493	Classroom	2	In classroom 203	Left	WT-042916-1510-A	< 1	WT-042916-1510-B	< 1			
11 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001492	Cooler	2	In hallway adjacent to room 204		WT-042916-1509-A	< 1	WT-042916-1509-B	< 1			
12 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001491	Fountain	2	In classroom 205		WT-042916-1508-A	< 1	WT-042916-1508-B	< 1			
13 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001490	Classroom	2	In classroom 205		WT-042916-1507-A	< 1	WT-042916-1507-B	< 1			
14 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001489	Fountain	2	In classroom 206	Right	WT-042916-1506-A	< 1	WT-042916-1506-B	< 1			
15 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001488	Classroom	2	In classroom 206	Right	WT-042916-1505-A	1.76	WT-042916-1505-B	< 1			
16 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001487	Fountain	2	In classroom 206	Left	WT-042916-1504-A	< 1	WT-042916-1504-B	< 1			
17 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001486	Classroom	2	In classroom 206		WT-042916-1503-A	< 1	WT-042916-1503-B	< 1			
18 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001485	Fountain	2	In classroom 209	Right	WT-042916-1502-A	< 1	WT-042916-1502-B	< 1			
19 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001484	Classroom	2	In classroom 209	Left	WT-042916-1501-A	< 1	WT-042916-1501-B	< 1			
20 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001483	Fountain	2	In classroom 210	Right	WT-042916-1500-A	< 1	WT-042916-1500-B	< 1			
21 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001482	Classroom	2	In classroom 210	Left	WT-042916-1499-A	< 1	WT-042916-1499-B	< 1			
22 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001481	Fountain	2	In classroom 207	Right	WT-042916-1498-A	< 1	WT-042916-1498-B	< 1			
23 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001480	Classroom	2	In classroom 207	Left	WT-042916-1497-A	< 1	WT-042916-1497-B	< 1			
24 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001479	Fountain	2	In classroom 211	Right	WT-042916-1496-A	< 1	WT-042916-1496-B	< 1			
25 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001478	Classroom	2	In classroom 211	Left	WT-042916-1495-A	< 1	WT-042916-1495-B	< 1			
26 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001477	Fountain	2	In classroom 212	Right	WT-042916-1494-A	< 1	WT-042916-1494-B	< 1			
27 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001476	Classroom	2	In classroom 212	Left	WT-042916-1493-A	< 1	WT-042916-1493-B	< 1			
28 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001475	Fountain	2	In classroom 208	Right	WT-042916-1492-A	< 1	WT-042916-1492-B	< 1			
29 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001474	Classroom	2	In classroom 208	Left	WT-042916-1491-A	< 1	WT-042916-1491-B	< 1			
30 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001473	Cooler	2	In hallway across from janitor room	Mid	WT-042916-1490-A	< 1	WT-042916-1490-B	< 1			
31 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001472	Classroom	2	In staff lounge	Mid	WT-042916-1489-A	< 1	WT-042916-1489-B	< 1			
32 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001471	Fountain	1	In classroom 105	Right	WT-042916-1488-A	< 1	WT-042916-1488-B	< 1			
33 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001470	Classroom	1	In classroom 105	Left	WT-042916-1487-A	< 1	WT-042916-1487-B	< 1			
34 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001469	Fountain	1	In classroom 103	Right	WT-042916-1486-A	< 1	WT-042916-1486-B	< 1			
35 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001468	Classroom	1	In classroom 103	Left	WT-042916-1485-A	< 1	WT-042916-1485-B	< 1			
36 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001467	Fountain	1	In classroom 101	Right	WT-042916-1484-A	< 1	WT-042916-1484-B	< 1			
37 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001466	Classroom	1	In classroom 101	Left	WT-042916-1483-A	< 1	WT-042916-1483-B	< 1			
38 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001465	Fountain	1	In classroom 102	Right	WT-042916-1482-A	1.39	WT-042916-1482-B	1.43			
39 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001464	Classroom	1	In classroom 102	Right	WT-042916-1481-A	< 1	WT-042916-1481-B	< 1			
40 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001463	Fountain	1	In classroom 104	Right	WT-042916-1480-A	< 1	WT-042916-1480-B	< 1			
41 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001462	Classroom	1	In classroom 104	Left	WT-042916-1479-A	< 1	WT-042916-1479-B	< 1			
42 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001461	Cooler	1	In hallway adjacent to room 103		WT-042916-1478-A	< 1	WT-042916-1478-B	< 1			
43 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001460	Cooler	1	In hallway adjacent to room 104		WT-042916-1477-A	< 1	WT-042916-1477-B	< 1			
44 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001459	Fountain	1	In classroom 106	Right	WT-042916-1476-A	< 1	WT-042916-1476-B	< 1			
45 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001458	Classroom	1	In classroom 106	Left	WT-042916-1475-A	< 1	WT-042916-1475-B	< 1			
46 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001457	Cooler	Basement	In lobby adjacent to restrooms	Right	WT-042916-1474-A	< 1	WT-042916-1474-B	< 1			
47 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001456	Classroom	1	In room 3 PTA room		WT-042916-1473-A	< 1	WT-042916-1473-B	< 1			
48 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001455	Health Suite	1	In health suite	Mid	WT-042916-1472-A	< 1	WT-042916-1472-B	< 1			
49 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001454	Cooler	Basement	In lobby adjacent to restrooms (bottle filler)	Left High	WT-042916-1471-A	< 1	WT-042916-1471-B	< 1			
50 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001452	Kitchen	Basement	In kitchen forth from left	Mid	WT-042916-1469-A	1.45	WT-042916-1469-B	< 1			
51 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001451	Kitchen	Basement	In kitchen third from left	Mid Low	WT-042916-1468-A	< 1	WT-042916-1468-B	< 1			
52 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001450	Kitchen	Basement	In kitchen second from left	Mid	WT-042916-1467-A	< 1	WT-042916-1467-B	< 1			
53 KEY ELEMENTARY SCHOOL	5/3/2016	WS-001449	Kitchen	Basement	In kitchen (spray nozzle)	Left High	WT-042916-1466-A	1.72	WT-042916-1466-B	< 1			

Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.