



Key ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 001454	5/15/2018	5/15/2019	Basement	Bottle Filler	In lobby adjacent to restrooms (bottle filler)	WF-05152018-001454	12/6/2018	FT-FY19-112018-001454-A	<1	FT-FY19-112018-001454-B	<1	
WS- 001455	5/15/2018	5/15/2019	1	Health Suite	In health suite	Mid	WF-05152018-001455	12/6/2018	FT-FY19-112018-001455-A	<1	FT-FY19-112018-001455-B	<1
WS- 001457	5/15/2018	5/15/2019	Basement	Cooler	In lobby adjacent to restrooms	WF-05152018-001457	12/6/2018	FT-FY19-112018-001457-A	<1	FT-FY19-112018-001457-B	<1	
WS- 001458	9/25/2018	9/25/2019	1	Combo Faucet	In classroom 106	Left	WF-09252018-001458	12/6/2018	FT-FY19-112018-001458-A	<1	FT-FY19-112018-001458-B	<1
WS- 001459	5/15/2018	5/15/2019	1	Combo Fountain	In classroom 106	Right	WF-05152018-001459	12/6/2018	FT-FY19-112018-001459-A	<1	FT-FY19-112018-001459-B	<1
WS- 001460	5/15/2018	5/15/2019	1	Cooler	In hallway adjacent to room 104	WF-05152018-001460	12/6/2018	FT-FY19-112018-001460-A	<1	FT-FY19-112018-001460-B	<1	
WS- 001461	5/15/2018	5/15/2019	1	Cooler	In hallway adjacent to room 103	WF-05152018-001461	12/6/2018	FT-FY19-112018-001461-A	<1	FT-FY19-112018-001461-B	<1	
WS- 001462	9/25/2018	9/25/2019	1	Combo Faucet	In classroom 104	Left	WF-09252018-001462	12/6/2018	FT-FY19-112018-001462-A	<1	FT-FY19-112018-001462-B	<1
WS- 001463	5/15/2018	5/15/2019	1	Combo Fountain	In classroom 104	Right	WF-05152018-001463	12/6/2018	FT-FY19-112018-001463-A	<1	FT-FY19-112018-001463-B	<1
WS- 001464	9/25/2018	9/25/2019	1	Combo Faucet	In classroom 102	Right	WF-09252018-001464	12/6/2018	FT-FY19-112018-001464-A	<1	FT-FY19-112018-001464-B	<1
WS- 001465	5/15/2018	5/15/2019	1	Combo Fountain	In classroom 102	Right	WF-05152018-001465	12/6/2018	FT-FY19-112018-001465-A	<1	FT-FY19-112018-001465-B	<1
WS- 001466	9/25/2018	9/25/2019	1	Combo Faucet	In classroom 101	Left	WF-09252018-001466	12/6/2018	FT-FY19-112018-001466-A	<1	FT-FY19-112018-001466-B	<1
WS- 001467	5/15/2018	5/15/2019	1	Combo Fountain	In classroom 101	Right	WF-05152018-001467	12/6/2018	FT-FY19-112018-001467-A	<1	FT-FY19-112018-001467-B	<1
WS- 001468	9/25/2018	9/25/2019	1	Combo Faucet	In classroom 103	Left	WF-09252018-001468	12/6/2018	FT-FY19-112018-001468-A	<1	FT-FY19-112018-001468-B	<1
WS- 001469	5/15/2018	5/15/2019	1	Combo Fountain	In classroom 103	Right	WF-05152018-001469	12/6/2018	FT-FY19-112018-001469-A	<1	FT-FY19-112018-001469-B	<1
WS- 001470	9/25/2018	9/25/2019	1	Combo Faucet	In classroom 105	Left	WF-09252018-001470	12/6/2018	FT-FY19-112018-001470-A	<1	FT-FY19-112018-001470-B	<1
WS- 001471	5/15/2018	5/15/2019	1	Combo Fountain	In classroom 105	Right	WF-05152018-001471	12/6/2018	FT-FY19-112018-001471-A	<1	FT-FY19-112018-001471-B	<1
WS- 001472	5/15/2018	5/15/2019	2	Break Room	In staff lounge	Mid	WF-05152018-001472	12/6/2018	FT-FY19-112018-001472-A	<1	FT-FY19-112018-001472-B	<1
WS- 001473	5/15/2018	5/15/2019	2	Cooler	In hallway across from janitor closet	WF-05152018-001473	12/6/2018	FT-FY19-112018-001473-A	<1	FT-FY19-112018-001473-B	<1	
WS- 001474	9/25/2018	9/25/2019	2	Combo Faucet	In classroom 208	Left	WF-09252018-001474	12/6/2018	FT-FY19-112018-001474-A	<1	FT-FY19-112018-001474-B	<1
WS- 001475	5/15/2018	5/15/2019	2	Combo Fountain	In classroom 208	Right	WF-05152018-001475	12/6/2018	FT-FY19-112018-001475-A	<1	FT-FY19-112018-001475-B	<1
WS- 001476	9/25/2018	9/25/2019	2	Combo Faucet	In classroom 212	Left	WF-09252018-001476	12/6/2018	FT-FY19-112018-001476-A	<1	FT-FY19-112018-001476-B	<1
WS- 001477	5/15/2018	5/15/2019	2	Combo Fountain	In classroom 212	Right	WF-05152018-001477	12/6/2018	FT-FY19-112018-001477-A	<1	FT-FY19-112018-001477-B	<1
WS- 001478	9/25/2018	9/25/2019	2	Combo Faucet	In classroom 211	Left	WF-09252018-001478	12/6/2018	FT-FY19-112018-001478-A	<1	FT-FY19-112018-001478-B	<1
WS- 001479	5/15/2018	5/15/2019	2	Combo Fountain	In classroom 211	Right	WF-05152018-001479	12/6/2018	FT-FY19-112018-001479-A	<1	FT-FY19-112018-001479-B	<1
WS- 001480	9/25/2018	9/25/2019	2	Combo Faucet	In classroom 207	Left	WF-09252018-001480	12/6/2018	FT-FY19-112018-001480-A	<1	FT-FY19-112018-001480-B	<1
WS- 001481	5/15/2018	5/15/2019	2	Combo Fountain	In classroom 207	Right	WF-05152018-001481	12/6/2018	FT-FY19-112018-001481-A	<1	FT-FY19-112018-001481-B	<1
WS- 001482	9/25/2018	9/25/2019	2	Combo Faucet	In classroom 210	Left	WF-09252018-001482	12/6/2018	FT-FY19-112018-001482-A	<1	FT-FY19-112018-001482-B	<1
WS- 001483	5/15/2018	5/15/2019	2	Combo Fountain	In Classroom 210	Right	WF-05152018-001483	12/6/2018	FT-FY19-112018-001483-A	<1	FT-FY19-112018-001483-B	<1
WS- 001484	9/25/2018	9/25/2019	2	Combo Faucet	In classroom 209	Left	WF-09252018-001484	12/6/2018	FT-FY19-112018-001484-A	<1	FT-FY19-112018-001484-B	<1
WS- 001485	5/15/2018	5/15/2019	2	Combo Fountain	In Classroom 209	Right	WF-05152018-001485	12/6/2018	FT-FY19-112018-001485-A	<1	FT-FY19-112018-001485-B	<1
WS- 001486	9/25/2018	9/25/2019	2	Combo Faucet	In classroom 206	Left	WF-09252018-001486	12/6/2018	FT-FY19-112018-001486-A	<1	FT-FY19-112018-001486-B	<1
WS- 001487	5/15/2018	5/15/2019	2	Combo Fountain	In classroom 206	Left	WF-05152018-001487	12/6/2018	FT-FY19-112018-001487-A	<1	FT-FY19-112018-001487-B	<1

WS- 001488	9/25/2018	9/25/2019	2	Combo Faucet	In classroom 206	Right	WF-09252018-001488	12/6/2018	FT-FY19-112018-001488-A	<1	FT-FY19-112018-001488-B	<1
WS- 001489	5/15/2018	5/15/2019	2	Combo Fountain	In classroom 206	Right	WF-05152018-001489	12/6/2018	FT-FY19-112018-001489-A	<1	FT-FY19-112018-001489-B	<1
WS- 001490	9/25/2018	9/25/2019	2	Combo Faucet	In classroom 205		WF-09252018-001490	12/6/2018	FT-FY19-112018-001490-A	<1	FT-FY19-112018-001490-B	<1
WS- 001491	5/15/2018	5/15/2019	2	Combo Fountain	In classroom 205		WF-05152018-001491	12/6/2018	FT-FY19-112018-001491-A	<1	FT-FY19-112018-001491-B	<1
WS- 001492	5/15/2018	5/15/2019	2	Cooler	In hallway adjacent to room 204		WF-05152018-001492	12/6/2018	FT-FY19-112018-001492-A	<1	FT-FY19-112018-001492-B	<1
WS- 001493	9/25/2018	9/25/2019	2	Combo Faucet	In classroom 203	Left	WF-09252018-001493	12/6/2018	FT-FY19-112018-001493-A	<1	FT-FY19-112018-001493-B	<1
WS- 001494	5/15/2018	5/15/2019	2	Combo Fountain	In classroom 203	Right	WF-05152018-001494	12/6/2018	FT-FY19-112018-001494-A	<1	FT-FY19-112018-001494-B	<1
WS- 001495	9/25/2018	9/25/2019	2	Combo Faucet	In classroom 204	Left	WF-09252018-001495	12/6/2018	FT-FY19-112018-001495-A	<1	FT-FY19-112018-001495-B	<1
WS- 001496	5/15/2018	5/15/2019	2	Combo Fountain	In classroom 204	Right	WF-05152018-001496	12/6/2018	FT-FY19-112018-001496-A	<1	FT-FY19-112018-001496-B	<1
WS- 001497	9/25/2018	9/25/2019	2	Combo Faucet	In classroom 201	Left	WF-09252018-001497	12/6/2018	FT-FY19-112018-001497-A	<1	FT-FY19-112018-001497-B	<1
WS- 001498	5/15/2018	5/15/2019	2	Combo Fountain	In classroom 201	Right	WF-05152018-001498	12/6/2018	FT-FY19-112018-001498-A	<1	FT-FY19-112018-001498-B	<1
WS- 001499	9/25/2018	9/25/2019	2	Combo Faucet	In classroom 202	Left	WF-09252018-001499	12/6/2018	FT-FY19-112018-001499-A	<1	FT-FY19-112018-001499-B	<1
WS- 001500	5/15/2018	5/15/2019	2	Combo Fountain	In classroom 202	Right	WF-05152018-001500	12/6/2018	FT-FY19-112018-001500-A	<1	FT-FY19-112018-001500-B	<1
WS- 001503	9/25/2018	9/25/2019	1	Bathroom	In classroom 101 in bathroom		WF-09252018-001503	12/6/2018	FT-FY19-112018-001503-A	<1	FT-FY19-112018-001503-B	<1
WS- 001504	9/25/2018	9/25/2019	1	Bathroom	In classroom 102 in bathroom		WF-09252018-001504	12/6/2018	FT-FY19-112018-001504-A	<1	FT-FY19-112018-001504-B	<1
WS- 001505	9/25/2018	9/25/2019	1	Bathroom	In classroom 103 in bathroom		WF-09252018-001505	12/6/2018	FT-FY19-112018-001505-A	<1	FT-FY19-112018-001505-B	<1
WS- 001506	9/25/2018	9/25/2019	1	Bathroom	In classroom 104 in bathroom		WF-09252018-001506	12/6/2018	FT-FY19-112018-001506-A	<1	FT-FY19-112018-001506-B	<1
WS- 001507	9/25/2018	9/25/2019	1	Bathroom	In classroom 105 in bathroom		WF-09252018-001507	12/6/2018	FT-FY19-112018-001507-A	<1	FT-FY19-112018-001507-B	<1
WS- 001508	9/25/2018	9/25/2019	1	Bathroom	In classroom 106 in bathroom		WF-09252018-001508	12/6/2018	FT-FY19-112018-001508-A	<1	FT-FY19-112018-001508-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Floor	Device Type	Device Location				Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 001450	Basement	Food Prep Sink	In kitchen second clockwise from entry door				Mid	12/6/2018	FT-FY19-112018-001450-A	<1	FT-FY19-112018-001450-B	<1
WS- 001451	Basement	Food Prep Sink	In kitchen third clockwise from entry door				Low Mid	12/6/2018	FT-FY19-112018-001451-A	<1	FT-FY19-112018-001451-B	<1
WS- 001452	Basement	Food Prep Sink	In kitchen fourth clockwise from entry door				Mid	12/6/2018	FT-FY19-112018-001452-A	<1	FT-FY19-112018-001452-B	<1