



# Kimball @ Davis ES Lead Water Test Results



## FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-007499	6/15/2018	6/15/2019	1	Combo Fountain	In classroom c109	WF-06152018-007499	10/22/2018	FT-FY19-102018-007499-A	< 1	FT-FY19-102018-007499-B	< 1
WS-007500	6/15/2018	6/15/2019	2	Cooler	In hallway adjacent to janitors closet b201c	WF-06152018-007500	10/22/2018	FT-FY19-102018-007500-A	< 1	FT-FY19-102018-007500-B	< 1
WS-007501	6/15/2018	6/15/2019	2	Cooler	In hallway adjacent to classroom 204	WF-06152018-007501	10/22/2018	FT-FY19-102018-007501-A	< 1	FT-FY19-102018-007501-B	< 1
WS-007502	6/15/2018	6/15/2019	2	Cooler	In hallway across from room 207	WF-06152018-007502	10/22/2018	FT-FY19-102018-007502-A	< 1	FT-FY19-102018-007502-B	< 1
WS-007505	6/15/2018	6/15/2019	1	Cooler	In hallway adjacent to janitors closet c108	WF-06152018-007505	10/22/2018	FT-FY19-102018-007505-A	< 1	FT-FY19-102018-007505-B	< 1
WS-007508	6/15/2018	6/15/2019	1	Cooler	In hallway adjacent to b101c janitor closet	WF-06152018-007508	10/22/2018	FT-FY19-102018-007508-A	< 1	FT-FY19-102018-007508-B	< 1
WS-007509	6/15/2018	6/15/2019	1	Health Suite	In health suite room a103	WF-06152018-007509	10/22/2018	FT-FY19-102018-007509-A	< 1	FT-FY19-102018-007509-B	< 1
WS-007510	6/15/2018	6/15/2019	1	Cooler	In hallway adjacent to classroom a102	WF-06152018-007510	10/22/2018	FT-FY19-102018-007510-A	< 1	FT-FY19-102018-007510-B	< 1
WS-007511	6/15/2018	6/15/2019	Basement	Cooler	In kitchen hallway adjacent to custodian closet	WF-06152018-007511	10/22/2018	FT-FY19-102018-007511-A	< 1	FT-FY19-102018-007511-B	< 1
WS-007518	6/15/2018	6/15/2019	1	Combo Fountain	In classroom c104	WF-06152018-007518	10/22/2018	FT-FY19-102018-007518-A	< 1	FT-FY19-102018-007518-B	< 1
WS-007519	6/15/2018	6/15/2019	1	Combo Fountain	In classroom c102	WF-06152018-007519	10/22/2018	FT-FY19-102018-007519-A	< 1	FT-FY19-102018-007519-B	< 1
WS-007520	6/15/2018	6/15/2019	1	Combo Fountain	In classroom c103	WF-06152018-007520	10/22/2018	FT-FY19-102018-007520-A	< 1	FT-FY19-102018-007520-B	< 1
WS-007521	6/15/2018	6/15/2019	1	Combo Fountain	In classroom c110	WF-06152018-007521	10/22/2018	FT-FY19-102018-007521-A	< 1	FT-FY19-102018-007521-B	< 1
WS-007503	10/8/2018	10/8/2019	1	Combo Faucet	In classroom c110	WF-10082018-007503	10/22/2018	FT-FY19-102018-007503-A	< 1	FT-FY19-102018-007503-B	< 1
WS-007504	10/8/2018	10/8/2019	1	Combo Faucet	In classroom c109	WF-10082018-007504	10/22/2018	FT-FY19-102018-007504-A	< 1	FT-FY19-102018-007504-B	< 1
WS-007506	10/8/2018	10/8/2019	1	Combo Faucet	In classroom c103	WF-10082018-007506	10/22/2018	FT-FY19-102018-007506-A	< 1	FT-FY19-102018-007506-B	< 1
WS-007507	10/8/2018	10/8/2019	1	Combo Faucet	In classroom c102	WF-10082018-007507	10/22/2018	FT-FY19-102018-007507-A	< 1	FT-FY19-102018-007507-B	< 1
WS-007517	10/8/2018	10/8/2019	1	Combo Faucet	In classroom c104	WF-10082018-007517	10/22/2018	FT-FY19-102018-007517-A	< 1	FT-FY19-102018-007517-B	< 1

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-007515	Basement	Food Prep Sink	In kitchen third from left Right	10/22/2018	FT-FY19-102018-007515-A	< 1	FT-FY19-102018-007515-B	< 1