



Kimball Elementary School Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014450	5/6/2020	5/6/2021	1	Break Room	In room 103 staff	WF-05062020-014450	3/9/2021	FT-FY21-022021-014450-A	<1	FT-FY21-022021-014450-B	<1
WS-014451	5/6/2020	5/6/2021	1	Combo Fountain	In room 103 staff	WF-05062020-014451	3/9/2021	FT-FY21-022021-014451-A	<1	FT-FY21-022021-014451-B	<1
WS-014453	5/6/2020	5/6/2021	1	Combo Fountain	In room 106 parent resource center	WF-05062020-014453	3/9/2021	FT-FY21-022021-014453-A	<1	FT-FY21-022021-014453-B	<1
WS-014454	5/6/2020	5/6/2021	1	Break Room	In room 119 staff	WF-05062020-014454	3/9/2021	FT-FY21-022021-014454-A	<1	FT-FY21-022021-014454-B	<1
WS-014455	5/6/2020	5/6/2021	1	Combo Fountain	In room 119 staff	WF-05062020-014455	3/9/2021	FT-FY21-022021-014455-A	<1	FT-FY21-022021-014455-B	<1
WS-014456	5/6/2020	5/6/2021	1	Health Suite	In room 113 nursing	WF-05062020-014456	3/9/2021	FT-FY21-022021-014456-A	<1	FT-FY21-022021-014456-B	<1
WS-014458	5/6/2020	5/6/2021	1	Combo Fountain	In room 117 classroom	WF-05062020-014458	3/9/2021	FT-FY21-022021-014458-A	<1	FT-FY21-022021-014458-B	<1
WS-014460	5/6/2020	5/6/2021	1	Combo Fountain	In room 116 classroom	WF-05062020-014460	3/9/2021	FT-FY21-022021-014460-A	<1	FT-FY21-022021-014460-B	<1
WS-014462	5/6/2020	5/6/2021	1	Combo Fountain	In room 139 commons	Left WF-05062020-014462	3/9/2021	FT-FY21-022021-014462-A	<1	FT-FY21-022021-014462-B	<1
WS-014464	5/6/2020	5/6/2021	1	Combo Fountain	In room 139 commons	Right WF-05062020-014464	3/9/2021	FT-FY21-022021-014464-A	<1	FT-FY21-022021-014464-B	<1
WS-014465	10/21/2020	10/21/2021	1	Combo Faucet	In room 121 classroom	WF-10212020-014465	3/9/2021	FT-FY21-022021-014465-A	<1	FT-FY21-022021-014465-B	<1
WS-014466	5/6/2020	5/6/2021	1	Combo Fountain	In room 121 classroom	WF-05062020-014466	3/9/2021	FT-FY21-022021-014466-A	<1	FT-FY21-022021-014466-B	<1
WS-014467	10/21/2020	10/21/2021	1	Combo Faucet	In room 122 classroom	WF-10212020-014467	3/9/2021	FT-FY21-022021-014467-A	<1	FT-FY21-022021-014467-B	<1
WS-014468	5/6/2020	5/6/2021	1	Combo Fountain	In room 122 classroom	WF-05062020-014468	3/9/2021	FT-FY21-022021-014468-A	<1	FT-FY21-022021-014468-B	<1
WS-014469	10/21/2020	10/21/2021	1	Combo Faucet	In room 123 classroom	WF-10212020-014469	3/9/2021	FT-FY21-022021-014469-A	<1	FT-FY21-022021-014469-B	<1
WS-014470	5/6/2020	5/6/2021	1	Combo Fountain	In room 123 classroom	WF-05062020-014470	3/9/2021	FT-FY21-022021-014470-A	<1	FT-FY21-022021-014470-B	<1
WS-014471	5/6/2020	5/6/2021	1	Bottle Filler	In hallway outside of restrooms	WF-05062020-014471	3/9/2021	FT-FY21-022021-014471-A	<1	FT-FY21-022021-014471-B	<1
WS-014481	5/6/2020	5/6/2021	1	Bottle Filler	In room 128 student dining	WF-05062020-014481	3/9/2021	FT-FY21-022021-014481-A	<1	FT-FY21-022021-014481-B	<1
WS-014484	5/6/2020	5/6/2021	1	Bottle Filler	In room 130 platform	WF-05062020-014484	3/9/2021	FT-FY21-022021-014484-A	<1	FT-FY21-022021-014484-B	<1
WS-014487	10/21/2020	10/21/2021	1	Combo Faucet	In room 132 classroom	WF-10212020-014487	3/9/2021	FT-FY21-022021-014487-A	<1	FT-FY21-022021-014487-B	<1
WS-014488	5/6/2020	5/6/2021	1	Combo Fountain	In room 132 classroom	WF-05062020-014488	3/9/2021	FT-FY21-022021-014488-A	<1	FT-FY21-022021-014488-B	<1
WS-014489	10/21/2020	10/21/2021	1	Combo Faucet	In room 133 classroom	WF-10212020-014489	3/9/2021	FT-FY21-022021-014489-A	<1	FT-FY21-022021-014489-B	<1
WS-014490	5/6/2020	5/6/2021	1	Combo Fountain	In room 133 classroom	WF-05062020-014490	3/9/2021	FT-FY21-022021-014490-A	<1	FT-FY21-022021-014490-B	<1
WS-014491	10/21/2020	10/21/2021	1	Combo Faucet	In room 134 classroom	WF-10212020-014491	3/9/2021	FT-FY21-022021-014491-A	<1	FT-FY21-022021-014491-B	<1
WS-014492	5/6/2020	5/6/2021	1	Combo Fountain	In room 134 classroom	WF-05062020-014492	3/9/2021	FT-FY21-022021-014492-A	<1	FT-FY21-022021-014492-B	<1
WS-014493	10/21/2020	10/21/2021	1	Combo Faucet	In room 135 classroom	WF-10212020-014493	3/9/2021	FT-FY21-022021-014493-A	<1	FT-FY21-022021-014493-B	<1
WS-014494	5/6/2020	5/6/2021	1	Combo Fountain	In room 135 classroom	WF-05062020-014494	3/9/2021	FT-FY21-022021-014494-A	<1	FT-FY21-022021-014494-B	<1
WS-014496	5/6/2020	5/6/2021	2	Combo Fountain	In room 210 classroom first clockwise from entry	WF-05062020-014496	3/9/2021	FT-FY21-022021-014496-A	1.2	FT-FY21-022021-014496-B	<1
WS-014498	5/6/2020	5/6/2021	2	Combo Fountain	In room 210 classroom second clockwise from entry	WF-05062020-014498	3/9/2021	FT-FY21-022021-014498-A	3.5	FT-FY21-022021-014498-B	<1
WS-014500	5/6/2020	5/6/2021	2	Combo Fountain	In room 210 classroom third clockwise from entry	WF-05062020-014500	3/9/2021	FT-FY21-022021-014500-A	<1	FT-FY21-022021-014500-B	<1
WS-014502	5/6/2020	5/6/2021	2	Combo Fountain	In room 210 classroom fourth clockwise from entry	WF-05062020-014502	3/9/2021	FT-FY21-022021-014502-A	<1	FT-FY21-022021-014502-B	<1
WS-014503	5/6/2020	5/6/2021	2	Break Room	In room 211 staff	WF-05062020-014503	3/9/2021	FT-FY21-022021-014503-A	<1	FT-FY21-022021-014503-B	<1
WS-014504	5/6/2020	5/6/2021	2	Combo Fountain	In room 211 staff	WF-05062020-014504	3/9/2021	FT-FY21-022021-014504-A	<1	FT-FY21-022021-014504-B	<1

WS-014509	5/6/2020	5/6/2021	2	Combo Fountain	In room music classroom	WF-05062020-014509	3/9/2021	FT-FY21-022021-014509-A	<1	FT-FY21-022021-014509-B	<1
WS-014511	5/6/2020	5/6/2021	2	Combo Fountain	In room 237 commons	WF-05062020-014511	3/9/2021	FT-FY21-022021-014511-A	<1	FT-FY21-022021-014511-B	<1
WS-014513	5/6/2020	5/6/2021	2	Combo Fountain	In room 216 food prints lab first clockwise from entry	WF-05062020-014513	3/9/2021	FT-FY21-022021-014513-A	<1	FT-FY21-022021-014513-B	<1
WS-014518	5/6/2020	5/6/2021	2	Combo Fountain	In room 216 food prints lab fifth clockwise from entry	WF-05062020-014518	3/9/2021	FT-FY21-022021-014518-A	1.6	FT-FY21-022021-014518-B	<1
WS-014520	5/6/2020	5/6/2021	2	Combo Fountain	In room 217 classroom	WF-05062020-014520	3/9/2021	FT-FY21-022021-014520-A	<1	FT-FY21-022021-014520-B	<1
WS-014522	5/6/2020	5/6/2021	2	Combo Fountain	In room 218 classroom	WF-05062020-014522	3/9/2021	FT-FY21-022021-014522-A	<1	FT-FY21-022021-014522-B	<1
WS-014524	5/6/2020	5/6/2021	2	Combo Fountain	In room 219 classroom	WF-05062020-014524	3/9/2021	FT-FY21-022021-014524-A	<1	FT-FY21-022021-014524-B	<1
WS-014525	5/6/2020	5/6/2021	2	Break Room	In room 222 classroom	WF-05062020-014525	3/9/2021	FT-FY21-022021-014525-A	<1	FT-FY21-022021-014525-B	<1
WS-014526	5/6/2020	5/6/2021	2	Combo Fountain	In room 222 classroom	WF-05062020-014526	3/9/2021	FT-FY21-022021-014526-A	<1	FT-FY21-022021-014526-B	<1
WS-014528	5/6/2020	5/6/2021	2	Combo Fountain	In library in room 223D small group instruction	WF-05062020-014528	3/9/2021	FT-FY21-022021-014528-A	<1	FT-FY21-022021-014528-B	<1
WS-014530	5/6/2020	5/6/2021	2	Combo Fountain	In room 227 classroom	WF-05062020-014530	3/9/2021	FT-FY21-022021-014530-A	<1	FT-FY21-022021-014530-B	<1
WS-014532	5/6/2020	5/6/2021	2	Combo Fountain	In room 228 classroom	WF-05062020-014532	3/9/2021	FT-FY21-022021-014532-A	<1	FT-FY21-022021-014532-B	<1
WS-014534	5/6/2020	5/6/2021	2	Combo Fountain	In room 230 classroom	WF-05062020-014534	3/9/2021	FT-FY21-022021-014534-A	<1	FT-FY21-022021-014534-B	<1
WS-014536	5/6/2020	5/6/2021	2	Combo Fountain	In room 231 classroom	WF-05062020-014536	3/9/2021	FT-FY21-022021-014536-A	<1	FT-FY21-022021-014536-B	<1
WS-014538	5/6/2020	5/6/2021	2	Combo Fountain	In room 233 classroom	WF-05062020-014538	3/9/2021	FT-FY21-022021-014538-A	<1	FT-FY21-022021-014538-B	<1
WS-014540	5/6/2020	5/6/2021	3	Combo Fountain	In room 300 commons	WF-05062020-014540	3/9/2021	FT-FY21-022021-014540-A	<1	FT-FY21-022021-014540-B	<1
WS-014541	5/6/2020	5/6/2021	3	Break Room	In room 301 staff	WF-05062020-014541	3/9/2021	FT-FY21-022021-014541-A	<1	FT-FY21-022021-014541-B	<1
WS-014542	5/6/2020	5/6/2021	3	Combo Fountain	In room 301 staff	WF-05062020-014542	3/9/2021	FT-FY21-022021-014542-A	<1	FT-FY21-022021-014542-B	<1
WS-014544	5/6/2020	5/6/2021	3	Combo Fountain	In room 305 classroom	WF-05062020-014544	3/9/2021	FT-FY21-022021-014544-A	<1	FT-FY21-022021-014544-B	<1
WS-014546	5/6/2020	5/6/2021	3	Combo Fountain	In room 306 classroom	WF-05062020-014546	3/9/2021	FT-FY21-022021-014546-A	<1	FT-FY21-022021-014546-B	<1
WS-014548	5/6/2020	5/6/2021	3	Combo Fountain	In room 307 classroom	WF-05062020-014548	3/9/2021	FT-FY21-022021-014548-A	<1	FT-FY21-022021-014548-B	<1
WS-014550	5/6/2020	5/6/2021	3	Combo Fountain	In room 308 classroom	WF-05062020-014550	3/9/2021	FT-FY21-022021-014550-A	<1	FT-FY21-022021-014550-B	<1
WS-014552	5/6/2020	5/6/2021	3	Combo Fountain	In room 309 classroom	WF-05062020-014552	3/9/2021	FT-FY21-022021-014552-A	1.2	FT-FY21-022021-014552-B	<1
WS-014553	5/6/2020	5/6/2021	3	Bottle Filler	In hallway across from 310 electrical	WF-05062020-014553	3/9/2021	FT-FY21-022021-014553-A	<1	FT-FY21-022021-014553-B	<1
WS-014557	5/6/2020	5/6/2021	3	Combo Fountain	In room 311 classroom	WF-05062020-014557	3/9/2021	FT-FY21-022021-014557-A	<1	FT-FY21-022021-014557-B	<1
WS-014559	5/6/2020	5/6/2021	3	Combo Fountain	In room 312 classroom	WF-05062020-014559	3/9/2021	FT-FY21-022021-014559-A	<1	FT-FY21-022021-014559-B	<1
WS-014561	5/6/2020	5/6/2021	3	Combo Fountain	In room 313 classroom	WF-05062020-014561	3/9/2021	FT-FY21-022021-014561-A	<1	FT-FY21-022021-014561-B	<1
WS-014562	8/18/2020	8/18/2021	2	Break Room	In room inside staff room 222	WF-08182020-014562	3/9/2021	FT-FY21-022021-014562-A	<1	FT-FY21-022021-014562-B	<1
WS-014563	8/18/2020	8/18/2021	2	Combo Fountain	In room inside staff room 222	WF-08182020-014563	3/9/2021	FT-FY21-022021-014563-A	<1	FT-FY21-022021-014563-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014476	2/19/2021	2/19/2022	1	Food Prep Sink	In kitchen third clockwise from entry	WF-02192021-014476	3/9/2021	FT-FY21-022021-014476-A	<1	FT-FY21-022021-014476-B	<1
WS-014514	2/19/2021	2/19/2022	2	Food Prep Sink	In room 216 food prints lab second clockwise from entry Left	WF-02192021-014514	3/9/2021	FT-FY21-022021-014514-A	<1	FT-FY21-022021-014514-B	<1
WS-014515	2/19/2021	2/19/2022	2	Food Prep Sink	In room 216 food prints lab third clockwise from entry Mid	WF-02192021-014515	3/9/2021	FT-FY21-022021-014515-A	<1	FT-FY21-022021-014515-B	<1
WS-014516	2/19/2021	2/19/2022	2	Food Prep Sink	In room 216 food prints lab fourth clockwise from entry Right	WF-02192021-014516	3/9/2021	FT-FY21-022021-014516-A	<1	FT-FY21-022021-014516-B	<1