



KIMBALL ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	KIMBALL ELEMENTARY SCHOOL	WS- 004442	8/12/2016	Basement	Food Prep Sink	In kitchen	FT-82016-004442-A	< 1	FT-82016-004442-B	< 1
2	KIMBALL ELEMENTARY SCHOOL	WS- 004443	8/12/2016	1	Cooler	In hallway adjacent to room 108	FT-82016-004443-A	< 1	FT-82016-004443-B	< 1
3	KIMBALL ELEMENTARY SCHOOL	WS- 004444	8/12/2016	1	Cooler	In hallway across from room 112	FT-82016-004444-A	< 1	FT-82016-004444-B	< 1
4	KIMBALL ELEMENTARY SCHOOL	WS- 004445	8/12/2016	1	Fountain	In classroom 109	FT-82016-004445-A	< 1	FT-82016-004445-B	< 1
5	KIMBALL ELEMENTARY SCHOOL	WS- 004446	8/12/2016	1	Cooler	In hallway adjacent to staff restroom	FT-82016-004446-A	< 1	FT-82016-004446-B	< 1
6	KIMBALL ELEMENTARY SCHOOL	WS- 004447	8/12/2016	1	Cooler	In hallway adjacent to auditorium	FT-82016-004447-A	< 1	FT-82016-004447-B	< 1
7	KIMBALL ELEMENTARY SCHOOL	WS- 004448	8/12/2016	1	Cooler	In hallway across from room 104	FT-82016-004448-A	< 1	FT-82016-004448-B	< 1
8	KIMBALL ELEMENTARY SCHOOL	WS- 004449	8/12/2016	1	Cooler	In classroom 102	FT-82016-004449-A	< 1	FT-82016-004449-B	1.1
			10/10/2016				Re-test A	< 1	Re-test B	< 1
9	KIMBALL ELEMENTARY SCHOOL	WS- 004450	8/12/2016	1	Cooler	In hallway across from room 102	FT-82016-004450-A	1.3	FT-82016-004450-B	< 1
			10/10/2016				Re-test A	< 1	Re-test B	< 1
10	KIMBALL ELEMENTARY SCHOOL	WS- 004452	8/12/2016	1	Classroom Faucet	In classroom 122	FT-72016-004452-A	< 1	FT-72016-004452-B	< 1
11	KIMBALL ELEMENTARY SCHOOL	WS- 004453	8/12/2016	Basement	Cooler	In hallway adjacent to staff restroom	FT-82016-004453-A	< 1	FT-82016-004453-B	< 1
12	KIMBALL ELEMENTARY SCHOOL	WS- 004454	8/12/2016	Basement	Health Suite	In health suite 005	FT-82016-004454-A	< 1	FT-82016-004454-B	< 1
13	KIMBALL ELEMENTARY SCHOOL	WS- 004456	8/12/2016	2	Cooler	In hallway adjacent to staff restroom	FT-82016-004456-A	< 1	FT-82016-004456-B	1.2
			10/10/2016				Re-test A	< 1	Re-test B	< 1
14	KIMBALL ELEMENTARY SCHOOL	WS- 004457	8/12/2016	2	Cooler	In hallway across from room OS2B	FT-82016-004457-A	< 1	FT-82016-004457-B	< 1
15	KIMBALL ELEMENTARY SCHOOL	WS- 004458	8/12/2016	2	Cooler	In hallway adjacent to room 212	FT-82016-004458-A	< 1	FT-82016-004458-B	< 1
16	KIMBALL ELEMENTARY SCHOOL	WS- 004459	8/12/2016	2	Cooler	In hallway adjacent to staff lounge	FT-82016-004459-A	< 1	FT-82016-004459-B	< 1
17	KIMBALL ELEMENTARY SCHOOL	WS- 004462	8/12/2016	2	Classroom Faucet	In science lab room 201	FT-72016-004462-A	< 1	FT-72016-004462-B	< 1
18	KIMBALL ELEMENTARY SCHOOL	WS- 004463	8/12/2016	2	Cooler	In hallway adjacent to room 203	FT-72016-004463-A	< 1	FT-72016-004463-B	< 1
19	KIMBALL ELEMENTARY SCHOOL	WS- 004464	8/12/2016	2	Classroom Faucet	In science lab room203	FT-72016-004464-A	< 1	FT-72016-004464-B	< 1
20	KIMBALL ELEMENTARY SCHOOL	WS- 004465	42594	Basement	Cooler	In cafeteria	FT-82016-004465-A	< 1	FT-82016-004465-B	< 1
21	KIMBALL ELEMENTARY SCHOOL	WS- 004466	42594	2	Cooler	In hallway adjacent to room 200	FT-82016-004466-A	< 1	FT-82016-004466-B	< 1