



KING ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	KING ELEMENTARY SCHOOL	WS- 008502	8/7/2016	1	Food Prep Sink	In kitchen second clockwise from entry door	FT-72016-008502-A	< 1	FT-72016-008502-B	< 1
2	KING ELEMENTARY SCHOOL	WS- 008503	8/7/2016	1	Food Prep Sink	In kitchen third clockwise from entry door	FT-72016-008503-A	< 1	FT-72016-008503-B	< 1
3	KING ELEMENTARY SCHOOL	WS- 008504	8/7/2016	1	Cooler	In gym/cafeteria	FT-72016-008504-A	< 1	FT-72016-008504-B	< 1
4	KING ELEMENTARY SCHOOL	WS- 008505	8/7/2016	1	Health Suite	In health suite 108	FT-72016-008505-A	< 1	FT-72016-008505-B	< 1
5	KING ELEMENTARY SCHOOL	WS- 008508	8/7/2016	1	Cooler	In hallway adjacent to boys' restroom High Left	FT-72016-008508-A	< 1	FT-72016-008508-B	< 1
6	KING ELEMENTARY SCHOOL	WS- 008509	8/7/2016	1	Cooler	In hallway adjacent to boys' restroom Low Right	FT-72016-008509-A	< 1	FT-72016-008509-B	< 1
7	KING ELEMENTARY SCHOOL	WS- 008510	8/7/2016	1	Cooler	In hallway adjacent to girls' restroom High Left	FT-72016-008510-A	< 1	FT-72016-008510-B	< 1
8	KING ELEMENTARY SCHOOL	WS- 008511	8/7/2016	1	Cooler	In hallway adjacent to girls' restroom Low Right	FT-72016-008511-A	< 1	FT-72016-008511-B	< 1
9	KING ELEMENTARY SCHOOL	WS- 008521	8/7/2016	2	Cooler	In hallway adjacent to room 208 High Left	FT-72016-008521-A	< 1	FT-72016-008521-B	< 1
10	KING ELEMENTARY SCHOOL	WS- 008522	8/7/2016	2	Cooler	In hallway adjacent to room 208 Low Right	FT-72016-008522-A	< 1	FT-72016-008522-B	< 1
11	KING ELEMENTARY SCHOOL	WS- 008524	8/7/2016	2	Cooler	In hallway adjacent to boys' restroom 206 High Left	FT-72016-008524-A	< 1	FT-72016-008524-B	< 1
12	KING ELEMENTARY SCHOOL	WS- 008525	8/7/2016	2	Cooler	In hallway adjacent to boys' restroom 206 Low Right	FT-72016-008525-A	< 1	FT-72016-008525-B	< 1
13	KING ELEMENTARY SCHOOL	WS- 008532	8/7/2016	3	Cooler	In hallway adjacent to boys' restroom 305 High Left	FT-72016-008532-A	< 1	FT-72016-008532-B	< 1
14	KING ELEMENTARY SCHOOL	WS- 008533	8/7/2016	3	Cooler	In hallway adjacent to boys' restroom 305 Low Right	FT-72016-008533-A	< 1	FT-72016-008533-B	< 1
15	KING ELEMENTARY SCHOOL	WS- 008534	8/7/2016	3	Cooler	In hallway adjacent to room 307 High Right	FT-72016-008534-A	< 1	FT-72016-008534-B	< 1
16	KING ELEMENTARY SCHOOL	WS- 008535	8/7/2016	3	Cooler	In hallway adjacent to room 307 Low Right	FT-72016-008535-A	< 1	FT-72016-008535-B	< 1
17	KING ELEMENTARY SCHOOL	WS- 008536	8/7/2016	3	Classroom Faucet	In science lab room 315 first clockwise from entry door Right	FT-72016-008536-A	< 1	FT-72016-008536-B	< 1
18	KING ELEMENTARY SCHOOL	WS- 008537	8/7/2016	3	Classroom Faucet	In science lab room 315 second clockwise from entry door Right	FT-72016-008537-A	< 1	FT-72016-008537-B	< 1
19	KING ELEMENTARY SCHOOL	WS- 008538	8/7/2016	3	Classroom Faucet	In science lab room 315 third clockwise from entry door Left	FT-72016-008538-A	< 1	FT-72016-008538-B	< 1