



KING LEAD WATER TEST RESULTS

May 16th, 2016



| Building Location | Sample Collected Date | Water Source ID | Device Type | Floor | Device Location | 1st Draw - Sample ID | Final Result - 1st Draw (ug/L) | 2nd Draw - Sample ID | Final Result - 2nd Draw (ug/L) | Remediation | Retest Date | Retest 1st Draw | Retest 2nd Draw |
|---------------------------|-----------------------|-----------------|--------------|----------|--|----------------------|--------------------------------|----------------------|--------------------------------|--|-------------|-----------------|-----------------|
| 1 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008500 | Utility | Basement | In boiler room sink | WT-042916-8517- A | < 1 | WT-042916-8517- B | < 1 | | | | |
| 2 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008501 | Kitchen | 1 | In kitchen facing to N wall, spray nozzle | WT-042916-8518- A | < 1 | WT-042916-8518- B | < 1 | | | | |
| 3 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008502 | Kitchen | 1 | In kitchen facing to N wall | WT-042916-8519- A | 1.14 | WT-042916-8519- B | < 1 | | | | |
| 4 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008503 | Kitchen | 1 | In kitchen facing to SW wall | WT-042916-8520- A | < 1 | WT-042916-8520- B | < 1 | | | | |
| 5 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008504 | Cooler | 1 | In gym/cafeteria | WT-042916-8521- A | < 1 | WT-042916-8521- B | < 1 | | | | |
| 6 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008505 | Health Suite | 1 | In room 108 | WT-042916-8522- A | < 1 | WT-042916-8522- B | < 1 | | | | |
| 7 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008506 | Classroom | 1 | In room 109 | WT-042916-8523- A | 7.81 | WT-042916-8523- B | 2.23 | | | | |
| 8 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008507 | Classroom | 1 | In classroom 118 | WT-042916-8524- A | < 1 | WT-042916-8524- B | < 1 | | | | |
| 9 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008508 | Cooler | 1 | In hallway adjacent to boys RR | WT-042916-8525- A | < 1 | WT-042916-8525- B | < 1 | | | | |
| 10 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008509 | Cooler | 1 | In hallway adjacent to boys RR | WT-042916-8526- A | < 1 | WT-042916-8526- B | < 1 | | | | |
| 11 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008510 | Cooler | 1 | In hallway adjacent to girls RR | WT-042916-8527- A | < 1 | WT-042916-8527- B | < 1 | | | | |
| 12 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008511 | Cooler | 1 | In hallway adjacent to girls RR | WT-042916-8528- A | < 1 | WT-042916-8528- B | < 1 | | | | |
| 13 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008512 | Classroom | 1 | In classroom 117 | WT-042916-8529- A | 2.05 | WT-042916-8529- B | < 1 | | | | |
| 14 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008513 | Classroom | 1 | In classroom 113 | WT-042916-8530- A | < 1 | WT-042916-8530- B | < 1 | | | | |
| 15 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008514 | Classroom | 1 | In classroom 114 | WT-042916-8531- A | < 1 | WT-042916-8531- B | 1.35 | | | | |
| 16 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008515 | Classroom | 1 | In classroom 116 | WT-042916-8532- A | < 1 | WT-042916-8532- B | < 1 | | | | |
| 17 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008516 | Classroom | 1 | In classroom 115 | WT-042916-8533- A | < 1 | WT-042916-8533- B | < 1 | | | | |
| 18 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008517 | Classroom | 2 | In classroom 210 | WT-042916-8534- A | 1.37 | WT-042916-8534- B | < 1 | | | | |
| 19 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008518 | Classroom | 2 | In classroom 209 | WT-042916-8535- A | < 1 | WT-042916-8535- B | 2.09 | | | | |
| 20 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008519 | Classroom | 2 | In classroom 211 | WT-042916-8536- A | 3.68 | WT-042916-8536- B | 1.29 | | | | |
| 21 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008520 | Classroom | 2 | In classroom 208 | WT-042916-8537- A | < 1 | WT-042916-8537- B | < 1 | | | | |
| 22 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008521 | Cooler | 2 | In hallway adjacent to classroom 208 | WT-042916-8538- A | < 1 | WT-042916-8538- B | < 1 | | | | |
| 23 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008522 | Cooler | 2 | In hallway adjacent to classroom 208 | WT-042916-8539- A | < 1 | WT-042916-8539- B | < 1 | | | | |
| 24 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008523 | Classroom | 2 | In classroom 212 | WT-042916-8540- A | 1.26 | WT-042916-8540- B | 1.58 | | | | |
| 25 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008524 | Cooler | 2 | In hallway adjacent to boys RR 206 | WT-042916-8541- A | < 1 | WT-042916-8541- B | < 1 | | | | |
| 26 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008525 | Cooler | 2 | In hallway adjacent to boys RR 206 | WT-042916-8542- A | 1.02 | WT-042916-8542- B | < 1 | | | | |
| 27 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008526 | Classroom | 2 | In classroom 213 | WT-042916-8543- A | 5.3 | WT-042916-8543- B | 6.71 | | | | |
| 28 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008527 | Classroom | 2 | In classroom 203 | WT-042916-8544- A | 3.25 | WT-042916-8544- B | 1.92 | | | | |
| 29 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008528 | Classroom | 2 | In classroom 215 | WT-042916-8545- A | < 1 | WT-042916-8545- B | < 1 | | | | |
| 30 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008529 | Classroom | 2 | In classroom 216 | WT-042916-8546- A | 8.26 | WT-042916-8546- B | 1.28 | | | | |
| 31 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008530 | Classroom | 2 | In classroom 202 | WT-042916-8547- A | 2.41 | WT-042916-8547- B | 1.44 | | | | |
| 32 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008531 | Classroom | 2 | In classroom 217 | WT-042916-8548- A | 2.52 | WT-042916-8548- B | < 1 | | | | |
| 33 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008532 | Cooler | 3 | In hallway adjacent to boys RR 305 | WT-042916-8549- A | < 1 | WT-042916-8549- B | < 1 | | | | |
| 34 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008533 | Cooler | 3 | In hallway adjacent to boys RR 305 | WT-042916-8550- A | < 1 | WT-042916-8550- B | < 1 | | | | |
| 35 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008534 | Cooler | 3 | In hallway adjacent to room 307 | WT-042916-8551- A | < 1 | WT-042916-8551- B | < 1 | | | | |
| 36 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008535 | Cooler | 3 | In hallway adjacent to room 307 | WT-042916-8552- A | < 1 | WT-042916-8552- B | < 1 | | | | |
| 37 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008536 | Classroom | 3 | In classroom 315, first sink on right | WT-042916-8553- A | 18.6 | WT-042916-8553- B | 23.3 | Filter will be installed and then retested | | | |
| 38 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008537 | Classroom | 3 | In classroom 315 second sink on the right | WT-042916-8554- A | 16.8 | WT-042916-8554- B | 11.2 | Filter will be installed and then retested | | | |
| 39 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008538 | Classroom | 3 | In classroom 315 third sink from the right | WT-042916-8555- A | 27.5 | WT-042916-8555- B | 6.24 | Filter will be installed and then retested | | | |
| 40 KING ELEMENTARY SCHOOL | 5/7/2016 | WS- 008539 | Classroom | 3 | In classroom 315 forth sink from the right | WT-042916-8556- A | 6.3 | WT-042916-8556- B | 4.5 | | | | |

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.