



KRAMER MS LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location		1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	KRAMER MIDDLE SCHOOL	WS- 004414	8/22/2016	Basement	Cooler	In hallway adjacent to room 003	High Left	FT-82016-004414-A	< 1	FT-82016-004414-B	< 1
2	KRAMER MIDDLE SCHOOL	WS- 004415	8/22/2016	Basement	Cooler	In hallway adjacent to room 003	Low Right	FT-82016-004415-A	< 1	FT-82016-004415-B	< 1
3	KRAMER MIDDLE SCHOOL	WS- 004416	8/22/2016	Basement	Cooler	In hallway adjacent to cafeteria	High Left	FT-82016-004416-A	< 1	FT-82016-004416-B	< 1
4	KRAMER MIDDLE SCHOOL	WS- 004417	8/22/2016	Basement	Cooler	In hallway adjacent to cafeteria	Low Right	FT-82016-004417-A	< 1	FT-82016-004417-B	< 1
5	KRAMER MIDDLE SCHOOL	WS- 004418	8/22/2016	Basement	Food Prep Sink	In kitchen first clockwise from entry door		FT-82016-004418-A	< 1	FT-82016-004418-B	< 1
6	KRAMER MIDDLE SCHOOL	WS- 004422	8/22/2016	Basement	Cooler	In hallway adjacent to room 019	High Left	FT-82016-004422-A	< 1	FT-82016-004422-B	< 1
7	KRAMER MIDDLE SCHOOL	WS- 004425	8/22/2016	Basement	Cooler	In hallway adjacent to room 019	Low Right	FT-82016-004425-A	< 1	FT-82016-004425-B	< 1
8	KRAMER MIDDLE SCHOOL	WS- 004426	8/22/2016	1	Cooler	In hallway adjacent to room 104	High Left	FT-82016-004426-A	< 1	FT-82016-004426-B	< 1
9	KRAMER MIDDLE SCHOOL	WS- 004427	8/22/2016	1	Cooler	In hallway adjacent to room 104	Low Right	FT-82016-004427-A	< 1	FT-82016-004427-B	< 1
10	KRAMER MIDDLE SCHOOL	WS- 004428	8/22/2016	1	Health Suite	In treatment room 110A in health suite		FT-82016-004428-A	< 1	FT-82016-004428-B	< 1
11	KRAMER MIDDLE SCHOOL	WS- 004429	8/22/2016	1	Cooler	In hallway across from room 117	High Left	FT-82016-004429-A	< 1	FT-82016-004429-B	< 1
12	KRAMER MIDDLE SCHOOL	WS- 004430	8/22/2016	1	Cooler	In hallway across from room 117	Low Right	FT-82016-004430-A	< 1	FT-82016-004430-B	< 1
13	KRAMER MIDDLE SCHOOL	WS- 004431	8/22/2016	1	Cooler	In hallway adjacent to room 128	High Left	FT-82016-004431-A	< 1	FT-82016-004431-B	< 1
14	KRAMER MIDDLE SCHOOL	WS- 004432	8/22/2016	1	Cooler	In hallway adjacent to room 128	Low Right	FT-82016-004432-A	< 1	FT-82016-004432-B	< 1
15	KRAMER MIDDLE SCHOOL	WS- 004433	8/22/2016	2	Cooler	In hallway adjacent to room 200	High Left	FT-82016-004433-A	< 1	FT-82016-004433-B	< 1
16	KRAMER MIDDLE SCHOOL	WS- 004434	8/22/2016	2	Cooler	In hallway adjacent to room 200	Low Right	FT-82016-004434-A	< 1	FT-82016-004434-B	< 1
17	KRAMER MIDDLE SCHOOL	WS- 004436	8/22/2016	2	Cooler	In hallway adjacent to room 204	High Left	FT-82016-004436-A	< 1	FT-82016-004436-B	< 1
18	KRAMER MIDDLE SCHOOL	WS- 004437	8/22/2016	2	Cooler	In hallway adjacent to room 204	Low Right	FT-82016-004437-A	< 1	FT-82016-004437-B	< 1
19	KRAMER MIDDLE SCHOOL	WS- 004439	8/22/2016	2	Cooler	In hallway adjacent to room 211	High Left	FT-82016-004439-A	< 1	FT-82016-004439-B	< 1
20	KRAMER MIDDLE SCHOOL	WS- 004440	8/22/2016	2	Cooler	In hallway adjacent to room 211	Low Right	FT-82016-004440-A	< 1	FT-82016-004440-B	< 1
21	KRAMER MIDDLE SCHOOL	WS- 008988	8/22/2016	3	Cooler	In hallway adjacent to room 300	High Left	FT-82016-008988-A	< 1	FT-82016-008988-B	< 1
22	KRAMER MIDDLE SCHOOL	WS- 008989	8/22/2016	3	Cooler	In hallway adjacent to room 300	Low Right	FT-82016-008989-A	< 1	FT-82016-008989-B	< 1
23	KRAMER MIDDLE SCHOOL	WS- 008990	8/22/2016	3	Cooler	In hallway adjacent to room 306	High Left	FT-82016-008990-A	< 1	FT-82016-008990-B	< 1
24	KRAMER MIDDLE SCHOOL	WS- 008991	8/22/2016	3	Cooler	In hallway adjacent to room 306	Low Right	FT-82016-008991-A	< 1	FT-82016-008991-B	< 1
25	KRAMER MIDDLE SCHOOL	WS- 008999	8/22/2016	3	Cooler	In hallway across from room 311	High Left	FT-82016-008999-A	< 1	FT-82016-008999-B	< 1
26	KRAMER MIDDLE SCHOOL	WS- 009000	8/22/2016	3	Cooler	In hallway across from room 311	Low Right	FT-82016-009000-A	< 1	FT-82016-009000-B	< 1