



Kramer Middle School Lead in Water Test Results

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004414	2/27/2024	2/27/2025	Basement	Cooler	In hallway adjacent to room 003 High Left	WF-02272024-004414	2/6/2025	FT-FY25-12262024-004414-A	<2	FT-FY25-12262024-004414-B	<2
WS- 004415	2/27/2024	2/27/2025	Basement	Cooler	In hallway adjacent to room 003 Low Right	WF-02272024-004415	2/6/2025	FT-FY25-12262024-004415-A	<2	FT-FY25-12262024-004415-B	<2
WS- 004426	2/27/2024	2/27/2025	1	Cooler	In hallway adjacent to room 104 High Left	WF-02272024-004426	2/6/2025	FT-FY25-12262024-004426-A	<2	FT-FY25-12262024-004426-B	<2
WS- 004427	2/27/2024	2/27/2025	1	Cooler	In hallway adjacent to room 104 Low Right	WF-02272024-004427	2/6/2025	FT-FY25-12262024-004427-A	<2	FT-FY25-12262024-004427-B	<2
WS- 004428	2/27/2024	2/27/2025	1	Health Suite	In health suite in treatment room 110A	WF-02272024-004428	2/6/2025	FT-FY25-12262024-004428-A	<2	FT-FY25-12262024-004428-B	<2
WS- 004429	2/27/2024	2/27/2025	1	Cooler	In hallway across from room 117 High Left	WF-02272024-004429	2/6/2025	FT-FY25-12262024-004429-A	<2	FT-FY25-12262024-004429-B	<2
WS- 004430	2/27/2024	2/27/2025	1	Cooler	In hallway across from room 117 Low Right	WF-02272024-004430	2/6/2025	FT-FY25-12262024-004430-A	<2	FT-FY25-12262024-004430-B	<2
WS- 004431	2/27/2024	2/27/2025	1	Cooler	In hallway adjacent to room 128 High Left	WF-02272024-004431	2/6/2025	FT-FY25-12262024-004431-A	<2	FT-FY25-12262024-004431-B	<2
WS- 004432	2/27/2024	2/27/2025	1	Cooler	In hallway adjacent to room 128 Low Right	WF-02272024-004432	2/6/2025	FT-FY25-12262024-004432-A	<2	FT-FY25-12262024-004432-B	<2
WS- 004433	2/27/2024	2/27/2025	2	Cooler	In hallway adjacent to room 200 High Left	WF-02272024-004433	2/6/2025	FT-FY25-12262024-004433-A	<2	FT-FY25-12262024-004433-B	<2
WS- 004434	2/27/2024	2/27/2025	2	Cooler	In hallway adjacent to room 200 Low Right	WF-02272024-004434	2/6/2025	FT-FY25-12262024-004434-A	<2	FT-FY25-12262024-004434-B	<2
WS- 004439	2/27/2024	2/27/2025	2	Cooler	In hallway adjacent to room 211 High Left	WF-02272024-004439	2/6/2025	FT-FY25-12262024-004439-A	<2	FT-FY25-12262024-004439-B	<2
WS- 004440	2/27/2024	2/27/2025	2	Cooler	In hallway adjacent to room 211 Low Right	WF-02272024-004440	2/6/2025	FT-FY25-12262024-004440-A	<2	FT-FY25-12262024-004440-B	<2
WS- 008987	2/27/2024	2/27/2025	2	Break Room	In staff lounge 218	WF-02272024-008987	2/6/2025	FT-FY25-12262024-008987-A	<2	FT-FY25-12262024-008987-B	<2
WS- 008988	2/27/2024	2/27/2025	3	Cooler	In hallway adjacent to room 300 High Left	WF-02272024-008988	2/6/2025	FT-FY25-12262024-008988-A	<2	FT-FY25-12262024-008988-B	<2
WS- 008989	2/27/2024	2/27/2025	3	Cooler	In hallway adjacent to room 300 Low Right	WF-02272024-008989	2/6/2025	FT-FY25-12262024-008989-A	<2	FT-FY25-12262024-008989-B	<2
WS- 008990	2/27/2024	2/27/2025	3	Cooler	In hallway adjacent to room 306 High Left	WF-02272024-008990	2/6/2025	FT-FY25-12262024-008990-A	<2	FT-FY25-12262024-008990-B	<2
WS- 008991	2/27/2024	2/27/2025	3	Cooler	In hallway adjacent to room 306 Low Right	WF-02272024-008991	2/6/2025	FT-FY25-12262024-008991-A	<2	FT-FY25-12262024-008991-B	<2
WS- 009001	2/27/2024	2/27/2025	3	Break Room	In break room 316	WF-02272024-009001	2/6/2025	FT-FY25-12262024-009001-A	<2	FT-FY25-12262024-009001-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004418	12/10/2024	12/10/2025	Basement	Food Prep Sink	In kitchen first clockwise from entry door	WF-12102024-004418	2/6/2025	FT-FY25-12262024-004418-A	<2	FT-FY25-12262024-004418-B	<2
WS- 004419	12/10/2024	12/10/2025	Basement	Food Prep Sink	In kitchen second clockwise from entry door	WF-12102024-004419	2/6/2025	FT-FY25-12262024-004419-A	<2	FT-FY25-12262024-004419-B	<2
WS- 004420	12/10/2024	12/10/2025	Basement	Food Prep Sink	In kitchen third clockwise from entry door	WF-12102024-004420	2/6/2025	FT-FY25-12262024-004420-A	<2	FT-FY25-12262024-004420-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.