



Kramer Middle School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-004416	3/16/2021	3/16/2022	Basement	Cooler	In hallway adjacent to cafeteria	High Left	WF-03162021-004416	3/15/2022	FT-FY22-02092022-004416-A	<1	FT-FY22-02092022-004416-B	<1
WS-004417	3/16/2021	3/16/2022	Basement	Cooler	In hallway adjacent to cafeteria	Low Right	WF-03162021-004417	3/15/2022	FT-FY22-02092022-004417-A	<1	FT-FY22-02092022-004417-B	<1
WS-004422	3/16/2021	3/16/2022	Basement	Cooler	In hallway adjacent to room 019	High Left	WF-03162021-004422	3/15/2022	FT-FY22-02092022-004422-A	<1	FT-FY22-02092022-004422-B	<1
WS-004425	3/16/2021	3/16/2022	Basement	Cooler	In hallway adjacent to room 019	Low Right	WF-03162021-004425	3/15/2022	FT-FY22-02092022-004425-A	<1	FT-FY22-02092022-004425-B	<1
WS-004426	3/16/2021	3/16/2022	1	Cooler	In hallway adjacent to room 104	High Left	WF-03162021-004426	3/15/2022	FT-FY22-02092022-004426-A	<1	FT-FY22-02092022-004426-B	<1
WS-004427	3/16/2021	3/16/2022	1	Cooler	In hallway adjacent to room 104	Low Right	WF-03162021-004427	3/15/2022	FT-FY22-02092022-004427-A	<1	FT-FY22-02092022-004427-B	<1
WS-004428	3/16/2021	3/16/2022	1	Health Suite	In health suite in treatment room 110A		WF-03162021-004428	3/15/2022	FT-FY22-02092022-004428-A	<1	FT-FY22-02092022-004428-B	<1
WS-004431	3/16/2021	3/16/2022	1	Cooler	In hallway adjacent to room 128	High Left	WF-03162021-004431	3/15/2022	FT-FY22-02092022-004431-A	<1	FT-FY22-02092022-004431-B	<1
WS-004432	3/16/2021	3/16/2022	1	Cooler	In hallway adjacent to room 128	Low Right	WF-03162021-004432	3/15/2022	FT-FY22-02092022-004432-A	<1	FT-FY22-02092022-004432-B	<1
WS-004433	3/16/2021	3/16/2022	2	Cooler	In hallway adjacent to room 200	High Left	WF-03162021-004433	3/15/2022	FT-FY22-02092022-004433-A	<1	FT-FY22-02092022-004433-B	<1
WS-004436	3/16/2021	3/16/2022	2	Cooler	In hallway adjacent to room 204	High Left	WF-03162021-004436	3/15/2022	FT-FY22-02092022-004436-A	<1	FT-FY22-02092022-004436-B	<1
WS-004437	3/16/2021	3/16/2022	2	Cooler	In hallway adjacent to room 204	Low Right	WF-03162021-004437	3/15/2022	FT-FY22-02092022-004437-A	<1	FT-FY22-02092022-004437-B	<1
WS-004439	3/16/2021	3/16/2022	2	Cooler	In hallway adjacent to room 211	High Left	WF-03162021-004439	3/15/2022	FT-FY22-02092022-004439-A	<1	FT-FY22-02092022-004439-B	<1
WS-004440	3/16/2021	3/16/2022	2	Cooler	In hallway adjacent to room 211	Low Right	WF-03162021-004440	3/15/2022	FT-FY22-02092022-004440-A	<1	FT-FY22-02092022-004440-B	<1
WS-008987	3/16/2021	3/16/2022	2	Break Room	In staff lounge 218		WF-03162021-008987	3/15/2022	FT-FY22-02092022-008987-A	<1	FT-FY22-02092022-008987-B	<1
WS-008988	3/16/2021	3/16/2022	3	Cooler	In hallway adjacent to room 300	High Left	WF-03162021-008988	3/15/2022	FT-FY22-02092022-008988-A	<1	FT-FY22-02092022-008988-B	<1
WS-008989	3/16/2021	3/16/2022	3	Cooler	In hallway adjacent to room 300	Low Right	WF-03162021-008989	3/15/2022	FT-FY22-02092022-008989-A	<1	FT-FY22-02092022-008989-B	<1
WS-008990	3/16/2021	3/16/2022	3	Cooler	In hallway adjacent to room 306	High Left	WF-03162021-008990	3/15/2022	FT-FY22-02092022-008990-A	<1	FT-FY22-02092022-008990-B	<1
WS-008991	3/16/2021	3/16/2022	3	Cooler	In hallway adjacent to room 306	Low Right	WF-03162021-008991	3/15/2022	FT-FY22-02092022-008991-A	<1	FT-FY22-02092022-008991-B	<1
WS-008999	3/16/2021	3/16/2022	3	Cooler	In hallway across from room 311	High Left	WF-03162021-008999	3/15/2022	FT-FY22-02092022-008999-A	<1	FT-FY22-02092022-008999-B	<1
WS-009001	3/16/2021	3/16/2022	3	Break Room	In break room 316		WF-03162021-009001	3/15/2022	FT-FY22-02092022-009001-A	<1	FT-FY22-02092022-009001-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-004418	2/9/2022	2/9/2023	Basement	Food Prep Sink	In kitchen first clockwise from entry door		WF-02092022-004418	3/15/2022	FT-FY22-02092022-004418-A	<1	FT-FY22-02092022-004418-B	<1
WS-004419	2/9/2022	2/9/2023	Basement	Food Prep Sink	In kitchen second clockwise from entry door		WF-02092022-004419	3/15/2022	FT-FY22-02092022-004419-A	<1	FT-FY22-02092022-004419-B	<1
WS-004420	2/9/2022	2/9/2023	Basement	Food Prep Sink	In kitchen third clockwise from entry door		WF-02092022-004420	3/15/2022	FT-FY22-02092022-004420-A	<1	FT-FY22-02092022-004420-B	<1