



# Kramer Middle School Lead Water Test Results



## FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation													
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location			WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004414	5/25/17	5/25/18	Basement	Cooler	In hallway adjacent to room 003	Left	High	WF-52017-004414	12/13/17	FT-FY18--52017-004414-A	<1	FT-FY18--52017-004414-B	<1
WS- 004415	5/25/17	5/25/18	Basement	Cooler	In hallway adjacent to room 003	Right	Low	WF-52017-004415	12/13/17	FT-FY18--52017-004415-A	<1	FT-FY18--52017-004415-B	<1
WS- 004422	5/25/17	5/25/18	Basement	Cooler	In hallway adjacent to room 019	Left	High	WF-52017-004422	12/13/17	FT-FY18--52017-004422-A	<1	FT-FY18--52017-004422-B	<1
WS- 004428	5/25/17	5/25/18	1	Health Suite	In health suite in treatment room 110A			WF-52017-004428	12/13/17	FT-FY18--52017-004428-A	<1	FT-FY18--52017-004428-B	<1
WS- 004430	5/25/17	5/25/18	1	Cooler	In hallway across from room 117	Right	Low	WF-52017-004430	12/13/17	FT-FY18--52017-004430-A	<1	FT-FY18--52017-004430-B	<1
WS- 004434	5/25/17	5/25/18	2	Cooler	In hallway adjacent to room 200	Right	Low	WF-52017-004434	12/13/17	FT-FY18--52017-004434-A	<1	FT-FY18--52017-004434-B	<1
WS- 008990	5/25/17	5/25/18	3	Cooler	In hallway adjacent to room 306	Left	High	WF-52017-008990	12/13/17	FT-FY18--52017-008990-A	<1	FT-FY18--52017-008990-B	<1
WS- 008991	5/25/17	5/25/18	3	Cooler	In hallway adjacent to room 306	Right	Low	WF-52017-008991	12/13/17	FT-FY18--52017-008991-A	<1	FT-FY18--52017-008991-B	<1
WS- 009000	5/25/17	5/25/18	3	Cooler	In hallway across from room 311	Right	Low	WF-52017-009000	12/13/17	FT-FY18--52017-009000-A	<1	FT-FY18--52017-009000-B	<1

## Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation										
RECORD ID	Floor	Device Type	Device Location			Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004418	Basement	Food Prep Sink	In kitchen first clockwise from entry door			12/13/17	FT-FY18-102017-004418-A	<1	FT-FY18-102017-004418-B	<1