



LaCasa TRP Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005672	4/18/2022	4/18/2023	2	Cooler	In hallway adjacent to room 204	WF-04182022-005672	2/9/2023	FT-FY23-01192023-005672-A	<1	FT-FY23-01192023-005672-B	<1
WS- 005673	4/18/2022	4/18/2023	3	Cooler	In hallway adjacent to room 308	WF-04182022-005673	2/9/2023	FT-FY23-01192023-005673-A	<1	FT-FY23-01192023-005673-B	<1