



LaSalle Backus Education Campus Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 000550	4/14/2021	4/14/2022	Basement	Cooler	In cafeteria High Left	WF-04142021-000550	12/19/2021	FT-FY22-12012021-000550-A	<1	FT-FY22-12012021-000550-B	<1	
WS- 000551	4/14/2021	4/14/2022	Basement	Cooler	In cafeteria Low Right	WF-04142021-000551	12/19/2021	FT-FY22-12012021-000551-A	<1	FT-FY22-12012021-000551-B	<1	
WS- 000552	4/14/2021	4/14/2022	1	Cooler	In hallway adjacent to classroom 110 High Left	WF-04142021-000552	12/19/2021	FT-FY22-12012021-000552-A	<1	FT-FY22-12012021-000552-B	<1	
WS- 000556	4/14/2021	4/14/2022	1	Bottle Filler	In hallway adjacent to principal's office 113	WF-04142021-000556	12/19/2021	FT-FY22-12012021-000556-A	<1	FT-FY22-12012021-000556-B	<1	
WS- 000557	4/14/2021	4/14/2022	1	Cooler	In hallway adjacent to principal's office 113 Low Left	WF-04142021-000557	12/19/2021	FT-FY22-12012021-000557-A	<1	FT-FY22-12012021-000557-B	<1	
WS- 000558	4/14/2021	4/14/2022	1	Cooler	In hallway adjacent to principal's office 113 High Right	WF-04142021-000558	12/19/2021	FT-FY22-12012021-000558-A	<1	FT-FY22-12012021-000558-B	<1	
WS- 000562	4/14/2021	4/14/2022	2	Cooler	In hallway adjacent to storage room 202 High Left	WF-04142021-000562	12/19/2021	FT-FY22-12012021-000562-A	<1	FT-FY22-12012021-000562-B	<1	
WS- 000563	4/14/2021	4/14/2022	2	Cooler	In hallway adjacent to storage room 202 Low Right	WF-04142021-000563	12/19/2021	FT-FY22-12012021-000563-A	<1	FT-FY22-12012021-000563-B	<1	
WS- 000564	4/14/2021	4/14/2022	3	Cooler	In hallway adjacent to classroom 308 High Left	WF-04142021-000564	12/19/2021	FT-FY22-12012021-000564-A	<1	FT-FY22-12012021-000564-B	<1	
WS- 000565	4/14/2021	4/14/2022	3	Cooler	In hallway adjacent to classroom 308 Low Right	WF-04142021-000565	12/19/2021	FT-FY22-12012021-000565-A	<1	FT-FY22-12012021-000565-B	<1	
WS- 000580	4/14/2021	4/14/2022	Ground Floor	Cooler	In hallway adjacent to custodians office G008 High Left	WF-04142021-000580	12/19/2021	FT-FY22-12012021-000580-A	<1	FT-FY22-12012021-000580-B	<1	
WS- 000581	4/14/2021	4/14/2022	Ground Floor	Cooler	In hallway adjacent to custodians office G008 Low Right	WF-04142021-000581	12/19/2021	FT-FY22-12012021-000581-A	<1	FT-FY22-12012021-000581-B	<1	
WS- 010259	4/14/2021	4/14/2022	Ground Floor	Combo Fountain	In classroom G011	WF-04142021-010259	12/19/2021	FT-FY22-12012021-010259-A	<1	FT-FY22-12012021-010259-B	<1	
WS- 010260	9/28/2021	9/28/2022	Ground Floor	Combo Faucet	In classroom G011	WF-09282021-010260	12/19/2021	FT-FY22-12012021-010260-A	<1	FT-FY22-12012021-010260-B	<1	
WS- 010261	4/14/2021	4/14/2022	Ground Floor	Combo Fountain	In classroom G010	WF-04142021-010261	12/19/2021	FT-FY22-12012021-010261-A	<1	FT-FY22-12012021-010261-B	<1	
WS- 010262	9/28/2021	9/28/2022	Ground Floor	Combo Faucet	In classroom G010	WF-09282021-010262	12/19/2021	FT-FY22-12012021-010262-A	<1	FT-FY22-12012021-010262-B	<1	
WS- 010263	9/28/2021	9/28/2022	Ground Floor	Combo Faucet	In classroom G009	WF-09282021-010263	12/19/2021	FT-FY22-12012021-010263-A	<1	FT-FY22-12012021-010263-B	<1	
WS- 010264	4/14/2021	4/14/2022	Ground Floor	Combo Fountain	In classroom G009	WF-04142021-010264	12/19/2021	FT-FY22-12012021-010264-A	<1	FT-FY22-12012021-010264-B	<1	
WS- 010265	9/28/2021	9/28/2022	Ground Floor	Combo Faucet	In classroom G007	WF-09282021-010265	12/19/2021	FT-FY22-12012021-010265-A	<1	FT-FY22-12012021-010265-B	<1	
WS- 010266	4/14/2021	4/14/2022	Ground Floor	Combo Fountain	In classroom G007	WF-04142021-010266	12/19/2021	FT-FY22-12012021-010266-A	<1	FT-FY22-12012021-010266-B	<1	
WS- 010267	9/28/2021	9/28/2022	Ground Floor	Combo Faucet	In classroom G005	WF-09282021-010267	12/19/2021	FT-FY22-12012021-010267-A	<1	FT-FY22-12012021-010267-B	<1	
WS- 010268	4/14/2021	4/14/2022	Ground Floor	Combo Fountain	In classroom G005	WF-04142021-010268	12/19/2021	FT-FY22-12012021-010268-A	<1	FT-FY22-12012021-010268-B	<1	
WS- 010272	4/14/2021	4/14/2022	1	Cooler	In health suite	WF-04142021-010272	12/19/2021	FT-FY22-12012021-010272-A	<1	FT-FY22-12012021-010272-B	<1	
WS- 010279	4/14/2021	4/14/2022	2	Break Room	In staff lounge	WF-04142021-010279	12/19/2021	FT-FY22-12012021-010279-A	<1	FT-FY22-12012021-010279-B	<1	

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 010269	1/7/2021	1/7/2022	Ground Floor	Food Prep Sink	In kitchen	WF-01072021-010269	12/19/2021	FT-FY22-12012021-010269-A	<1	FT-FY22-12012021-010269-B	<1	