



LaSalle-Backus Education Campus Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation													
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 000550	4/7/2022	4/7/2023	Basement	Cooler	In cafeteria	High Left	WF-04072022-000550	1/9/2023	FT-FY23-11182022-000550-A	<1	FT-FY23-11182022-000550-B	<1	
WS- 000551	4/7/2022	4/7/2023	Basement	Cooler	In cafeteria	Low Right	WF-04072022-000551	1/9/2023	FT-FY23-11182022-000551-A	<1	FT-FY23-11182022-000551-B	<1	
WS- 000552	4/7/2022	4/7/2023	1	Cooler	In hallway adjacent to classroom 110	High Left	WF-04072022-000552	1/9/2023	FT-FY23-11182022-000552-A	<1	FT-FY23-11182022-000552-B	<1	
WS- 000554	3/31/2022	3/31/2023	1	Cooler	In hallway adjacent to storage room 104	Low Left	WF-03312022-000554	1/9/2023	FT-FY23-11182022-000554-A	<1	FT-FY23-11182022-000554-B	<1	
WS- 000555	3/31/2022	3/31/2023	1	Cooler	In hallway adjacent to storage room 104	High Right	WF-03312022-000555	1/9/2023	FT-FY23-11182022-000555-A	<1	FT-FY23-11182022-000555-B	<1	
WS- 000556	4/7/2022	4/7/2023	1	Bottle Filler	In hallway adjacent to principal's office 113		WF-04072022-000556	1/9/2023	FT-FY23-11182022-000556-A	<1	FT-FY23-11182022-000556-B	<1	
WS- 000557	4/7/2022	4/7/2023	1	Cooler	In hallway adjacent to principal's office 113	Low Left	WF-04072022-000557	1/9/2023	FT-FY23-11182022-000557-A	<1	FT-FY23-11182022-000557-B	<1	
WS- 000558	4/7/2022	4/7/2023	1	Cooler	In hallway adjacent to principal's office 113	High Right	WF-04072022-000558	1/9/2023	FT-FY23-11182022-000558-A	<1	FT-FY23-11182022-000558-B	<1	
WS- 000559	4/7/2022	4/7/2023	1	Bottle Filler	In hallway across from multipurpose room 122		WF-04072022-000559	1/9/2023	FT-FY23-11182022-000559-A	<1	FT-FY23-11182022-000559-B	<1	
WS- 000560	4/7/2022	4/7/2023	1	Cooler	In hallway across from multipurpose room 122	High Left	WF-04072022-000560	1/9/2023	FT-FY23-11182022-000560-A	<1	FT-FY23-11182022-000560-B	<1	
WS- 000561	4/7/2022	4/7/2023	1	Cooler	In hallway across from multipurpose room 122	Low Right	WF-04072022-000561	1/9/2023	FT-FY23-11182022-000561-A	<1	FT-FY23-11182022-000561-B	<1	
WS- 000562	3/31/2022	3/31/2023	2	Cooler	In hallway adjacent to storage room 202	High Left	WF-03312022-000562	1/9/2023	FT-FY23-11182022-000562-A	<1	FT-FY23-11182022-000562-B	<1	
WS- 000563	3/31/2022	3/31/2023	2	Cooler	In hallway adjacent to storage room 202	Low Right	WF-03312022-000563	1/9/2023	FT-FY23-11182022-000563-A	<1	FT-FY23-11182022-000563-B	<1	
WS- 000564	4/7/2022	4/7/2023	3	Cooler	In hallway adjacent to classroom 308	High Left	WF-04072022-000564	1/9/2023	FT-FY23-11182022-000564-A	<1	FT-FY23-11182022-000564-B	<1	
WS- 000565	4/7/2022	4/7/2023	3	Cooler	In hallway adjacent to classroom 308	Low Right	WF-04072022-000565	1/9/2023	FT-FY23-11182022-000565-A	<1	FT-FY23-11182022-000565-B	<1	
WS- 000580	3/31/2022	3/31/2023	Ground Floor	Cooler	In hallway adjacent to custodians office G008	High Left	WF-03312022-000580	1/9/2023	FT-FY23-11182022-000580-A	<1	FT-FY23-11182022-000580-B	<1	
WS- 000581	3/31/2022	3/31/2023	Ground Floor	Cooler	In hallway adjacent to custodians office G008	Low Right	WF-03312022-000581	1/9/2023	FT-FY23-11182022-000581-A	<1	FT-FY23-11182022-000581-B	<1	
WS- 010259	4/7/2022	4/7/2023	Ground Floor	Combo Fountain	In classroom G011		WF-04072022-010259	1/9/2023	FT-FY23-11182022-010259-A	<1	FT-FY23-11182022-010259-B	<1	
WS- 010260	9/20/2022	9/20/2023	Ground Floor	Combo Faucet	In classroom G011		WF-09202022-010260	1/9/2023	FT-FY23-11182022-010260-A	<1	FT-FY23-11182022-010260-B	<1	
WS- 010261	4/7/2022	4/7/2023	Ground Floor	Combo Fountain	In classroom G010		WF-04072022-010261	1/9/2023	FT-FY23-11182022-010261-A	<1	FT-FY23-11182022-010261-B	<1	
WS- 010262	9/20/2022	9/20/2023	Ground Floor	Combo Faucet	In classroom G010		WF-09202022-010262	1/9/2023	FT-FY23-11182022-010262-A	<1	FT-FY23-11182022-010262-B	<1	
WS- 010264	4/7/2022	4/7/2023	Ground Floor	Combo Fountain	In classroom G009		WF-04072022-010264	1/9/2023	FT-FY23-11182022-010264-A	<1	FT-FY23-11182022-010264-B	<1	
WS- 010265	9/20/2022	9/20/2023	Ground Floor	Combo Faucet	In classroom G007		WF-09202022-010265	1/9/2023	FT-FY23-11182022-010265-A	<1	FT-FY23-11182022-010265-B	<1	
WS- 010266	4/7/2022	4/7/2023	Ground Floor	Combo Fountain	In classroom G007		WF-04072022-010266	1/9/2023	FT-FY23-11182022-010266-A	<1	FT-FY23-11182022-010266-B	<1	
WS- 010268	4/7/2022	4/7/2023	Ground Floor	Combo Fountain	In classroom G005		WF-04072022-010268	1/9/2023	FT-FY23-11182022-010268-A	<1	FT-FY23-11182022-010268-B	<1	
WS- 010272	4/7/2022	4/7/2023	1	Cooler	In health suite		WF-04072022-010272	1/9/2023	FT-FY23-11182022-010272-A	<1	FT-FY23-11182022-010272-B	<1	
WS- 010279	4/7/2022	4/7/2023	2	Break Room	In staff lounge		WF-04072022-010279	1/9/2023	FT-FY23-11182022-010279-A	<1	FT-FY23-11182022-010279-B	<1	
WS- 010282	4/7/2022	4/7/2023	2	Cooler	In hallway adjacent to room 208		WF-04072022-010282	1/9/2023	FT-FY23-11182022-010282-A	<1	FT-FY23-11182022-010282-B	<1	
WS- 010292	3/31/2022	3/31/2023	3	Cooler	In hallway adjacent to custodian closet		WF-03312022-010292	1/9/2023	FT-FY23-11182022-010292-A	<1	FT-FY23-11182022-010292-B	<1	

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010269	12/29/2021	12/29/2022	Ground Floor	Food Prep Sink	In kitchen		WF-12292021-010269	1/9/2023	FT-FY23-11182022-010269-A	<1	FT-FY23-11182022-010269-B	<1

FY23 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010263	9/20/2022	9/20/2023	Ground Floor	Combo Faucet	In classroom G009	WF-09202022-010263	1/9/2023	FT-FY23-11182022-010263-A	7.9	FT-FY23-11182022-010263-B	<1