



LaSalle-Backus EC Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000550	5/21/2019	5/21/2020	Basement	Cooler	In cafeteria High Left	WF-05212019-000550	11/20/2019	FT-FY20-112019-000550-A	<1	FT-FY20-112019-000550-B	<1
WS- 000551	5/21/2019	5/21/2020	Basement	Cooler	In cafeteria Low Right	WF-05212019-000551	11/20/2019	FT-FY20-112019-000551-A	<1	FT-FY20-112019-000551-B	<1
WS- 000552	5/21/2019	5/21/2020	1	Cooler	In hallway adjacent to classroom 110 High Left	WF-05212019-000552	11/20/2019	FT-FY20-112019-000552-A	<1	FT-FY20-112019-000552-B	<1
WS- 000553	5/21/2019	5/21/2020	1	Cooler	In hallway adjacent to classroom 110 Low Right	WF-05212019-000553	11/20/2019	FT-FY20-112019-000553-A	<1	FT-FY20-112019-000553-B	<1
WS- 000554	5/21/2019	5/21/2020	1	Cooler	In hallway adjacent to storage room 104 Low Left	WF-05212019-000554	11/20/2019	FT-FY20-112019-000554-A	<1	FT-FY20-112019-000554-B	<1
WS- 000555	5/21/2019	5/21/2020	1	Cooler	In hallway adjacent to storage room 104 High Right	WF-05212019-000555	11/20/2019	FT-FY20-112019-000555-A	<1	FT-FY20-112019-000555-B	<1
WS- 000556	5/21/2019	5/21/2020	1	Bottle Filler	In hallway adjacent to principal's office 113	WF-05212019-000556	11/20/2019	FT-FY20-112019-000556-A	<1	FT-FY20-112019-000556-B	<1
WS- 000557	5/21/2019	5/21/2020	1	Cooler	In hallway adjacent to principal's office 113 Low Left	WF-05212019-000557	11/20/2019	FT-FY20-112019-000557-A	<1	FT-FY20-112019-000557-B	<1
WS- 000558	5/21/2019	5/21/2020	1	Cooler	In hallway adjacent to principal's office 113 High Right	WF-05212019-000558	11/20/2019	FT-FY20-112019-000558-A	<1	FT-FY20-112019-000558-B	<1
WS- 000562	5/21/2019	5/21/2020	2	Cooler	In hallway adjacent to storage room 202 High Left	WF-05212019-000562	11/20/2019	FT-FY20-112019-000562-A	<1	FT-FY20-112019-000562-B	<1
WS- 000563	5/21/2019	5/21/2020	2	Cooler	In hallway adjacent to storage room 202 Low Right	WF-05212019-000563	11/20/2019	FT-FY20-112019-000563-A	<1	FT-FY20-112019-000563-B	<1
WS- 000564	5/21/2019	5/21/2020	3	Cooler	In hallway adjacent to classroom 308 High Left	WF-05212019-000564	11/20/2019	FT-FY20-112019-000564-A	<1	FT-FY20-112019-000564-B	<1
WS- 000565	5/21/2019	5/21/2020	3	Cooler	In hallway adjacent to classroom 308 Low Right	WF-05212019-000565	11/20/2019	FT-FY20-112019-000565-A	<1	FT-FY20-112019-000565-B	<1
WS- 000580	5/21/2019	5/21/2020	Ground Floor	Cooler	In hallway adjacent to custodians office G008 High Left	WF-05212019-000580	11/20/2019	FT-FY20-112019-000580-A	<1	FT-FY20-112019-000580-B	<1
WS- 000581	5/21/2019	5/21/2020	Ground Floor	Cooler	In hallway adjacent to custodians office G008 Low Right	WF-05212019-000581	11/20/2019	FT-FY20-112019-000581-A	<1	FT-FY20-112019-000581-B	<1
WS- 010259	5/21/2019	5/21/2020	Ground Floor	Combo Fountain	In classroom G011	WF-05212019-010259	11/20/2019	FT-FY20-112019-010259-A	<1	FT-FY20-112019-010259-B	<1
WS- 010260	10/16/2019	10/16/2020	Ground Floor	Combo Faucet	In classroom G011	WF-10162019-010260	11/20/2019	FT-FY20-112019-010260-A	<1	FT-FY20-112019-010260-B	<1
WS- 010261	5/21/2019	5/21/2020	Ground Floor	Combo Fountain	In classroom G010	WF-05212019-010261	11/20/2019	FT-FY20-112019-010261-A	<1	FT-FY20-112019-010261-B	<1
WS- 010262	10/16/2019	10/16/2020	Ground Floor	Combo Faucet	In classroom G010	WF-10162019-010262	11/20/2019	FT-FY20-112019-010262-A	2.3	FT-FY20-112019-010262-B	<1
WS- 010263	10/16/2019	10/16/2020	Ground Floor	Combo Faucet	In classroom G009	WF-10162019-010263	11/20/2019	FT-FY20-112019-010263-A	<1	FT-FY20-112019-010263-B	<1
WS- 010264	5/21/2019	5/21/2020	Ground Floor	Combo Fountain	In classroom G009	WF-05212019-010264	11/20/2019	FT-FY20-112019-010264-A	<1	FT-FY20-112019-010264-B	<1
WS- 010265	10/16/2019	10/16/2020	Ground Floor	Combo Faucet	In classroom G007	WF-10162019-010265	11/20/2019	FT-FY20-112019-010265-A	1.8	FT-FY20-112019-010265-B	<1
WS- 010266	5/21/2019	5/21/2020	Ground Floor	Combo Fountain	In classroom G007	WF-05212019-010266	11/20/2019	FT-FY20-112019-010266-A	<1	FT-FY20-112019-010266-B	<1
WS- 010267	10/16/2019	10/16/2020	Ground Floor	Combo Faucet	In classroom G005	WF-10162019-010267	11/20/2019	FT-FY20-112019-010267-A	1.8	FT-FY20-112019-010267-B	<1
WS- 010268	5/21/2019	5/21/2020	Ground Floor	Combo Fountain	In classroom G005	WF-05212019-010268	11/20/2019	FT-FY20-112019-010268-A	<1	FT-FY20-112019-010268-B	<1
WS- 010272	5/21/2019	5/21/2020	1	Cooler	In health suite	WF-05212019-010272	11/20/2019	FT-FY20-112019-010272-A	<1	FT-FY20-112019-010272-B	<1
WS- 010279	5/21/2019	5/21/2020	2	Break Room	In staff lounge	WF-05212019-010279	11/20/2019	FT-FY20-112019-010279-A	<1	FT-FY20-112019-010279-B	<1
WS- 010292	5/21/2019	5/21/2020	3	Cooler	In hallway adjacent to custodian closet	WF-05212019-010292	11/20/2019	FT-FY20-112019-010292-A	<1	FT-FY20-112019-010292-B	<1