



LaSalle Backus Education Campus Lead in Water Test Results

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000550	3/12/2024	3/12/2025	Basement	Cooler	In cafeteria High Left	WF-03122024-000550	11/14/2024	FT-FY25-10082024-000550-A	<2	FT-FY25-10082024-000550-B	<2
WS- 000551	3/12/2024	3/12/2025	Basement	Cooler	In cafeteria Low Right	WF-03122024-000551	11/14/2024	FT-FY25-10082024-000551-A	<2	FT-FY25-10082024-000551-B	<2
WS- 000552	3/12/2024	3/12/2025	1	Cooler	In hallway adjacent to classroom 110 High Left	WF-03122024-000552	11/14/2024	FT-FY25-10082024-000552-A	<2	FT-FY25-10082024-000552-B	<2
WS- 000554	3/12/2024	3/12/2025	1	Cooler	In hallway adjacent to storage room 104 Low Left	WF-03122024-000554	11/14/2024	FT-FY25-10082024-000554-A	<2	FT-FY25-10082024-000554-B	<2
WS- 000555	3/12/2024	3/12/2025	1	Cooler	In hallway adjacent to storage room 104 High Right	WF-03122024-000555	11/14/2024	FT-FY25-10082024-000555-A	<2	FT-FY25-10082024-000555-B	<2
WS- 000556	3/12/2024	3/12/2025	1	Bottle Filler	In hallway adjacent to principal's office 113	WF-03122024-000556	11/14/2024	FT-FY25-10082024-000556-A	<2	FT-FY25-10082024-000556-B	<2
WS- 000557	3/12/2024	3/12/2025	1	Cooler	In hallway adjacent to principal's office 113 Low Left	WF-03122024-000557	11/14/2024	FT-FY25-10082024-000557-A	<2	FT-FY25-10082024-000557-B	<2
WS- 000558	3/12/2024	3/12/2025	1	Cooler	In hallway adjacent to principal's office 113 High Right	WF-03122024-000558	11/14/2024	FT-FY25-10082024-000558-A	<2	FT-FY25-10082024-000558-B	<2
WS- 000559	3/12/2024	3/12/2025	1	Bottle Filler	In hallway across from multipurpose room 122	WF-03122024-000559	11/14/2024	FT-FY25-10082024-000559-A	<2	FT-FY25-10082024-000559-B	<2
WS- 000560	3/12/2024	3/12/2025	1	Cooler	In hallway across from multipurpose room 122 High Left	WF-03122024-000560	11/14/2024	FT-FY25-10082024-000560-A	<2	FT-FY25-10082024-000560-B	<2
WS- 000561	3/12/2024	3/12/2025	1	Cooler	In hallway across from multipurpose room 122 Low Right	WF-03122024-000561	11/14/2024	FT-FY25-10082024-000561-A	<2	FT-FY25-10082024-000561-B	<2
WS- 000564	3/12/2024	3/12/2025	3	Cooler	In hallway adjacent to classroom 308 High Left	WF-03122024-000564	11/14/2024	FT-FY25-10082024-000564-A	<2	FT-FY25-10082024-000564-B	<2
WS- 000565	3/12/2024	3/12/2025	3	Cooler	In hallway adjacent to classroom 308 Low Right	WF-03122024-000565	11/14/2024	FT-FY25-10082024-000565-A	<2	FT-FY25-10082024-000565-B	<2
WS- 000580	3/12/2024	3/12/2025	Ground Floor	Cooler	In hallway adjacent to custodians office G008 High Left	WF-03122024-000580	11/14/2024	FT-FY25-10082024-000580-A	<2	FT-FY25-10082024-000580-B	<2
WS- 000581	3/12/2024	3/12/2025	Ground Floor	Cooler	In hallway adjacent to custodians office G008 Low Right	WF-03122024-000581	11/14/2024	FT-FY25-10082024-000581-A	<2	FT-FY25-10082024-000581-B	<2
WS- 010261	3/12/2024	3/12/2025	Ground Floor	Combo Fountain	In classroom G010	WF-03122024-010261	11/14/2024	FT-FY25-10082024-010261-A	<2	FT-FY25-10082024-010261-B	<2
WS- 010262	9/9/2024	9/9/2025	Ground Floor	Combo Faucet	In classroom G010	WF-09092024-010262	11/14/2024	FT-FY25-10082024-010262-A	<2	FT-FY25-10082024-010262-B	<2
WS- 010263	9/9/2024	9/9/2025	Ground Floor	Combo Faucet	In classroom G009	WF-09092024-010263	11/14/2024	FT-FY25-10082024-010263-A	<2	FT-FY25-10082024-010263-B	<2
WS- 010264	3/12/2024	3/12/2025	Ground Floor	Combo Fountain	In classroom G009	WF-03122024-010264	11/14/2024	FT-FY25-10082024-010264-A	<2	FT-FY25-10082024-010264-B	<2
WS- 010265	9/9/2024	9/9/2025	Ground Floor	Combo Faucet	In classroom G007	WF-09092024-010265	11/14/2024	FT-FY25-10082024-010265-A	<2	FT-FY25-10082024-010265-B	<2
WS- 010266	3/12/2024	3/12/2025	Ground Floor	Combo Fountain	In classroom G007	WF-03122024-010266	11/14/2024	FT-FY25-10082024-010266-A	<2	FT-FY25-10082024-010266-B	<2
WS- 010267	9/9/2024	9/9/2025	Ground Floor	Combo Faucet	In classroom G005	WF-09092024-010267	11/14/2024	FT-FY25-10082024-010267-A	<2	FT-FY25-10082024-010267-B	<2
WS- 010268	3/12/2024	3/12/2025	Ground Floor	Combo Fountain	In classroom G005	WF-03122024-010268	11/14/2024	FT-FY25-10082024-010268-A	<2	FT-FY25-10082024-010268-B	<2
WS- 010272	3/12/2024	3/12/2025	1	Cooler	In health suite	WF-03122024-010272	11/14/2024	FT-FY25-10082024-010272-A	<2	FT-FY25-10082024-010272-B	<2
WS- 010279	3/12/2024	3/12/2025	2	Break Room	In staff lounge	WF-03122024-010279	11/14/2024	FT-FY25-10082024-010279-A	<2	FT-FY25-10082024-010279-B	<2
WS- 010282	3/12/2024	3/12/2025	2	Cooler	In hallway adjacent to room 208	WF-03122024-010282	11/14/2024	FT-FY25-10082024-010282-A	<2	FT-FY25-10082024-010282-B	<2
WS- 010292	3/12/2024	3/12/2025	3	Cooler	In hallway adjacent to custodian closet	WF-03122024-010292	11/14/2024	FT-FY25-10082024-010292-A	<2	FT-FY25-10082024-010292-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010269	12/6/2023	12/6/2024	Ground Floor	Food Prep Sink	In kitchen	WF-12062023-010269	11/14/2024	FT-FY25-10082024-010269-A	<2	FT-FY25-10082024-010269-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.