



# LaSALLE BACKUS EC LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	LASALLE-BACKUS EDUCATIONAL CAMPUS	WS- 010259	8/24/2016	Ground Floor	Fountain	In classroom G011	FT-82016-010259-A	< 1	FT-82016-010259-B	< 1
2	LASALLE-BACKUS EDUCATIONAL CAMPUS	WS- 010261	8/24/2016	Ground Floor	Fountain	In classroom G010	FT-82016-010261-A	< 1	FT-82016-010261-B	< 1
3	LASALLE-BACKUS EDUCATIONAL CAMPUS	WS- 010264	8/24/2016	Ground Floor	Fountain	In classroom G009	FT-82016-010264-A	< 1	FT-82016-010264-B	< 1
4	LASALLE-BACKUS EDUCATIONAL CAMPUS	WS- 010266	8/24/2016	Ground Floor	Fountain	In classroom G007	FT-82016-010266-A	< 1	FT-82016-010266-B	< 1
5	LASALLE-BACKUS EDUCATIONAL CAMPUS	WS- 010268	8/24/2016	Ground Floor	Fountain	In classroom G005	FT-82016-010268-A	< 1	FT-82016-010268-B	< 1
6	LASALLE-BACKUS EDUCATIONAL CAMPUS	WS- 010269	8/24/2016	Ground Floor	Food Prep Sink	In kitchen	FT-82016-010269-A	< 1	FT-82016-010269-B	< 1
7	LASALLE-BACKUS EDUCATIONAL CAMPUS	WS- 010270	8/24/2016	Ground Floor	Cooler	In cafeteria	FT-82016-010270-A	< 1	FT-82016-010270-B	< 1
8	LASALLE-BACKUS EDUCATIONAL CAMPUS	WS- 010271	8/24/2016	1	Cooler	In hallway adjacent to room 120	FT-82016-010271-A	< 1	FT-82016-010271-B	< 1
9	LASALLE-BACKUS EDUCATIONAL CAMPUS	WS- 010272	8/24/2016	1	Cooler	In health suite	FT-82016-010272-A	< 1	FT-82016-010272-B	< 1
10	LASALLE-BACKUS EDUCATIONAL CAMPUS	WS- 010273	8/24/2016	1	Cooler	In hallway adjacent to room 113	FT-82016-010273-A	< 1	FT-82016-010273-B	< 1
11	LASALLE-BACKUS EDUCATIONAL CAMPUS	WS- 010274	8/24/2016	1	Cooler	In hallway adjacent to room 104	FT-82016-010274-A	< 1	FT-82016-010274-B	< 1
12	LASALLE-BACKUS EDUCATIONAL CAMPUS	WS- 010275	8/24/2016	1	Cooler	In hallway adjacent to room 110	FT-82016-010275-A	< 1	FT-82016-010275-B	< 1
13	LASALLE-BACKUS EDUCATIONAL CAMPUS	WS- 010280	8/24/2016	2	Cooler	In hallway adjacent to room 202	FT-82016-010280-A	< 1	FT-82016-010280-B	< 1
14	LASALLE-BACKUS EDUCATIONAL CAMPUS	WS- 010282	8/24/2016	2	Cooler	In hallway adjacent to room 208	FT-82016-010282-A	< 1	FT-82016-010282-B	< 1
15	LASALLE-BACKUS EDUCATIONAL CAMPUS	WS- 010283	8/24/2016	3	Cooler	In hallway adjacent to room 308	FT-82016-010283-A	< 1	FT-82016-010283-B	< 1
16	LASALLE-BACKUS EDUCATIONAL CAMPUS	WS- 010292	8/24/2016	3	Cooler	In hallway adjacent to custodian closet	FT-82016-010292-A	< 1	FT-82016-010292-B	< 1
17	LASALLE-BACKUS EDUCATIONAL CAMPUS	WS- 010318	8/24/2016	Ground Floor	Cooler	In hallway adjacent to room G008	FT-82016-010318-A	< 1	FT-82016-010318-B	< 1