



LASALLE LEAD WATER TEST RESULTS

May 16th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	LASALLE-BACKUS EDUCATIONAL CAMPUS	5/11/2016	WS- 010258	Utility	Ground Floor	In boiler room	WT-042916-10275- A	79	WT-042916-10275- B	2.2	Non-drinking water source turned off until further analysis complete			
2	LASALLE-BACKUS EDUCATIONAL CAMPUS	5/11/2016	WS- 010259	Fountain	Ground Floor	In classroom G11	WT-042916-10276- A	< 1	WT-042916-10276- B	< 1				
3	LASALLE-BACKUS EDUCATIONAL CAMPUS	5/11/2016	WS- 010260	Classroom	Ground Floor	In classroom G11	WT-042916-10277- A	< 1	WT-042916-10277- B	< 1				
4	LASALLE-BACKUS EDUCATIONAL CAMPUS	5/11/2016	WS- 010261	Fountain	Ground Floor	In classroom G 010	WT-042916-10278- A	< 1	WT-042916-10278- B	< 1				
5	LASALLE-BACKUS EDUCATIONAL CAMPUS	5/11/2016	WS- 010262	Classroom	Ground Floor	In classroom G 010	WT-042916-10279- A	< 1	WT-042916-10279- B	< 1				
6	LASALLE-BACKUS EDUCATIONAL CAMPUS	5/11/2016	WS- 010263	Classroom	Ground Floor	In classroom G009	WT-042916-10280- A	< 1	WT-042916-10280- B	< 1				
7	LASALLE-BACKUS EDUCATIONAL CAMPUS	5/11/2016	WS- 010264	Fountain	Ground Floor	In classroom G 009	WT-042916-10281- A	< 1	WT-042916-10281- B	< 1				
8	LASALLE-BACKUS EDUCATIONAL CAMPUS	5/11/2016	WS- 010265	Classroom	Ground Floor	In classroom G007	WT-042916-10282- A	11.3	WT-042916-10282- B	< 1				
9	LASALLE-BACKUS EDUCATIONAL CAMPUS	5/11/2016	WS- 010266	Fountain	Ground Floor	In classroom G 007	WT-042916-10283- A	< 1	WT-042916-10283- B	< 1				
10	LASALLE-BACKUS EDUCATIONAL CAMPUS	5/11/2016	WS- 010267	Classroom	Ground Floor	In classroom G005	WT-042916-10284- A	12.3	WT-042916-10284- B	< 1				
11	LASALLE-BACKUS EDUCATIONAL CAMPUS	5/11/2016	WS- 010268	Fountain	Ground Floor	In classroom G 005	WT-042916-10285- A	< 1	WT-042916-10285- B	< 1				
12	LASALLE-BACKUS EDUCATIONAL CAMPUS	5/11/2016	WS- 010269	Kitchen	Ground Floor	In kitchen	WT-042916-10286- A	< 1	WT-042916-10286- B	< 1				
13	LASALLE-BACKUS EDUCATIONAL CAMPUS	5/11/2016	WS- 010270	Cooler	Ground Floor	In cafeteria	WT-042916-10287- A	< 1	WT-042916-10287- B	< 1				
14	LASALLE-BACKUS EDUCATIONAL CAMPUS	5/11/2016	WS- 010271	Cooler	1	In hallway adjacent to 120	WT-042916-10288- A	< 1	WT-042916-10288- B	< 1				
15	LASALLE-BACKUS EDUCATIONAL CAMPUS	5/11/2016	WS- 010272	Cooler	1	In health suite	WT-042916-10289- A	< 1	WT-042916-10289- B	< 1				
16	LASALLE-BACKUS EDUCATIONAL CAMPUS	5/11/2016	WS- 010273	Cooler	1	In hallway adjacent to room 113	WT-042916-10290- A	< 1	WT-042916-10290- B	< 1				
17	LASALLE-BACKUS EDUCATIONAL CAMPUS	5/11/2016	WS- 010274	Cooler	1	In hallway adjacent to 104	WT-042916-10291- A	< 1	WT-042916-10291- B	< 1				
18	LASALLE-BACKUS EDUCATIONAL CAMPUS	5/11/2016	WS- 010275	Cooler	1	In hallway adjacent to room 110	WT-042916-10292- A	< 1	WT-042916-10292- B	< 1				
19	LASALLE-BACKUS EDUCATIONAL CAMPUS	5/11/2016	WS- 010276	Classroom	1	In classroom 109 Left	WT-042916-10293- A	< 1	WT-042916-10293- B	< 1				
20	LASALLE-BACKUS EDUCATIONAL CAMPUS	5/11/2016	WS- 010277	Classroom	1	In classroom 109 Mid	WT-042916-10294- A	1.8	WT-042916-10294- B	< 1				
21	LASALLE-BACKUS EDUCATIONAL CAMPUS	5/11/2016	WS- 010278	Classroom	1	In classroom 109 Right	WT-042916-10295- A	< 1	WT-042916-10295- B	< 1				
22	LASALLE-BACKUS EDUCATIONAL CAMPUS	5/11/2016	WS- 010279	Classroom	2	In teachers lounge	WT-042916-10296- A	1.2	WT-042916-10296- B	< 1				
23	LASALLE-BACKUS EDUCATIONAL CAMPUS	5/11/2016	WS- 010280	Cooler	2	In hallway adjacent to 202	WT-042916-10297- A	< 1	WT-042916-10297- B	< 1				
24	LASALLE-BACKUS EDUCATIONAL CAMPUS	5/11/2016	WS- 010281	Classroom	2	In classroom 207	WT-042916-10298- A	33.7	WT-042916-10298- B	< 1	Filter will be installed and then retested			
25	LASALLE-BACKUS EDUCATIONAL CAMPUS	5/11/2016	WS- 010282	Cooler	2	In hallway adjacent to 208	WT-042916-10299- A	2.9	WT-042916-10299- B	< 1				
26	LASALLE-BACKUS EDUCATIONAL CAMPUS	5/11/2016	WS- 010283	Cooler	3	In hallway adjacent to 308	WT-042916-10300- A	< 1	WT-042916-10300- B	< 1				
27	LASALLE-BACKUS EDUCATIONAL CAMPUS	5/11/2016	WS- 010284	Classroom	3	In classroom 309 Left	WT-042916-10301- A	< 1	WT-042916-10301- B	1.7				
28	LASALLE-BACKUS EDUCATIONAL CAMPUS	5/11/2016	WS- 010285	Classroom	3	In classroom 309 Mid 01 Mid	WT-042916-10302- A	4.9	WT-042916-10302- B	1.3	Filter will be installed and then retested			
29	LASALLE-BACKUS EDUCATIONAL CAMPUS	5/11/2016	WS- 010286	Classroom	3	In classroom 309 mid 2 Mid	WT-042916-10303- A	72.5	WT-042916-10303- B	1.2	Filter will be installed and then retested			
30	LASALLE-BACKUS EDUCATIONAL CAMPUS	5/11/2016	WS- 010287	Classroom	3	In classroom 309 Right	WT-042916-10304- A	23.2	WT-042916-10304- B	1.1	Filter will be installed and then retested			
31	LASALLE-BACKUS EDUCATIONAL CAMPUS	5/11/2016	WS- 010288	Classroom	3	In classroom 307 Left	WT-042916-10305- A	2.8	WT-042916-10305- B	< 1				
32	LASALLE-BACKUS EDUCATIONAL CAMPUS	5/11/2016	WS- 010289	Classroom	3	In classroom 307 mid left Mid	WT-042916-10306- A	21.6	WT-042916-10306- B	< 1	Filter will be installed and then retested			
33	LASALLE-BACKUS EDUCATIONAL CAMPUS	5/11/2016	WS- 010290	Classroom	3	In classroom 307 mid right Mid	WT-042916-10307- A	6.1	WT-042916-10307- B	< 1	Filter will be installed and then retested			
34	LASALLE-BACKUS EDUCATIONAL CAMPUS	5/11/2016	WS- 010291	Classroom	3	In classroom 307 Right	WT-042916-10308- A	112	WT-042916-10308- B	1.8	Filter will be installed and then retested			



LASALLE LEAD WATER TEST RESULTS

May 16th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
35	LASALLE-BACKUS EDUCATIONAL CAMPUS	5/11/2016	WS- 010292	Cooler	3	In hallway adjacent to custodian closet	WT-042916-10309- A	< 1	WT-042916-10309- B	< 1				
36	LASALLE-BACKUS EDUCATIONAL CAMPUS	5/11/2016	WS- 010318	Cooler	Ground Floor	In hallway adjacent to room G008	WT-042916-10335- A	< 1	WT-042916-10335- B	< 1				

Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.