



LaSalle-Backus EC Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010261	6/20/2017	6/20/2018	Ground Floor	Combo Fountain	In classroom G010	WF-62017-010261	11/30/2017	FT-FY18--62017-010261-A	<1	FT-FY18--62017-010261-B	<1
WS- 010262	11/15/2017	11/15/2018	Ground Floor	Combo Faucet	In classroom G010	WF-112017-010262	11/30/2017	FT-FY18-112017-010262-A	<1	FT-FY18-112017-010262-B	<1
WS- 010263	11/15/2017	11/15/2018	Ground Floor	Combo Faucet	In classroom G009	WF-112017-010263	11/30/2017	FT-FY18-112017-010263-A	<1	FT-FY18-112017-010263-B	<1
WS- 010267	11/15/2017	11/15/2018	Ground Floor	Combo Faucet	In classroom G005	WF-112017-010267	11/30/2017	FT-FY18-112017-010267-A	<1	FT-FY18-112017-010267-B	<1
WS- 010268	6/20/2017	6/20/2018	Ground Floor	Combo Fountain	In classroom G005	WF-62017-010268	11/30/2017	FT-FY18--62017-010268-A	<1	FT-FY18--62017-010268-B	<1
WS- 010274	6/20/2017	6/20/2018	1	Cooler	In hallway adjacent to room 104	WF-62017-010274	11/30/2017	FT-FY18--62017-010274-A	<1	FT-FY18--62017-010274-B	<1
WS- 010283	6/20/2017	6/20/2018	3	Cooler	In hallway adjacent to room 308	WF-62017-010283	11/30/2017	FT-FY18--62017-010283-A	<1	FT-FY18--62017-010283-B	<1

Greater than 5 ppb - Devices Requiring Remediation											
WS- 010279	6/20/2017	6/20/2018	2	Break Room	In staff lounge	WF-62017-010279	11/30/2017	FT-FY18--62017-010279-A	51	FT-FY18--62017-010279-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)			
WS- 010269	Ground Floor	Food Prep Sink	In kitchen	11/30/2017	FT-FY18-102017-010269-A	<1	FT-FY18-102017-010269-B	<1			