



## LACASA THERAPEUTIC PROGRAM LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	LACASA THEROUUTIC PROGRAM	WS- 005672	9/22/2016	2	Cooler	In hallway adjacent to room 204	FT-82016-005672-A	< 1	FT-82016-005672-B	< 1
2	LACASA THEROUUTIC PROGRAM	WS- 005673	9/22/2016	3	Cooler	In hallway adjacent to room 308	FT-82016-005673-A	< 1	FT-82016-005673-B	< 1
3	LACASA THEROUUTIC PROGRAM	WS- 005675	9/22/2016	2	Food Prep Sink	In kitchen	FT-82016-005675-A	< 1	FT-82016-005675-B	< 1