



Lafayette Elementary School Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 003475	5/6/2020	5/6/2021	2	Combo Fountain	In classroom 220	WF-05062020-003475	3/21/2021	FT-FY21-032021-003475-A	<1	FT-FY21-032021-003475-B	<1	
WS- 003476	5/6/2020	5/6/2021	2	Combo Fountain	In classroom 222	WF-05062020-003476	3/21/2021	FT-FY21-032021-003476-A	<1	FT-FY21-032021-003476-B	<1	
WS- 003477	5/6/2020	5/6/2021	2	Combo Fountain	In classroom 224	WF-05062020-003477	3/21/2021	FT-FY21-032021-003477-A	<1	FT-FY21-032021-003477-B	<1	
WS- 003478	5/6/2020	5/6/2021	2	Combo Fountain	In classroom 225	WF-05062020-003478	3/21/2021	FT-FY21-032021-003478-A	<1	FT-FY21-032021-003478-B	<1	
WS- 003479	5/6/2020	5/6/2021	2	Combo Fountain	In classroom 223	WF-05062020-003479	3/21/2021	FT-FY21-032021-003479-A	<1	FT-FY21-032021-003479-B	<1	
WS- 003480	5/6/2020	5/6/2021	2	Combo Fountain	In classroom 221	WF-05062020-003480	3/21/2021	FT-FY21-032021-003480-A	<1	FT-FY21-032021-003480-B	<1	
WS- 003481	5/6/2020	5/6/2021	1	Combo Fountain	In classroom 145	Right	WF-05062020-003481	3/21/2021	FT-FY21-032021-003481-A	<1	FT-FY21-032021-003481-B	<1
WS- 003482	5/6/2020	5/6/2021	1	Combo Fountain	In classroom 145	Left	WF-05062020-003482	3/21/2021	FT-FY21-032021-003482-A	<1	FT-FY21-032021-003482-B	<1
WS- 003490	9/14/2020	9/14/2021	1	Combo Faucet	In classroom 124	WF-09142020-003490	3/21/2021	FT-FY21-032021-003490-A	<1	FT-FY21-032021-003490-B	<1	
WS- 003491	9/14/2020	9/14/2021	1	Combo Faucet	In resource room 140	WF-09142020-003491	3/21/2021	FT-FY21-032021-003491-A	<1	FT-FY21-032021-003491-B	<1	
WS- 003492	9/14/2020	9/14/2021	1	Combo Faucet	In hallway adjacent to room 141	Right	WF-09142020-003492	3/21/2021	FT-FY21-032021-003492-A	<1	FT-FY21-032021-003492-B	<1
WS- 003495	9/14/2020	9/14/2021	1	Combo Faucet	In classroom 141	Left	WF-09142020-003495	3/21/2021	FT-FY21-032021-003495-A	<1	FT-FY21-032021-003495-B	<1
WS- 003496	9/14/2020	9/14/2021	1	Combo Faucet	In classroom 141	Right	WF-09142020-003496	3/21/2021	FT-FY21-032021-003496-A	<1	FT-FY21-032021-003496-B	<1
WS- 003497	9/14/2020	9/14/2021	1	Combo Faucet	In classroom 142	Left	WF-09142020-003497	3/21/2021	FT-FY21-032021-003497-A	<1	FT-FY21-032021-003497-B	<1
WS- 003498	9/14/2020	9/14/2021	1	Combo Faucet	In classroom 142	Right	WF-09142020-003498	3/21/2021	FT-FY21-032021-003498-A	<1	FT-FY21-032021-003498-B	<1
WS- 003499	9/14/2020	9/14/2021	1	Combo Faucet	In classroom 143	Left	WF-09142020-003499	3/21/2021	FT-FY21-032021-003499-A	<1	FT-FY21-032021-003499-B	<1
WS- 003500	9/14/2020	9/14/2021	1	Combo Faucet	In classroom 143	Right	WF-09142020-003500	3/21/2021	FT-FY21-032021-003500-A	1.9	FT-FY21-032021-003500-B	<1
WS- 003501	9/14/2020	9/14/2021	1	Combo Faucet	In classroom 145	Left	WF-09142020-003501	3/21/2021	FT-FY21-032021-003501-A	<1	FT-FY21-032021-003501-B	<1
WS- 003502	9/14/2020	9/14/2021	1	Combo Faucet	In classroom 145	Right	WF-09142020-003502	3/21/2021	FT-FY21-032021-003502-A	<1	FT-FY21-032021-003502-B	<1
WS- 003503	9/14/2020	9/14/2021	1	Combo Faucet	In classroom 135	Left	WF-09142020-003503	3/21/2021	FT-FY21-032021-003503-A	<1	FT-FY21-032021-003503-B	<1
WS- 003504	9/14/2020	9/14/2021	1	Combo Faucet	In classroom 135	Right	WF-09142020-003504	3/21/2021	FT-FY21-032021-003504-A	<1	FT-FY21-032021-003504-B	<1
WS- 003505	9/14/2020	9/14/2021	1	Combo Faucet	In classroom 134	Left	WF-09142020-003505	3/21/2021	FT-FY21-032021-003505-A	<1	FT-FY21-032021-003505-B	<1
WS- 003506	9/14/2020	9/14/2021	1	Combo Faucet	In classroom 134	Right	WF-09142020-003506	3/21/2021	FT-FY21-032021-003506-A	<1	FT-FY21-032021-003506-B	<1
WS- 003507	9/14/2020	9/14/2021	1	Combo Faucet	In classroom 132	Left	WF-09142020-003507	3/21/2021	FT-FY21-032021-003507-A	<1	FT-FY21-032021-003507-B	<1
WS- 003508	9/14/2020	9/14/2021	1	Combo Faucet	In classroom 132	Right	WF-09142020-003508	3/21/2021	FT-FY21-032021-003508-A	<1	FT-FY21-032021-003508-B	<1
WS- 003509	9/14/2020	9/14/2021	1	Combo Faucet	In classroom 130	Left	WF-09142020-003509	3/21/2021	FT-FY21-032021-003509-A	<1	FT-FY21-032021-003509-B	<1
WS- 003510	9/14/2020	9/14/2021	1	Combo Faucet	In classroom 130	Left	WF-09142020-003510	3/21/2021	FT-FY21-032021-003510-A	<1	FT-FY21-032021-003510-B	<1
WS- 003511	9/14/2020	9/14/2021	1	Combo Faucet	In classroom 133	Left	WF-09142020-003511	3/21/2021	FT-FY21-032021-003511-A	<1	FT-FY21-032021-003511-B	<1
WS- 003512	9/14/2020	9/14/2021	1	Combo Faucet	In classroom 133	Right	WF-09142020-003512	3/21/2021	FT-FY21-032021-003512-A	<1	FT-FY21-032021-003512-B	<1
WS- 003513	5/6/2020	5/6/2021	1	Combo Fountain	In classroom 136	Left	WF-05062020-003513	3/21/2021	FT-FY21-032021-003513-A	<1	FT-FY21-032021-003513-B	<1
WS- 003514	9/14/2020	9/14/2021	1	Combo Faucet	In classroom 136	Left	WF-09142020-003514	3/21/2021	FT-FY21-032021-003514-A	<1	FT-FY21-032021-003514-B	<1
WS- 003515	5/6/2020	5/6/2021	1	Combo Fountain	In classroom 136	Right	WF-05062020-003515	3/21/2021	FT-FY21-032021-003515-A	<1	FT-FY21-032021-003515-B	<1
WS- 003516	9/14/2020	9/14/2021	1	Combo Faucet	In classroom 136	Right	WF-09142020-003516	3/21/2021	FT-FY21-032021-003516-A	<1	FT-FY21-032021-003516-B	<1
WS- 003519	5/6/2020	5/6/2021	1	Bottle Filler	In hallway adjacent to gym room 150 (bottle filler)	WF-05062020-003519	3/21/2021	FT-FY21-032021-003519-A	<1	FT-FY21-032021-003519-B	<1	
WS- 005418	5/6/2020	5/6/2021	Basement	Bottle Filler	In multi-purpose room (bottle filler)	WF-05062020-005418	3/21/2021	FT-FY21-032021-005418-A	<1	FT-FY21-032021-005418-B	<1	

WS-005469	5/6/2020	5/6/2021	2	Combo Fountain	In classroom 232	WF-05062020-005469	3/21/2021	FT-FY21-032021-005469-A	<1	FT-FY21-032021-005469-B	<1
WS-005472	5/6/2020	5/6/2021	2	Bottle Filler	In hallway adjacent to room 209 (bottle filler)	WF-05062020-005472	3/21/2021	FT-FY21-032021-005472-A	<1	FT-FY21-032021-005472-B	<1
WS-005474	5/6/2020	5/6/2021	2	Combo Fountain	In classroom 212	WF-05062020-005474	3/21/2021	FT-FY21-032021-005474-A	<1	FT-FY21-032021-005474-B	<1
WS-005475	5/6/2020	5/6/2021	2	Combo Fountain	In classroom 214	WF-05062020-005475	3/21/2021	FT-FY21-032021-005475-A	<1	FT-FY21-032021-005475-B	<1
WS-005476	5/6/2020	5/6/2021	2	Combo Fountain	In classroom 216	WF-05062020-005476	3/21/2021	FT-FY21-032021-005476-A	<1	FT-FY21-032021-005476-B	<1
WS-005477	5/6/2020	5/6/2021	2	Combo Fountain	In classroom 215	WF-05062020-005477	3/21/2021	FT-FY21-032021-005477-A	<1	FT-FY21-032021-005477-B	<1
WS-005478	5/6/2020	5/6/2021	2	Combo Fountain	In classroom 213	WF-05062020-005478	3/21/2021	FT-FY21-032021-005478-A	<1	FT-FY21-032021-005478-B	<1
WS-005479	5/6/2020	5/6/2021	2	Combo Fountain	In classroom 211	WF-05062020-005479	3/21/2021	FT-FY21-032021-005479-A	<1	FT-FY21-032021-005479-B	<1
WS-005540	10/12/2020	10/12/2021	Basement	Combo Fountain	In classroom 008	WF-10122020-005540	3/21/2021	FT-FY21-032021-005540-A	<1	FT-FY21-032021-005540-B	<1
WS-005542	10/12/2020	10/12/2021	Basement	Combo Fountain	In classroom 007	WF-10122020-005542	3/21/2021	FT-FY21-032021-005542-A	<1	FT-FY21-032021-005542-B	<1
WS-005544	10/12/2020	10/12/2021	Basement	Combo Fountain	In classroom 005	WF-10122020-005544	3/21/2021	FT-FY21-032021-005544-A	<1	FT-FY21-032021-005544-B	<1
WS-005546	10/12/2020	10/12/2021	Basement	Combo Fountain	In classroom 009	WF-10122020-005546	3/21/2021	FT-FY21-032021-005546-A	<1	FT-FY21-032021-005546-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-005416	2/4/2021	2/4/2022	Basement	Food Prep Sink	In kitchen	WF-02042021-005416	3/21/2021	FT-FY21-032021-005416-A	<1	FT-FY21-032021-005416-B	<1

FY21 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-005446	5/6/2020	5/6/2021	1	Combo Fountain	In classroom 133 Right	WF-05062020-005446	3/21/2021	FT-FY21-032021-005446-A	<1	FT-FY21-032021-005446-B	35.0