



Lafayette ES Lead in Water Test Results

FY26 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 003475	2/25/2025	2/25/2026	2	Combo Fountain	In classroom 220	WF-02252025-003475	11/11/2025	FT-FY26-10172025-003475-A	<2	FT-FY26-10172025-003475-B	<2	
WS- 003476	2/25/2025	2/25/2026	2	Combo Fountain	In classroom 222	WF-02252025-003476	11/11/2025	FT-FY26-10172025-003476-A	<2	FT-FY26-10172025-003476-B	<2	
WS- 003477	2/25/2025	2/25/2026	2	Combo Fountain	In classroom 224	WF-02252025-003477	11/11/2025	FT-FY26-10172025-003477-A	<2	FT-FY26-10172025-003477-B	<2	
WS- 003478	2/25/2025	2/25/2026	2	Combo Fountain	In classroom 225	WF-02252025-003478	11/11/2025	FT-FY26-10172025-003478-A	<2	FT-FY26-10172025-003478-B	<2	
WS- 003479	2/25/2025	2/25/2026	2	Combo Fountain	In classroom 223	WF-02252025-003479	11/11/2025	FT-FY26-10172025-003479-A	<2	FT-FY26-10172025-003479-B	<2	
WS- 003480	2/25/2025	2/25/2026	2	Combo Fountain	In classroom 221	WF-02252025-003480	11/11/2025	FT-FY26-10172025-003480-A	<2	FT-FY26-10172025-003480-B	<2	
WS- 003481	2/25/2025	2/25/2026	1	Combo Fountain	In classroom 145	Right	WF-02252025-003481	11/11/2025	FT-FY26-10172025-003481-A	<2	FT-FY26-10172025-003481-B	<2
WS- 003482	2/25/2025	2/25/2026	1	Combo Fountain	In classroom 145	Left	WF-02252025-003482	11/11/2025	FT-FY26-10172025-003482-A	<2	FT-FY26-10172025-003482-B	<2
WS- 003490	8/12/2025	8/12/2026	1	Combo Faucet	In classroom 124	WF-08122025-003490	11/11/2025	FT-FY26-10172025-003490-A	<2	FT-FY26-10172025-003490-B	<2	
WS- 003491	8/12/2025	8/12/2026	1	Combo Faucet	In resource room 140	WF-08122025-003491	11/11/2025	FT-FY26-10172025-003491-A	<2	FT-FY26-10172025-003491-B	<2	
WS- 003492	8/12/2025	8/12/2026	1	Combo Faucet	In hallway adjacent to room 141	Right	WF-08122025-003492	11/11/2025	FT-FY26-10172025-003492-A	<2	FT-FY26-10172025-003492-B	<2
WS- 003493	8/12/2025	8/12/2026	1	Combo Faucet	In classroom 144	Left	WF-08122025-003493	11/11/2025	FT-FY26-10172025-003493-A	<2	FT-FY26-10172025-003493-B	<2
WS- 003494	8/12/2025	8/12/2026	1	Combo Faucet	In classroom 144	Right	WF-08122025-003494	11/11/2025	FT-FY26-10172025-003494-A	<2	FT-FY26-10172025-003494-B	<2
WS- 003495	8/12/2025	8/12/2026	1	Combo Faucet	In classroom 141	Left	WF-08122025-003495	11/11/2025	FT-FY26-10172025-003495-A	<2	FT-FY26-10172025-003495-B	<2
WS- 003496	8/12/2025	8/12/2026	1	Combo Faucet	In classroom 141	Right	WF-08122025-003496	11/11/2025	FT-FY26-10172025-003496-A	<2	FT-FY26-10172025-003496-B	<2
WS- 003497	8/12/2025	8/12/2026	1	Combo Faucet	In classroom 142	Left	WF-08122025-003497	11/11/2025	FT-FY26-10172025-003497-A	<2	FT-FY26-10172025-003497-B	<2
WS- 003498	8/12/2025	8/12/2026	1	Combo Faucet	In classroom 142	Right	WF-08122025-003498	11/11/2025	FT-FY26-10172025-003498-A	<2	FT-FY26-10172025-003498-B	<2
WS- 003500	8/12/2025	8/12/2026	1	Combo Faucet	In classroom 143	Right	WF-08122025-003500	11/11/2025	FT-FY26-10172025-003500-A	<2	FT-FY26-10172025-003500-B	<2
WS- 003501	8/12/2025	8/12/2026	1	Combo Faucet	In classroom 145	Left	WF-08122025-003501	11/11/2025	FT-FY26-10172025-003501-A	<2	FT-FY26-10172025-003501-B	<2
WS- 003502	8/12/2025	8/12/2026	1	Combo Faucet	In classroom 145	Right	WF-08122025-003502	11/11/2025	FT-FY26-10172025-003502-A	<2	FT-FY26-10172025-003502-B	<2
WS- 003503	8/12/2025	8/12/2026	1	Combo Faucet	In classroom 135	Left	WF-08122025-003503	11/11/2025	FT-FY26-10172025-003503-A	<2	FT-FY26-10172025-003503-B	<2
WS- 003504	8/12/2025	8/12/2026	1	Combo Faucet	In classroom 135	Right	WF-08122025-003504	11/11/2025	FT-FY26-10172025-003504-A	<2	FT-FY26-10172025-003504-B	<2
WS- 003505	8/12/2025	8/12/2026	1	Combo Faucet	In classroom 134	Left	WF-08122025-003505	11/11/2025	FT-FY26-10172025-003505-A	<2	FT-FY26-10172025-003505-B	<2
WS- 003506	8/12/2025	8/12/2026	1	Combo Faucet	In classroom 134	Right	WF-08122025-003506	11/11/2025	FT-FY26-10172025-003506-A	<2	FT-FY26-10172025-003506-B	<2
WS- 003507	8/12/2025	8/12/2026	1	Combo Faucet	In classroom 132	Left	WF-08122025-003507	11/11/2025	FT-FY26-10172025-003507-A	<2	FT-FY26-10172025-003507-B	<2
WS- 003508	8/12/2025	8/12/2026	1	Combo Faucet	In classroom 132	Right	WF-08122025-003508	11/11/2025	FT-FY26-10172025-003508-A	<2	FT-FY26-10172025-003508-B	<2
WS- 003509	8/12/2025	8/12/2026	1	Combo Faucet	In classroom 130	Left	WF-08122025-003509	11/11/2025	FT-FY26-10172025-003509-A	<2	FT-FY26-10172025-003509-B	<2
WS- 003510	8/12/2025	8/12/2026	1	Combo Faucet	In classroom 130	Left	WF-08122025-003510	11/11/2025	FT-FY26-10172025-003510-A	<2	FT-FY26-10172025-003510-B	<2
WS- 003511	8/12/2025	8/12/2026	1	Combo Faucet	In classroom 133	Left	WF-08122025-003511	11/11/2025	FT-FY26-10172025-003511-A	<2	FT-FY26-10172025-003511-B	<2
WS- 003512	8/12/2025	8/12/2026	1	Combo Faucet	In classroom 133	Right	WF-08122025-003512	11/11/2025	FT-FY26-10172025-003512-A	<2	FT-FY26-10172025-003512-B	<2
WS- 003513	2/25/2025	2/25/2026	1	Combo Fountain	In classroom 136	Left	WF-02252025-003513	11/11/2025	FT-FY26-10172025-003513-A	<2	FT-FY26-10172025-003513-B	<2
WS- 003514	8/12/2025	8/12/2026	1	Combo Faucet	In classroom 136	Left	WF-08122025-003514	11/11/2025	FT-FY26-10172025-003514-A	<2	FT-FY26-10172025-003514-B	<2
WS- 003515	2/25/2025	2/25/2026	1	Combo Fountain	In classroom 136	Right	WF-02252025-003515	11/11/2025	FT-FY26-10172025-003515-A	<2	FT-FY26-10172025-003515-B	<2
WS- 003516	8/12/2025	8/12/2026	1	Combo Faucet	In classroom 136	Right	WF-08122025-003516	11/11/2025	FT-FY26-10172025-003516-A	<2	FT-FY26-10172025-003516-B	<2

WS-003518	2/25/2025	2/25/2026	1	Cooler	In hallway adjacent to gym room 150	High Left	WF-02252025-003518	11/11/2025	FT-FY26-10172025-003518-A	<2	FT-FY26-10172025-003518-B	<2
WS-003519	2/25/2025	2/25/2026	1	Bottle Filler	In hallway adjacent to gym room 150 (bottle filler)		WF-02252025-003519	11/11/2025	FT-FY26-10172025-003519-A	<2	FT-FY26-10172025-003519-B	<2
WS-003520	2/25/2025	2/25/2026	1	Cooler	In hallway adjacent to gym room 150	Low Right	WF-02252025-003520	11/11/2025	FT-FY26-10172025-003520-A	<2	FT-FY26-10172025-003520-B	<2
WS-005417	2/25/2025	2/25/2026	Basement	Cooler	In multi-purpose room	High Left	WF-02252025-005417	11/11/2025	FT-FY26-10172025-005417-A	<2	FT-FY26-10172025-005417-B	<2
WS-005418	2/25/2025	2/25/2026	Basement	Bottle Filler	In multi-purpose room (bottle filler)		WF-02252025-005418	11/11/2025	FT-FY26-10172025-005418-A	<2	FT-FY26-10172025-005418-B	<2
WS-005419	2/25/2025	2/25/2026	Basement	Cooler	In multi-purpose room	Low Right	WF-02252025-005419	11/11/2025	FT-FY26-10172025-005419-A	<2	FT-FY26-10172025-005419-B	<2
WS-005420	10/7/2025	10/7/2026	1	Cooler	In hallway across from elevator	High Left	WF-10072025-005420	11/11/2025	FT-FY26-10172025-005420-A	<2	FT-FY26-10172025-005420-B	<2
WS-005421	10/7/2025	10/7/2026	1	Bottle Filler	In hallway across from elevator (bottle filler)		WF-10072025-005421	11/11/2025	FT-FY26-10172025-005421-A	<2	FT-FY26-10172025-005421-B	<2
WS-005422	10/7/2025	10/7/2026	1	Cooler	In hallway across from elevator	Low Right	WF-10072025-005422	11/11/2025	FT-FY26-10172025-005422-A	<2	FT-FY26-10172025-005422-B	<2
WS-005423	2/25/2025	2/25/2026	1	Combo Fountain	In classroom 111		WF-02252025-005423	11/11/2025	FT-FY26-10172025-005423-A	<2	FT-FY26-10172025-005423-B	<2
WS-005424	2/25/2025	2/25/2026	1	Combo Fountain	In classroom 112		WF-02252025-005424	11/11/2025	FT-FY26-10172025-005424-A	<2	FT-FY26-10172025-005424-B	<2
WS-005425	2/25/2025	2/25/2026	1	Combo Fountain	In classroom 114		WF-02252025-005425	11/11/2025	FT-FY26-10172025-005425-A	<2	FT-FY26-10172025-005425-B	<2
WS-005426	2/25/2025	2/25/2026	1	Combo Fountain	In classroom 116		WF-02252025-005426	11/11/2025	FT-FY26-10172025-005426-A	<2	FT-FY26-10172025-005426-B	<2
WS-005427	2/25/2025	2/25/2026	1	Combo Fountain	In classroom 115		WF-02252025-005427	11/11/2025	FT-FY26-10172025-005427-A	<2	FT-FY26-10172025-005427-B	<2
WS-005428	2/25/2025	2/25/2026	1	Combo Fountain	In classroom 113		WF-02252025-005428	11/11/2025	FT-FY26-10172025-005428-A	<2	FT-FY26-10172025-005428-B	<2
WS-005429	2/25/2025	2/25/2026	1	Combo Fountain	In classroom 124		WF-02252025-005429	11/11/2025	FT-FY26-10172025-005429-A	<2	FT-FY26-10172025-005429-B	<2
WS-005430	2/25/2025	2/25/2026	1	Health Suite	In health suite 102		WF-02252025-005430	11/11/2025	FT-FY26-10172025-005430-A	<2	FT-FY26-10172025-005430-B	<2
WS-005431	2/25/2025	2/25/2026	1	Combo Fountain	In resource room 140		WF-02252025-005431	11/11/2025	FT-FY26-10172025-005431-A	<2	FT-FY26-10172025-005431-B	<2
WS-005432	2/25/2025	2/25/2026	1	Combo Fountain	In classroom 142	Left	WF-02252025-005432	11/11/2025	FT-FY26-10172025-005432-A	<2	FT-FY26-10172025-005432-B	<2
WS-005434	2/25/2025	2/25/2026	1	Combo Fountain	In classroom 144	Left	WF-02252025-005434	11/11/2025	FT-FY26-10172025-005434-A	<2	FT-FY26-10172025-005434-B	<2
WS-005435	2/25/2025	2/25/2026	1	Combo Fountain	In classroom 144	Right	WF-02252025-005435	11/11/2025	FT-FY26-10172025-005435-A	<2	FT-FY26-10172025-005435-B	<2
WS-005437	2/25/2025	2/25/2026	1	Combo Fountain	In classroom 143	Right	WF-02252025-005437	11/11/2025	FT-FY26-10172025-005437-A	<2	FT-FY26-10172025-005437-B	<2
WS-005438	2/25/2025	2/25/2026	1	Combo Fountain	In hallway adjacent to room 141		WF-02252025-005438	11/11/2025	FT-FY26-10172025-005438-A	<2	FT-FY26-10172025-005438-B	<2
WS-005441	2/25/2025	2/25/2026	1	Combo Fountain	In classroom 130	Left	WF-02252025-005441	11/11/2025	FT-FY26-10172025-005441-A	<2	FT-FY26-10172025-005441-B	<2
WS-005442	2/25/2025	2/25/2026	1	Combo Fountain	In classroom 130	Right	WF-02252025-005442	11/11/2025	FT-FY26-10172025-005442-A	<2	FT-FY26-10172025-005442-B	<2
WS-005443	2/25/2025	2/25/2026	1	Combo Fountain	In classroom 132	Left	WF-02252025-005443	11/11/2025	FT-FY26-10172025-005443-A	<2	FT-FY26-10172025-005443-B	<2
WS-005444	2/25/2025	2/25/2026	1	Combo Fountain	In classroom 132	Right	WF-02252025-005444	11/11/2025	FT-FY26-10172025-005444-A	<2	FT-FY26-10172025-005444-B	<2
WS-005445	2/25/2025	2/25/2026	1	Combo Fountain	In classroom 133	Left	WF-02252025-005445	11/11/2025	FT-FY26-10172025-005445-A	<2	FT-FY26-10172025-005445-B	<2
WS-005446	2/25/2025	2/25/2026	1	Combo Fountain	In classroom 133	Right	WF-02252025-005446	11/11/2025	FT-FY26-10172025-005446-A	<2	FT-FY26-10172025-005446-B	<2
WS-005447	2/25/2025	2/25/2026	1	Combo Fountain	In classroom 134	Left	WF-02252025-005447	11/11/2025	FT-FY26-10172025-005447-A	<2	FT-FY26-10172025-005447-B	<2
WS-005448	2/25/2025	2/25/2026	1	Combo Fountain	In classroom 134	Right	WF-02252025-005448	11/11/2025	FT-FY26-10172025-005448-A	<2	FT-FY26-10172025-005448-B	<2
WS-005449	2/25/2025	2/25/2026	1	Combo Fountain	In classroom 135	Left	WF-02252025-005449	11/11/2025	FT-FY26-10172025-005449-A	<2	FT-FY26-10172025-005449-B	<2
WS-005450	2/25/2025	2/25/2026	1	Combo Fountain	In classroom 135	Right	WF-02252025-005450	11/11/2025	FT-FY26-10172025-005450-A	<2	FT-FY26-10172025-005450-B	<2
WS-005451	2/25/2025	2/25/2026	1	Combo Fountain	In classroom 146	Left	WF-02252025-005451	11/11/2025	FT-FY26-10172025-005451-A	<2	FT-FY26-10172025-005451-B	<2
WS-005452	2/25/2025	2/25/2026	1	Cooler	In hallway adjacent to girls' restroom	High Left	WF-02252025-005452	11/11/2025	FT-FY26-10172025-005452-A	<2	FT-FY26-10172025-005452-B	<2
WS-005453	2/25/2025	2/25/2026	1	Bottle Filler	In hallway adjacent to girls' restroom (bottle filler)		WF-02252025-005453	11/11/2025	FT-FY26-10172025-005453-A	<2	FT-FY26-10172025-005453-B	<2
WS-005454	2/25/2025	2/25/2026	1	Cooler	In hallway adjacent to girls' restroom	Low Right	WF-02252025-005454	11/11/2025	FT-FY26-10172025-005454-A	<2	FT-FY26-10172025-005454-B	<2
WS-005455	2/25/2025	2/25/2026	2	Cooler	In hallway adjacent to room 207	High Left	WF-02252025-005455	11/11/2025	FT-FY26-10172025-005455-A	<2	FT-FY26-10172025-005455-B	<2
WS-005456	2/25/2025	2/25/2026	2	Bottle Filler	In hallway adjacent to room 207 (bottle filler)		WF-02252025-005456	11/11/2025	FT-FY26-10172025-005456-A	<2	FT-FY26-10172025-005456-B	<2
WS-005457	2/25/2025	2/25/2026	2	Cooler	In hallway adjacent to room 207	Low Right	WF-02252025-005457	11/11/2025	FT-FY26-10172025-005457-A	<2	FT-FY26-10172025-005457-B	<2
WS-005458	2/25/2025	2/25/2026	2	Combo Fountain	In classroom 240		WF-02252025-005458	11/11/2025	FT-FY26-10172025-005458-A	<2	FT-FY26-10172025-005458-B	<2

WS- 005460	2/25/2025	2/25/2026	2	Combo Fountain	In classroom 244		WF-02252025-005460	11/11/2025	FT-FY26-10172025-005460-A	<2	FT-FY26-10172025-005460-B	<2
WS- 005461	2/25/2025	2/25/2026	2	Combo Fountain	In classroom 245		WF-02252025-005461	11/11/2025	FT-FY26-10172025-005461-A	<2	FT-FY26-10172025-005461-B	<2
WS- 005462	2/25/2025	2/25/2026	2	Combo Fountain	In classroom 243		WF-02252025-005462	11/11/2025	FT-FY26-10172025-005462-A	<2	FT-FY26-10172025-005462-B	<2
WS- 005463	2/25/2025	2/25/2026	2	Combo Fountain	In classroom 241		WF-02252025-005463	11/11/2025	FT-FY26-10172025-005463-A	<2	FT-FY26-10172025-005463-B	<2
WS- 005464	2/25/2025	2/25/2026	2	Combo Fountain	In classroom 231		WF-02252025-005464	11/11/2025	FT-FY26-10172025-005464-A	<2	FT-FY26-10172025-005464-B	<2
WS- 005465	2/25/2025	2/25/2026	2	Combo Fountain	In classroom 233		WF-02252025-005465	11/11/2025	FT-FY26-10172025-005465-A	<2	FT-FY26-10172025-005465-B	<2
WS- 005466	2/25/2025	2/25/2026	2	Combo Fountain	In classroom 235		WF-02252025-005466	11/11/2025	FT-FY26-10172025-005466-A	<2	FT-FY26-10172025-005466-B	<2
WS- 005467	2/25/2025	2/25/2026	2	Combo Fountain	In classroom 236		WF-02252025-005467	11/11/2025	FT-FY26-10172025-005467-A	<2	FT-FY26-10172025-005467-B	<2
WS- 005468	2/25/2025	2/25/2026	2	Combo Fountain	In classroom 234		WF-02252025-005468	11/11/2025	FT-FY26-10172025-005468-A	<2	FT-FY26-10172025-005468-B	<2
WS- 005469	2/25/2025	2/25/2026	2	Combo Fountain	In classroom 232		WF-02252025-005469	11/11/2025	FT-FY26-10172025-005469-A	<2	FT-FY26-10172025-005469-B	<2
WS- 005471	2/25/2025	2/25/2026	2	Cooler	In hallway adjacent to room 209	High Left	WF-02252025-005471	11/11/2025	FT-FY26-10172025-005471-A	<2	FT-FY26-10172025-005471-B	<2
WS- 005472	2/25/2025	2/25/2026	2	Bottle Filler	In hallway adjacent to room 209 (bottle filler)		WF-02252025-005472	11/11/2025	FT-FY26-10172025-005472-A	<2	FT-FY26-10172025-005472-B	<2
WS- 005473	2/25/2025	2/25/2026	2	Cooler	In hallway adjacent to room 209	Low Right	WF-02252025-005473	11/11/2025	FT-FY26-10172025-005473-A	<2	FT-FY26-10172025-005473-B	<2
WS- 005474	2/25/2025	2/25/2026	2	Combo Fountain	In classroom 212		WF-02252025-005474	11/11/2025	FT-FY26-10172025-005474-A	<2	FT-FY26-10172025-005474-B	<2
WS- 005475	2/25/2025	2/25/2026	2	Combo Fountain	In classroom 214		WF-02252025-005475	11/11/2025	FT-FY26-10172025-005475-A	<2	FT-FY26-10172025-005475-B	<2
WS- 005476	2/25/2025	2/25/2026	2	Combo Fountain	In classroom 216		WF-02252025-005476	11/11/2025	FT-FY26-10172025-005476-A	<2	FT-FY26-10172025-005476-B	<2
WS- 005477	2/25/2025	2/25/2026	2	Combo Fountain	In classroom 215		WF-02252025-005477	11/11/2025	FT-FY26-10172025-005477-A	<2	FT-FY26-10172025-005477-B	<2
WS- 005478	2/25/2025	2/25/2026	2	Combo Fountain	In classroom 213		WF-02252025-005478	11/11/2025	FT-FY26-10172025-005478-A	<2	FT-FY26-10172025-005478-B	<2
WS- 005479	2/25/2025	2/25/2026	2	Combo Fountain	In classroom 211		WF-02252025-005479	11/11/2025	FT-FY26-10172025-005479-A	<2	FT-FY26-10172025-005479-B	<2
WS- 005540	2/25/2025	2/25/2026	Basement	Combo Fountain	In classroom 008		WF-02252025-005540	11/11/2025	FT-FY26-10172025-005540-A	<2	FT-FY26-10172025-005540-B	<2
WS- 005542	2/25/2025	2/25/2026	Basement	Combo Fountain	In classroom 007		WF-02252025-005542	11/11/2025	FT-FY26-10172025-005542-A	<2	FT-FY26-10172025-005542-B	<2
WS- 005544	2/25/2025	2/25/2026	Basement	Combo Fountain	In classroom 005		WF-02252025-005544	11/11/2025	FT-FY26-10172025-005544-A	<2	FT-FY26-10172025-005544-B	<2
WS- 005546	2/25/2025	2/25/2026	Basement	Combo Fountain	In classroom 009		WF-02252025-005546	11/11/2025	FT-FY26-10172025-005546-A	<2	FT-FY26-10172025-005546-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 005416	12/2/2024	12/2/2025	Basement	Food Prep Sink	In kitchen	WF-12022024-005416	11/11/2025	FT-FY26-10172025-005416-A	<2	FT-FY26-10172025-005416-B	<2	

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.