



Lafayette ES Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 003475	5/13/2019	5/13/2020	2	Combo Fountain	In classroom 220	WF-05132019-003475	11/23/2019	FT-FY20-112019-003475-A	<1	FT-FY20-112019-003475-B	<1	
WS- 003476	5/13/2019	5/13/2020	2	Combo Fountain	In classroom 222	WF-05132019-003476	11/23/2019	FT-FY20-112019-003476-A	<1	FT-FY20-112019-003476-B	<1	
WS- 003477	5/13/2019	5/13/2020	2	Combo Fountain	In classroom 224	WF-05132019-003477	11/23/2019	FT-FY20-112019-003477-A	<1	FT-FY20-112019-003477-B	<1	
WS- 003478	5/13/2019	5/13/2020	2	Combo Fountain	In classroom 225	WF-05132019-003478	11/23/2019	FT-FY20-112019-003478-A	<1	FT-FY20-112019-003478-B	<1	
WS- 003479	5/13/2019	5/13/2020	2	Combo Fountain	In classroom 223	WF-05132019-003479	11/23/2019	FT-FY20-112019-003479-A	<1	FT-FY20-112019-003479-B	<1	
WS- 003480	5/13/2019	5/13/2020	2	Combo Fountain	In classroom 221	WF-05132019-003480	11/23/2019	FT-FY20-112019-003480-A	<1	FT-FY20-112019-003480-B	<1	
WS- 003481	5/13/2019	5/13/2020	1	Combo Fountain	In classroom 145	Right	WF-05132019-003481	11/23/2019	FT-FY20-112019-003481-A	<1	FT-FY20-112019-003481-B	<1
WS- 003482	5/13/2019	5/13/2020	1	Combo Fountain	In classroom 145	Left	WF-05132019-003482	11/23/2019	FT-FY20-112019-003482-A	<1	FT-FY20-112019-003482-B	<1
WS- 003490	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 124	WF-09242019-003490	11/23/2019	FT-FY20-112019-003490-A	<1	FT-FY20-112019-003490-B	<1	
WS- 003491	9/24/2019	9/24/2020	1	Combo Faucet	In resource room 140	WF-09242019-003491	11/23/2019	FT-FY20-112019-003491-A	1.3	FT-FY20-112019-003491-B	<1	
WS- 003492	9/24/2019	9/24/2020	1	Combo Faucet	In hallway adjacent to room 141	Right	WF-09242019-003492	11/23/2019	FT-FY20-112019-003492-A	<1	FT-FY20-112019-003492-B	<1
WS- 003493	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 144	Left	WF-09242019-003493	11/23/2019	FT-FY20-112019-003493-A	<1	FT-FY20-112019-003493-B	<1
WS- 003494	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 144	Right	WF-09242019-003494	11/23/2019	FT-FY20-112019-003494-A	<1	FT-FY20-112019-003494-B	<1
WS- 003495	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 141	Left	WF-09242019-003495	11/23/2019	FT-FY20-112019-003495-A	<1	FT-FY20-112019-003495-B	<1
WS- 003496	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 141	Right	WF-09242019-003496	11/23/2019	FT-FY20-112019-003496-A	<1	FT-FY20-112019-003496-B	<1
WS- 003497	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 142	Left	WF-09242019-003497	11/23/2019	FT-FY20-112019-003497-A	<1	FT-FY20-112019-003497-B	<1
WS- 003498	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 142	Right	WF-09242019-003498	11/23/2019	FT-FY20-112019-003498-A	<1	FT-FY20-112019-003498-B	<1
WS- 003499	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 143	Left	WF-09242019-003499	11/23/2019	FT-FY20-112019-003499-A	<1	FT-FY20-112019-003499-B	<1
WS- 003500	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 143	Right	WF-09242019-003500	11/23/2019	FT-FY20-112019-003500-A	<1	FT-FY20-112019-003500-B	<1
WS- 003501	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 145	Left	WF-09242019-003501	11/23/2019	FT-FY20-112019-003501-A	<1	FT-FY20-112019-003501-B	<1
WS- 003502	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 145	Right	WF-09242019-003502	11/23/2019	FT-FY20-112019-003502-A	<1	FT-FY20-112019-003502-B	<1
WS- 003503	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 135	Left	WF-09242019-003503	11/23/2019	FT-FY20-112019-003503-A	<1	FT-FY20-112019-003503-B	<1
WS- 003504	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 135	Right	WF-09242019-003504	11/23/2019	FT-FY20-112019-003504-A	<1	FT-FY20-112019-003504-B	<1
WS- 003505	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 134	Left	WF-09242019-003505	11/23/2019	FT-FY20-112019-003505-A	<1	FT-FY20-112019-003505-B	<1
WS- 003506	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 134	Right	WF-09242019-003506	11/23/2019	FT-FY20-112019-003506-A	<1	FT-FY20-112019-003506-B	<1
WS- 003507	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 132	Left	WF-09242019-003507	11/23/2019	FT-FY20-112019-003507-A	<1	FT-FY20-112019-003507-B	<1
WS- 003508	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 132	Right	WF-09242019-003508	11/23/2019	FT-FY20-112019-003508-A	<1	FT-FY20-112019-003508-B	<1
WS- 003509	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 130	Left	WF-09242019-003509	11/23/2019	FT-FY20-112019-003509-A	<1	FT-FY20-112019-003509-B	<1
WS- 003510	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 130	Left	WF-09242019-003510	11/23/2019	FT-FY20-112019-003510-A	<1	FT-FY20-112019-003510-B	<1
WS- 003511	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 133	Left	WF-09242019-003511	11/23/2019	FT-FY20-112019-003511-A	<1	FT-FY20-112019-003511-B	<1

WS- 003512	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 133	Right	WF-09242019-003512	11/23/2019	FT-FY20-112019-003512-A	<1	FT-FY20-112019-003512-B	<1
WS- 003513	5/13/2019	5/13/2020	1	Combo Fountain	In classroom 136	Left	WF-05132019-003513	11/23/2019	FT-FY20-112019-003513-A	<1	FT-FY20-112019-003513-B	<1
WS- 003514	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 136	Left	WF-09242019-003514	11/23/2019	FT-FY20-112019-003514-A	<1	FT-FY20-112019-003514-B	<1
WS- 003515	5/13/2019	5/13/2020	1	Combo Fountain	In classroom 136	Right	WF-05132019-003515	11/23/2019	FT-FY20-112019-003515-A	<1	FT-FY20-112019-003515-B	<1
WS- 003516	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 136	Right	WF-09242019-003516	11/23/2019	FT-FY20-112019-003516-A	<1	FT-FY20-112019-003516-B	<1
WS- 003518	5/13/2019	5/13/2020	1	Cooler	In hallway adjacent to gym room 150	High Left	WF-05132019-003518	11/23/2019	FT-FY20-112019-003518-A	<1	FT-FY20-112019-003518-B	<1
WS- 003519	5/13/2019	5/13/2020	1	Bottle Filler	In hallway adjacent to gym room 150		WF-05132019-003519	11/23/2019	FT-FY20-112019-003519-A	<1	FT-FY20-112019-003519-B	<1
WS- 003520	5/13/2019	5/13/2020	1	Cooler	In hallway adjacent to gym room 150	Low Right	WF-05132019-003520	11/23/2019	FT-FY20-112019-003520-A	<1	FT-FY20-112019-003520-B	<1
WS- 005417	5/13/2019	5/13/2020	Basement	Cooler	In multi-purpose room	High Left	WF-05132019-005417	11/23/2019	FT-FY20-112019-005417-A	<1	FT-FY20-112019-005417-B	<1
WS- 005418	5/13/2019	5/13/2020	Basement	Bottle Filler	In multi-purpose room (bottle filler)		WF-05132019-005418	11/23/2019	FT-FY20-112019-005418-A	<1	FT-FY20-112019-005418-B	<1
WS- 005419	5/13/2019	5/13/2020	Basement	Cooler	In multi-purpose room	Low Right	WF-05132019-005419	11/23/2019	FT-FY20-112019-005419-A	<1	FT-FY20-112019-005419-B	<1
WS- 005420	5/13/2019	5/13/2020	1	Cooler	In hallway across from elevator	High Left	WF-05132019-005420	11/23/2019	FT-FY20-112019-005420-A	<1	FT-FY20-112019-005420-B	<1
WS- 005421	5/13/2019	5/13/2020	1	Bottle Filler	In hallway across from elevator		WF-05132019-005421	11/23/2019	FT-FY20-112019-005421-A	<1	FT-FY20-112019-005421-B	<1
WS- 005422	5/13/2019	5/13/2020	1	Cooler	In hallway across from elevator	Low Right	WF-05132019-005422	11/23/2019	FT-FY20-112019-005422-A	<1	FT-FY20-112019-005422-B	<1
WS- 005423	5/13/2019	5/13/2020	1	Combo Fountain	In classroom 111		WF-05132019-005423	11/23/2019	FT-FY20-112019-005423-A	<1	FT-FY20-112019-005423-B	<1
WS- 005424	5/13/2019	5/13/2020	1	Combo Fountain	In classroom 112		WF-05132019-005424	11/23/2019	FT-FY20-112019-005424-A	<1	FT-FY20-112019-005424-B	<1
WS- 005425	5/13/2019	5/13/2020	1	Combo Fountain	In classroom 114		WF-05132019-005425	11/23/2019	FT-FY20-112019-005425-A	<1	FT-FY20-112019-005425-B	<1
WS- 005426	5/13/2019	5/13/2020	1	Combo Fountain	In classroom 116		WF-05132019-005426	11/23/2019	FT-FY20-112019-005426-A	<1	FT-FY20-112019-005426-B	<1
WS- 005427	5/13/2019	5/13/2020	1	Combo Fountain	In classroom 115		WF-05132019-005427	11/23/2019	FT-FY20-112019-005427-A	<1	FT-FY20-112019-005427-B	<1
WS- 005428	5/13/2019	5/13/2020	1	Combo Fountain	In classroom 113		WF-05132019-005428	11/23/2019	FT-FY20-112019-005428-A	<1	FT-FY20-112019-005428-B	<1
WS- 005429	5/13/2019	5/13/2020	1	Combo Fountain	In classroom 124		WF-05132019-005429	11/23/2019	FT-FY20-112019-005429-A	<1	FT-FY20-112019-005429-B	<1
WS- 005430	5/13/2019	5/13/2020	1	Health Suite	In health suite 102		WF-05132019-005430	11/23/2019	FT-FY20-112019-005430-A	<1	FT-FY20-112019-005430-B	<1
WS- 005431	5/13/2019	5/13/2020	1	Combo Fountain	In resource room 140		WF-05132019-005431	11/23/2019	FT-FY20-112019-005431-A	<1	FT-FY20-112019-005431-B	<1
WS- 005432	5/13/2019	5/13/2020	1	Combo Fountain	In classroom 142	Left	WF-05132019-005432	11/23/2019	FT-FY20-112019-005432-A	<1	FT-FY20-112019-005432-B	<1
WS- 005433	5/13/2019	5/13/2020	1	Combo Fountain	In classroom 142	Right	WF-05132019-005433	11/23/2019	FT-FY20-112019-005433-A	<1	FT-FY20-112019-005433-B	<1
WS- 005434	5/13/2019	5/13/2020	1	Combo Fountain	In classroom 144	Left	WF-05132019-005434	11/23/2019	FT-FY20-112019-005434-A	<1	FT-FY20-112019-005434-B	<1
WS- 005435	5/13/2019	5/13/2020	1	Combo Fountain	In classroom 144	Right	WF-05132019-005435	11/23/2019	FT-FY20-112019-005435-A	<1	FT-FY20-112019-005435-B	<1
WS- 005436	5/13/2019	5/13/2020	1	Combo Fountain	In classroom 143	Left	WF-05132019-005436	11/23/2019	FT-FY20-112019-005436-A	<1	FT-FY20-112019-005436-B	<1
WS- 005437	5/13/2019	5/13/2020	1	Combo Fountain	In classroom 143	Right	WF-05132019-005437	11/23/2019	FT-FY20-112019-005437-A	<1	FT-FY20-112019-005437-B	<1
WS- 005438	5/13/2019	5/13/2020	1	Combo Fountain	In hallway adjacent to room 141		WF-05132019-005438	11/23/2019	FT-FY20-112019-005438-A	<1	FT-FY20-112019-005438-B	<1
WS- 005439	5/13/2019	5/13/2020	1	Combo Fountain	In classroom 141	Left	WF-05132019-005439	11/23/2019	FT-FY20-112019-005439-A	<1	FT-FY20-112019-005439-B	<1
WS- 005440	5/13/2019	5/13/2020	1	Combo Fountain	In classroom 141	Right	WF-05132019-005440	11/23/2019	FT-FY20-112019-005440-A	<1	FT-FY20-112019-005440-B	<1
WS- 005441	5/13/2019	5/13/2020	1	Combo Fountain	In classroom 130	Left	WF-05132019-005441	11/23/2019	FT-FY20-112019-005441-A	<1	FT-FY20-112019-005441-B	<1
WS- 005442	5/13/2019	5/13/2020	1	Combo Fountain	In classroom 130	Right	WF-05132019-005442	11/23/2019	FT-FY20-112019-005442-A	<1	FT-FY20-112019-005442-B	<1
WS- 005443	5/13/2019	5/13/2020	1	Combo Fountain	In classroom 132	Left	WF-05132019-005443	11/23/2019	FT-FY20-112019-005443-A	<1	FT-FY20-112019-005443-B	<1
WS- 005444	5/13/2019	5/13/2020	1	Combo Fountain	In classroom 132	Right	WF-05132019-005444	11/23/2019	FT-FY20-112019-005444-A	<1	FT-FY20-112019-005444-B	<1

WS- 005445	5/13/2019	5/13/2020	1	Combo Fountain	In classroom 133	Left	WF-05132019-005445	11/23/2019	FT-FY20-112019-005445-A	<1	FT-FY20-112019-005445-B	<1
WS- 005446	5/13/2019	5/13/2020	1	Combo Fountain	In classroom 133	Right	WF-05132019-005446	11/23/2019	FT-FY20-112019-005446-A	<1	FT-FY20-112019-005446-B	<1
WS- 005447	5/13/2019	5/13/2020	1	Combo Fountain	In classroom 134	Left	WF-05132019-005447	11/23/2019	FT-FY20-112019-005447-A	<1	FT-FY20-112019-005447-B	<1
WS- 005448	5/13/2019	5/13/2020	1	Combo Fountain	In classroom 134	Right	WF-05132019-005448	11/23/2019	FT-FY20-112019-005448-A	<1	FT-FY20-112019-005448-B	<1
WS- 005449	5/13/2019	5/13/2020	1	Combo Fountain	In classroom 135	Left	WF-05132019-005449	11/23/2019	FT-FY20-112019-005449-A	<1	FT-FY20-112019-005449-B	<1
WS- 005450	5/13/2019	5/13/2020	1	Combo Fountain	In classroom 135	Right	WF-05132019-005450	11/23/2019	FT-FY20-112019-005450-A	<1	FT-FY20-112019-005450-B	<1
WS- 005451	5/13/2019	5/13/2020	1	Combo Fountain	In classroom 146	Left	WF-05132019-005451	11/23/2019	FT-FY20-112019-005451-A	<1	FT-FY20-112019-005451-B	<1
WS- 005452	5/13/2019	5/13/2020	1	Cooler	In hallway adjacent to girls' restroom	High Left	WF-05132019-005452	11/23/2019	FT-FY20-112019-005452-A	<1	FT-FY20-112019-005452-B	<1
WS- 005453	5/13/2019	5/13/2020	1	Bottle Filler	In hallway adjacent to girls' restroom		WF-05132019-005453	11/23/2019	FT-FY20-112019-005453-A	<1	FT-FY20-112019-005453-B	<1
WS- 005454	5/13/2019	5/13/2020	1	Cooler	In hallway adjacent to girls' restroom	Low Right	WF-05132019-005454	11/23/2019	FT-FY20-112019-005454-A	<1	FT-FY20-112019-005454-B	<1
WS- 005455	5/13/2019	5/13/2020	2	Cooler	In hallway adjacent to room 207	High Left	WF-05132019-005455	11/23/2019	FT-FY20-112019-005455-A	<1	FT-FY20-112019-005455-B	<1
WS- 005456	5/13/2019	5/13/2020	2	Bottle Filler	In hallway adjacent to room 207		WF-05132019-005456	11/23/2019	FT-FY20-112019-005456-A	<1	FT-FY20-112019-005456-B	<1
WS- 005457	5/13/2019	5/13/2020	2	Cooler	In hallway adjacent to room 207	Low Right	WF-05132019-005457	11/23/2019	FT-FY20-112019-005457-A	<1	FT-FY20-112019-005457-B	<1
WS- 005458	5/13/2019	5/13/2020	2	Combo Fountain	In classroom 240		WF-05132019-005458	11/23/2019	FT-FY20-112019-005458-A	<1	FT-FY20-112019-005458-B	<1
WS- 005459	5/13/2019	5/13/2020	2	Combo Fountain	In classroom 242		WF-05132019-005459	11/23/2019	FT-FY20-112019-005459-A	<1	FT-FY20-112019-005459-B	<1
WS- 005460	5/13/2019	5/13/2020	2	Combo Fountain	In classroom 244		WF-05132019-005460	11/23/2019	FT-FY20-112019-005460-A	<1	FT-FY20-112019-005460-B	<1
WS- 005461	5/13/2019	5/13/2020	2	Combo Fountain	In classroom 245		WF-05132019-005461	11/23/2019	FT-FY20-112019-005461-A	<1	FT-FY20-112019-005461-B	<1
WS- 005462	5/13/2019	5/13/2020	2	Combo Fountain	In classroom 243		WF-05132019-005462	11/23/2019	FT-FY20-112019-005462-A	<1	FT-FY20-112019-005462-B	<1
WS- 005463	5/13/2019	5/13/2020	2	Combo Fountain	In classroom 241		WF-05132019-005463	11/23/2019	FT-FY20-112019-005463-A	<1	FT-FY20-112019-005463-B	<1
WS- 005464	5/13/2019	5/13/2020	2	Combo Fountain	In classroom 231		WF-05132019-005464	11/23/2019	FT-FY20-112019-005464-A	<1	FT-FY20-112019-005464-B	<1
WS- 005465	5/13/2019	5/13/2020	2	Combo Fountain	In classroom 233		WF-05132019-005465	11/23/2019	FT-FY20-112019-005465-A	<1	FT-FY20-112019-005465-B	<1
WS- 005466	5/13/2019	5/13/2020	2	Combo Fountain	In classroom 235		WF-05132019-005466	11/23/2019	FT-FY20-112019-005466-A	<1	FT-FY20-112019-005466-B	<1
WS- 005467	5/13/2019	5/13/2020	2	Combo Fountain	In classroom 236		WF-05132019-005467	11/23/2019	FT-FY20-112019-005467-A	<1	FT-FY20-112019-005467-B	<1
WS- 005468	5/13/2019	5/13/2020	2	Combo Fountain	In classroom 234		WF-05132019-005468	11/23/2019	FT-FY20-112019-005468-A	<1	FT-FY20-112019-005468-B	<1
WS- 005469	5/13/2019	5/13/2020	2	Combo Fountain	In classroom 232		WF-05132019-005469	11/23/2019	FT-FY20-112019-005469-A	<1	FT-FY20-112019-005469-B	<1
WS- 005471	5/13/2019	5/13/2020	2	Cooler	In hallway adjacent to room 209	High Left	WF-05132019-005471	11/23/2019	FT-FY20-112019-005471-A	<1	FT-FY20-112019-005471-B	<1
WS- 005472	5/13/2019	5/13/2020	2	Bottle Filler	In hallway adjacent to room 209		WF-05132019-005472	11/23/2019	FT-FY20-112019-005472-A	<1	FT-FY20-112019-005472-B	<1
WS- 005473	5/13/2019	5/13/2020	2	Cooler	In hallway adjacent to room 209	Low Right	WF-05132019-005473	11/23/2019	FT-FY20-112019-005473-A	<1	FT-FY20-112019-005473-B	<1
WS- 005474	5/13/2019	5/13/2020	2	Combo Fountain	In classroom 212		WF-05132019-005474	11/23/2019	FT-FY20-112019-005474-A	<1	FT-FY20-112019-005474-B	<1
WS- 005475	5/13/2019	5/13/2020	2	Combo Fountain	In classroom 214		WF-05132019-005475	11/23/2019	FT-FY20-112019-005475-A	<1	FT-FY20-112019-005475-B	<1
WS- 005476	5/13/2019	5/13/2020	2	Combo Fountain	In classroom 216		WF-05132019-005476	11/23/2019	FT-FY20-112019-005476-A	<1	FT-FY20-112019-005476-B	<1
WS- 005477	5/13/2019	5/13/2020	2	Combo Fountain	In classroom 215		WF-05132019-005477	11/23/2019	FT-FY20-112019-005477-A	<1	FT-FY20-112019-005477-B	<1
WS- 005478	5/13/2019	5/13/2020	2	Combo Fountain	In classroom 213		WF-05132019-005478	11/23/2019	FT-FY20-112019-005478-A	<1	FT-FY20-112019-005478-B	<1
WS- 005479	5/13/2019	5/13/2020	2	Combo Fountain	In classroom 211		WF-05132019-005479	11/23/2019	FT-FY20-112019-005479-A	<1	FT-FY20-112019-005479-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005416	7/3/2019	7/3/2020	Basement	Food Prep Sink	In kitchen	WF-07032019-005416	11/23/2019	FT-FY20-112019-005416-A	<1	FT-FY20-112019-005416-B	<1