



Lafayette Elementary School Lead in Water Test Results

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 003475	3/6/2024	3/6/2025	2	Combo Fountain	In classroom 220	WF-03062024-003475	11/19/2024	FT-FY25-10082024-003475-A	<2	FT-FY25-10082024-003475-B	<2	
WS- 003476	3/6/2024	3/6/2025	2	Combo Fountain	In classroom 222	WF-03062024-003476	11/19/2024	FT-FY25-10082024-003476-A	<2	FT-FY25-10082024-003476-B	<2	
WS- 003477	3/6/2024	3/6/2025	2	Combo Fountain	In classroom 224	WF-03062024-003477	11/19/2024	FT-FY25-10082024-003477-A	<2	FT-FY25-10082024-003477-B	<2	
WS- 003478	3/6/2024	3/6/2025	2	Combo Fountain	In classroom 225	WF-03062024-003478	11/19/2024	FT-FY25-10082024-003478-A	<2	FT-FY25-10082024-003478-B	<2	
WS- 003481	3/6/2024	3/6/2025	1	Combo Fountain	In classroom 145	Right	WF-03062024-003481	11/19/2024	FT-FY25-10082024-003481-A	<2	FT-FY25-10082024-003481-B	<2
WS- 003482	3/6/2024	3/6/2025	1	Combo Fountain	In classroom 145	Left	WF-03062024-003482	11/19/2024	FT-FY25-10082024-003482-A	<2	FT-FY25-10082024-003482-B	<2
WS- 003490	8/19/2024	8/19/2025	1	Combo Faucet	In classroom 124	WF-08192024-003490	11/19/2024	FT-FY25-10082024-003490-A	<2	FT-FY25-10082024-003490-B	<2	
WS- 003491	8/19/2024	8/19/2025	1	Combo Faucet	In resource room 140	WF-08192024-003491	11/19/2024	FT-FY25-10082024-003491-A	<2	FT-FY25-10082024-003491-B	<2	
WS- 003492	8/19/2024	8/19/2025	1	Combo Faucet	In hallway adjacent to room 141	Right	WF-08192024-003492	11/19/2024	FT-FY25-10082024-003492-A	2.3	FT-FY25-10082024-003492-B	<2
WS- 003493	8/19/2024	8/19/2025	1	Combo Faucet	In classroom 144	Left	WF-08192024-003493	11/19/2024	FT-FY25-10082024-003493-A	<2	FT-FY25-10082024-003493-B	<2
WS- 003494	8/19/2024	8/19/2025	1	Combo Faucet	In classroom 144	Right	WF-08192024-003494	11/19/2024	FT-FY25-10082024-003494-A	<2	FT-FY25-10082024-003494-B	<2
WS- 003495	8/19/2024	8/19/2025	1	Combo Faucet	In classroom 141	Left	WF-08192024-003495	11/19/2024	FT-FY25-10082024-003495-A	<2	FT-FY25-10082024-003495-B	<2
WS- 003496	8/19/2024	8/19/2025	1	Combo Faucet	In classroom 141	Right	WF-08192024-003496	11/19/2024	FT-FY25-10082024-003496-A	<2	FT-FY25-10082024-003496-B	<2
WS- 003497	8/19/2024	8/19/2025	1	Combo Faucet	In classroom 142	Left	WF-08192024-003497	11/19/2024	FT-FY25-10082024-003497-A	<2	FT-FY25-10082024-003497-B	<2
WS- 003498	8/19/2024	8/19/2025	1	Combo Faucet	In classroom 142	Right	WF-08192024-003498	11/19/2024	FT-FY25-10082024-003498-A	<2	FT-FY25-10082024-003498-B	<2
WS- 003499	8/19/2024	8/19/2025	1	Combo Faucet	In classroom 143	Left	WF-08192024-003499	11/19/2024	FT-FY25-10082024-003499-A	<2	FT-FY25-10082024-003499-B	<2
WS- 003500	8/19/2024	8/19/2025	1	Combo Faucet	In classroom 143	Right	WF-08192024-003500	11/19/2024	FT-FY25-10082024-003500-A	<2	FT-FY25-10082024-003500-B	<2
WS- 003501	8/19/2024	8/19/2025	1	Combo Faucet	In classroom 145	Left	WF-08192024-003501	11/19/2024	FT-FY25-10082024-003501-A	<2	FT-FY25-10082024-003501-B	<2
WS- 003502	8/19/2024	8/19/2025	1	Combo Faucet	In classroom 145	Right	WF-08192024-003502	11/19/2024	FT-FY25-10082024-003502-A	<2	FT-FY25-10082024-003502-B	<2
WS- 003503	8/19/2024	8/19/2025	1	Combo Faucet	In classroom 135	Left	WF-08192024-003503	11/19/2024	FT-FY25-10082024-003503-A	<2	FT-FY25-10082024-003503-B	<2
WS- 003504	8/19/2024	8/19/2025	1	Combo Faucet	In classroom 135	Right	WF-08192024-003504	11/19/2024	FT-FY25-10082024-003504-A	<2	FT-FY25-10082024-003504-B	<2
WS- 003505	8/19/2024	8/19/2025	1	Combo Faucet	In classroom 134	Left	WF-08192024-003505	11/19/2024	FT-FY25-10082024-003505-A	<2	FT-FY25-10082024-003505-B	<2
WS- 003506	8/19/2024	8/19/2025	1	Combo Faucet	In classroom 134	Right	WF-08192024-003506	11/19/2024	FT-FY25-10082024-003506-A	<2	FT-FY25-10082024-003506-B	<2
WS- 003507	8/19/2024	8/19/2025	1	Combo Faucet	In classroom 132	Left	WF-08192024-003507	11/19/2024	FT-FY25-10082024-003507-A	<2	FT-FY25-10082024-003507-B	<2
WS- 003508	8/19/2024	8/19/2025	1	Combo Faucet	In classroom 132	Right	WF-08192024-003508	11/19/2024	FT-FY25-10082024-003508-A	<2	FT-FY25-10082024-003508-B	<2
WS- 003509	8/19/2024	8/19/2025	1	Combo Faucet	In classroom 130	Left	WF-08192024-003509	11/19/2024	FT-FY25-10082024-003509-A	<2	FT-FY25-10082024-003509-B	<2
WS- 003510	8/19/2024	8/19/2025	1	Combo Faucet	In classroom 130	Left	WF-08192024-003510	11/19/2024	FT-FY25-10082024-003510-A	<2	FT-FY25-10082024-003510-B	<2
WS- 003511	8/19/2024	8/19/2025	1	Combo Faucet	In classroom 133	Left	WF-08192024-003511	11/19/2024	FT-FY25-10082024-003511-A	<2	FT-FY25-10082024-003511-B	<2
WS- 003512	8/19/2024	8/19/2025	1	Combo Faucet	In classroom 133	Right	WF-08192024-003512	11/19/2024	FT-FY25-10082024-003512-A	<2	FT-FY25-10082024-003512-B	<2
WS- 003513	3/6/2024	3/6/2025	1	Combo Fountain	In classroom 136	Left	WF-03062024-003513	11/19/2024	FT-FY25-10082024-003513-A	<2	FT-FY25-10082024-003513-B	<2
WS- 003514	8/19/2024	8/19/2025	1	Combo Faucet	In classroom 136	Left	WF-08192024-003514	11/19/2024	FT-FY25-10082024-003514-A	<2	FT-FY25-10082024-003514-B	<2
WS- 003516	8/19/2024	8/19/2025	1	Combo Faucet	In classroom 136	Right	WF-08192024-003516	11/19/2024	FT-FY25-10082024-003516-A	<2	FT-FY25-10082024-003516-B	<2
WS- 003518	3/6/2024	3/6/2025	1	Cooler	In hallway adjacent to gym room 150	High Left	WF-03062024-003518	11/19/2024	FT-FY25-10082024-003518-A	<2	FT-FY25-10082024-003518-B	<2

WS-003519	3/6/2024	3/6/2025	1	Bottle Filler	In hallway adjacent to gym room 150 (bottle filler)		WF-03062024-003519	11/19/2024	FT-FY25-10082024-003519-A	<2	FT-FY25-10082024-003519-B	<2
WS-003520	3/6/2024	3/6/2025	1	Cooler	In hallway adjacent to gym room 150	Low Right	WF-03062024-003520	11/19/2024	FT-FY25-10082024-003520-A	<2	FT-FY25-10082024-003520-B	<2
WS-005417	8/22/2024	8/22/2025	Basement	Cooler	In multi-purpose room	High Left	WF-08222024-005417	11/19/2024	FT-FY25-10082024-005417-A	<2	FT-FY25-10082024-005417-B	<2
WS-005418	8/22/2024	8/22/2025	Basement	Bottle Filler	In multi-purpose room (bottle filler)		WF-08222024-005418	11/19/2024	FT-FY25-10082024-005418-A	<2	FT-FY25-10082024-005418-B	<2
WS-005419	8/22/2024	8/22/2025	Basement	Cooler	In multi-purpose room	Low Right	WF-08222024-005419	11/19/2024	FT-FY25-10082024-005419-A	<2	FT-FY25-10082024-005419-B	<2
WS-005420	3/6/2024	3/6/2025	1	Cooler	In hallway across from elevator	High Left	WF-03062024-005420	11/19/2024	FT-FY25-10082024-005420-A	<2	FT-FY25-10082024-005420-B	<2
WS-005421	3/6/2024	3/6/2025	1	Bottle Filler	In hallway across from elevator (bottle filler)		WF-03062024-005421	11/19/2024	FT-FY25-10082024-005421-A	<2	FT-FY25-10082024-005421-B	<2
WS-005422	3/6/2024	3/6/2025	1	Cooler	In hallway across from elevator	Low Right	WF-03062024-005422	11/19/2024	FT-FY25-10082024-005422-A	<2	FT-FY25-10082024-005422-B	<2
WS-005423	3/6/2024	3/6/2025	1	Combo Fountain	In classroom 111		WF-03062024-005423	11/19/2024	FT-FY25-10082024-005423-A	<2	FT-FY25-10082024-005423-B	<2
WS-005424	3/6/2024	3/6/2025	1	Combo Fountain	In classroom 112		WF-03062024-005424	11/19/2024	FT-FY25-10082024-005424-A	<2	FT-FY25-10082024-005424-B	<2
WS-005425	3/6/2024	3/6/2025	1	Combo Fountain	In classroom 114		WF-03062024-005425	11/19/2024	FT-FY25-10082024-005425-A	<2	FT-FY25-10082024-005425-B	<2
WS-005426	3/6/2024	3/6/2025	1	Combo Fountain	In classroom 116		WF-03062024-005426	11/19/2024	FT-FY25-10082024-005426-A	<2	FT-FY25-10082024-005426-B	<2
WS-005427	3/6/2024	3/6/2025	1	Combo Fountain	In classroom 115		WF-03062024-005427	11/19/2024	FT-FY25-10082024-005427-A	<2	FT-FY25-10082024-005427-B	<2
WS-005428	3/6/2024	3/6/2025	1	Combo Fountain	In classroom 113		WF-03062024-005428	11/19/2024	FT-FY25-10082024-005428-A	<2	FT-FY25-10082024-005428-B	<2
WS-005429	3/6/2024	3/6/2025	1	Combo Fountain	In classroom 124		WF-03062024-005429	11/19/2024	FT-FY25-10082024-005429-A	<2	FT-FY25-10082024-005429-B	<2
WS-005430	3/6/2024	3/6/2025	1	Health Suite	In health suite 102		WF-03062024-005430	11/19/2024	FT-FY25-10082024-005430-A	<2	FT-FY25-10082024-005430-B	<2
WS-005431	3/6/2024	3/6/2025	1	Combo Fountain	In resource room 140		WF-03062024-005431	11/19/2024	FT-FY25-10082024-005431-A	<2	FT-FY25-10082024-005431-B	<2
WS-005432	3/6/2024	3/6/2025	1	Combo Fountain	In classroom 142	Left	WF-03062024-005432	11/19/2024	FT-FY25-10082024-005432-A	<2	FT-FY25-10082024-005432-B	<2
WS-005433	3/6/2024	3/6/2025	1	Combo Fountain	In classroom 142	Right	WF-03062024-005433	11/19/2024	FT-FY25-10082024-005433-A	<2	FT-FY25-10082024-005433-B	<2
WS-005434	3/6/2024	3/6/2025	1	Combo Fountain	In classroom 144	Left	WF-03062024-005434	11/19/2024	FT-FY25-10082024-005434-A	<2	FT-FY25-10082024-005434-B	<2
WS-005435	3/6/2024	3/6/2025	1	Combo Fountain	In classroom 144	Right	WF-03062024-005435	11/19/2024	FT-FY25-10082024-005435-A	<2	FT-FY25-10082024-005435-B	<2
WS-005437	3/6/2024	3/6/2025	1	Combo Fountain	In classroom 143	Right	WF-03062024-005437	11/19/2024	FT-FY25-10082024-005437-A	<2	FT-FY25-10082024-005437-B	<2
WS-005438	3/6/2024	3/6/2025	1	Combo Fountain	In hallway adjacent to room 141		WF-03062024-005438	11/19/2024	FT-FY25-10082024-005438-A	<2	FT-FY25-10082024-005438-B	<2
WS-005439	3/6/2024	3/6/2025	1	Combo Fountain	In classroom 141	Left	WF-03062024-005439	11/19/2024	FT-FY25-10082024-005439-A	<2	FT-FY25-10082024-005439-B	<2
WS-005441	3/6/2024	3/6/2025	1	Combo Fountain	In classroom 130	Left	WF-03062024-005441	11/19/2024	FT-FY25-10082024-005441-A	<2	FT-FY25-10082024-005441-B	<2
WS-005442	3/6/2024	3/6/2025	1	Combo Fountain	In classroom 130	Right	WF-03062024-005442	11/19/2024	FT-FY25-10082024-005442-A	<2	FT-FY25-10082024-005442-B	<2
WS-005443	3/6/2024	3/6/2025	1	Combo Fountain	In classroom 132	Left	WF-03062024-005443	11/19/2024	FT-FY25-10082024-005443-A	<2	FT-FY25-10082024-005443-B	<2
WS-005444	3/6/2024	3/6/2025	1	Combo Fountain	In classroom 132	Right	WF-03062024-005444	11/19/2024	FT-FY25-10082024-005444-A	<2	FT-FY25-10082024-005444-B	<2
WS-005445	3/6/2024	3/6/2025	1	Combo Fountain	In classroom 133	Left	WF-03062024-005445	11/19/2024	FT-FY25-10082024-005445-A	<2	FT-FY25-10082024-005445-B	<2
WS-005446	3/6/2024	3/6/2025	1	Combo Fountain	In classroom 133	Right	WF-03062024-005446	11/19/2024	FT-FY25-10082024-005446-A	<2	FT-FY25-10082024-005446-B	<2
WS-005447	3/6/2024	3/6/2025	1	Combo Fountain	In classroom 134	Left	WF-03062024-005447	11/19/2024	FT-FY25-10082024-005447-A	<2	FT-FY25-10082024-005447-B	<2
WS-005448	3/6/2024	3/6/2025	1	Combo Fountain	In classroom 134	Right	WF-03062024-005448	11/19/2024	FT-FY25-10082024-005448-A	<2	FT-FY25-10082024-005448-B	<2
WS-005449	3/6/2024	3/6/2025	1	Combo Fountain	In classroom 135	Left	WF-03062024-005449	11/19/2024	FT-FY25-10082024-005449-A	<2	FT-FY25-10082024-005449-B	<2
WS-005450	3/6/2024	3/6/2025	1	Combo Fountain	In classroom 135	Right	WF-03062024-005450	11/19/2024	FT-FY25-10082024-005450-A	<2	FT-FY25-10082024-005450-B	<2
WS-005451	3/6/2024	3/6/2025	1	Combo Fountain	In classroom 146	Left	WF-03062024-005451	11/19/2024	FT-FY25-10082024-005451-A	<2	FT-FY25-10082024-005451-B	<2
WS-005453	3/6/2024	3/6/2025	1	Bottle Filler	In hallway adjacent to girls' restroom (bottle filler)		WF-03062024-005453	11/19/2024	FT-FY25-10082024-005453-A	<2	FT-FY25-10082024-005453-B	<2
WS-005454	3/6/2024	3/6/2025	1	Cooler	In hallway adjacent to girls' restroom	Low Right	WF-03062024-005454	11/19/2024	FT-FY25-10082024-005454-A	<2	FT-FY25-10082024-005454-B	<2
WS-005455	3/6/2024	3/6/2025	2	Cooler	In hallway adjacent to room 207	High Left	WF-03062024-005455	11/19/2024	FT-FY25-10082024-005455-A	<2	FT-FY25-10082024-005455-B	<2
WS-005456	3/6/2024	3/6/2025	2	Bottle Filler	In hallway adjacent to room 207 (bottle filler)		WF-03062024-005456	11/19/2024	FT-FY25-10082024-005456-A	<2	FT-FY25-10082024-005456-B	<2

WS- 005457	3/6/2024	3/6/2025	2	Cooler	In hallway adjacent to room 207	Low Right	WF-03062024-005457	11/19/2024	FT-FY25-10082024-005457-A	<2	FT-FY25-10082024-005457-B	<2
WS- 005458	3/6/2024	3/6/2025	2	Combo Fountain	In classroom 240		WF-03062024-005458	11/19/2024	FT-FY25-10082024-005458-A	<2	FT-FY25-10082024-005458-B	<2
WS- 005460	3/6/2024	3/6/2025	2	Combo Fountain	In classroom 244		WF-03062024-005460	11/19/2024	FT-FY25-10082024-005460-A	<2	FT-FY25-10082024-005460-B	<2
WS- 005462	3/6/2024	3/6/2025	2	Combo Fountain	In classroom 243		WF-03062024-005462	11/19/2024	FT-FY25-10082024-005462-A	<2	FT-FY25-10082024-005462-B	<2
WS- 005464	3/6/2024	3/6/2025	2	Combo Fountain	In classroom 231		WF-03062024-005464	11/19/2024	FT-FY25-10082024-005464-A	<2	FT-FY25-10082024-005464-B	<2
WS- 005465	3/6/2024	3/6/2025	2	Combo Fountain	In classroom 233		WF-03062024-005465	11/19/2024	FT-FY25-10082024-005465-A	<2	FT-FY25-10082024-005465-B	<2
WS- 005466	3/6/2024	3/6/2025	2	Combo Fountain	In classroom 235		WF-03062024-005466	11/19/2024	FT-FY25-10082024-005466-A	<2	FT-FY25-10082024-005466-B	<2
WS- 005467	3/6/2024	3/6/2025	2	Combo Fountain	In classroom 236		WF-03062024-005467	11/19/2024	FT-FY25-10082024-005467-A	<2	FT-FY25-10082024-005467-B	<2
WS- 005469	3/6/2024	3/6/2025	2	Combo Fountain	In classroom 232		WF-03062024-005469	11/19/2024	FT-FY25-10082024-005469-A	<2	FT-FY25-10082024-005469-B	<2
WS- 005471	3/6/2024	3/6/2025	2	Cooler	In hallway adjacent to room 209	High Left	WF-03062024-005471	11/19/2024	FT-FY25-10082024-005471-A	<2	FT-FY25-10082024-005471-B	<2
WS- 005472	3/6/2024	3/6/2025	2	Bottle Filler	In hallway adjacent to room 209 (bottle filler)		WF-03062024-005472	11/19/2024	FT-FY25-10082024-005472-A	<2	FT-FY25-10082024-005472-B	<2
WS- 005473	3/6/2024	3/6/2025	2	Cooler	In hallway adjacent to room 209	Low Right	WF-03062024-005473	11/19/2024	FT-FY25-10082024-005473-A	<2	FT-FY25-10082024-005473-B	<2
WS- 005478	3/6/2024	3/6/2025	2	Combo Fountain	In classroom 213		WF-03062024-005478	11/19/2024	FT-FY25-10082024-005478-A	<2	FT-FY25-10082024-005478-B	<2
WS- 005540	3/6/2024	3/6/2025	Basement	Combo Fountain	In classroom 008		WF-03062024-005540	11/19/2024	FT-FY25-10082024-005540-A	<2	FT-FY25-10082024-005540-B	<2
WS- 005542	3/6/2024	3/6/2025	Basement	Combo Fountain	In classroom 007		WF-03062024-005542	11/19/2024	FT-FY25-10082024-005542-A	<2	FT-FY25-10082024-005542-B	<2
WS- 005544	3/6/2024	3/6/2025	Basement	Combo Fountain	In classroom 005		WF-03062024-005544	11/19/2024	FT-FY25-10082024-005544-A	<2	FT-FY25-10082024-005544-B	<2
WS- 005546	3/6/2024	3/6/2025	Basement	Combo Fountain	In classroom 009		WF-03062024-005546	11/19/2024	FT-FY25-10082024-005546-A	<2	FT-FY25-10082024-005546-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005416	12/4/2023	12/4/2024	Basement	Food Prep Sink	In kitchen	WF-12042023-005416	11/19/2024	FT-FY25-10082024-005416-A	<2	FT-FY25-10082024-005416-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.