



LAFAYETTE LEAD WATER TEST RESULTS

May 15, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	LAFAYETTE ELEMENTARY SCHOOL	5/5/2016	WS- 003691	Utility	Ground Floor	In construction site (Main water source)	WT-042916-3708- A	2.5	WT-042916-3708- B	< 1				
2	LAFAYETTE ELEMENTARY SCHOOL	5/5/2016	WS- 003692	Classroom	1	In classroom B100	WT-042916-3709- A	< 1	WT-042916-3709- B	< 1				
3	LAFAYETTE ELEMENTARY SCHOOL	5/5/2016	WS- 003693	Classroom	1	In classroom B101	WT-042916-3710- A	< 1	WT-042916-3710- B	< 1				
4	LAFAYETTE ELEMENTARY SCHOOL	5/5/2016	WS- 003694	Classroom	1	In classroom B102	WT-042916-3711- A	< 1	WT-042916-3711- B	< 1				
5	LAFAYETTE ELEMENTARY SCHOOL	5/5/2016	WS- 003695	Classroom	1	In classroom B103	WT-042916-3712- A	< 1	WT-042916-3712- B	< 1				
6	LAFAYETTE ELEMENTARY SCHOOL	5/5/2016	WS- 003696	Classroom	1	In classroom B104	WT-042916-3713- A	< 1	WT-042916-3713- B	< 1				
7	LAFAYETTE ELEMENTARY SCHOOL	5/5/2016	WS- 003697	Classroom	1	In classroom B105	WT-042916-3714- A	< 1	WT-042916-3714- B	< 1				
8	LAFAYETTE ELEMENTARY SCHOOL	5/5/2016	WS- 003698	Cooler	1	In hallway across from room F110	Left High	WT-042916-3715- A	< 1	WT-042916-3715- B	< 1			
9	LAFAYETTE ELEMENTARY SCHOOL	5/5/2016	WS- 003699	Cooler	1	In hallway across from room 110	Right Low	WT-042916-3716- A	< 1	WT-042916-3716- B	< 1			
10	LAFAYETTE ELEMENTARY SCHOOL	5/5/2016	WS- 003700	Cooler	1	In hallway across from room F110	Left High	WT-042916-3717- A	< 1	WT-042916-3717- B	< 1			
11	LAFAYETTE ELEMENTARY SCHOOL	5/5/2016	WS- 003701	Cooler	1	In hallway across from room110	Right Low	WT-042916-3718- A	< 1	WT-042916-3718- B	< 1			
12	LAFAYETTE ELEMENTARY SCHOOL	5/5/2016	WS- 003702	Cooler	1	In hallway adjacent to room G102	Left High	WT-042916-3719- A	< 1	WT-042916-3719- B	< 1			
13	LAFAYETTE ELEMENTARY SCHOOL	5/5/2016	WS- 003703	Cooler	1	In hallway adjacent to room G102	Left Low	WT-042916-3720- A	< 1	WT-042916-3720- B	< 1			
14	LAFAYETTE ELEMENTARY SCHOOL	5/5/2016	WS- 003704	Cooler	1	In hallway across from room G102	Left High	WT-042916-3721- A	< 1	WT-042916-3721- B	< 1			
15	LAFAYETTE ELEMENTARY SCHOOL	5/5/2016	WS- 003705	Cooler	1	In hallway adjacent to room G102	Right Low	WT-042916-3722- A	< 1	WT-042916-3722- B	< 1			
16	LAFAYETTE ELEMENTARY SCHOOL	5/5/2016	WS- 003706	Cooler	1	In hallway across from room G102	Left High	WT-042916-3723- A	< 1	WT-042916-3723- B	< 1			
17	LAFAYETTE ELEMENTARY SCHOOL	5/5/2016	WS- 003707	Cooler	1	In hallway across from room H102	Left Low	WT-042916-3724- A	< 1	WT-042916-3724- B	< 1			
18	LAFAYETTE ELEMENTARY SCHOOL	5/5/2016	WS- 003708	Cooler	1	In hallway across from room H102	Left High	WT-042916-3725- A	< 1	WT-042916-3725- B	< 1			
19	LAFAYETTE ELEMENTARY SCHOOL	5/5/2016	WS- 003709	Cooler	1	In hallway across from room H102	Right Low	WT-042916-3726- A	< 1	WT-042916-3726- B	< 1			
20	LAFAYETTE ELEMENTARY SCHOOL	5/5/2016	WS- 003710	Classroom	1	In art room	WT-042916-3727- A	< 1	WT-042916-3727- B	< 1				
21	LAFAYETTE ELEMENTARY SCHOOL	5/5/2016	WS- 003711	Kitchen	1	In kitchen	Left	WT-042916-3728- A	< 1	WT-042916-3728- B	< 1			
22	LAFAYETTE ELEMENTARY SCHOOL	5/5/2016	WS- 003712	Classroom	1	In the kitchen	Right	WT-042916-3729- A	< 1	WT-042916-3729- B	< 1			
23	LAFAYETTE ELEMENTARY SCHOOL	5/5/2016	WS- 003713	Fountain	Ground Floor	In play area	High	WT-042916-3730- A	< 1	WT-042916-3730- B	< 1			
24	LAFAYETTE ELEMENTARY SCHOOL	5/5/2016	WS- 003714	Fountain	1	Across from the playground	Mid	WT-042916-3731- A	< 1	WT-042916-3731- B	< 1			
25	LAFAYETTE ELEMENTARY SCHOOL	5/5/2016	WS- 003715	Fountain	1	In play area	Low	WT-042916-3732- A	< 1	WT-042916-3732- B	< 1			
26	LAFAYETTE ELEMENTARY SCHOOL	5/5/2016	WS- 003716	Fountain	1	Across from the obstacle course	High	WT-042916-3733- A	< 1	WT-042916-3733- B	< 1			
27	LAFAYETTE ELEMENTARY SCHOOL	5/5/2016	WS- 003717	Fountain	1	In play area across from obstacle course	Low	WT-042916-3734- A	< 1	WT-042916-3734- B	< 1			
28	LAFAYETTE ELEMENTARY SCHOOL	5/5/2016	WS- 003718	Fountain	1	Across from the tennis court	High	WT-042916-3735- A	< 1	WT-042916-3735- B	< 1			
29	LAFAYETTE ELEMENTARY SCHOOL	5/5/2016	WS- 003719	Fountain	1	Across from tennis court	Low	WT-042916-3736- A	< 1	WT-042916-3736- B	< 1			

Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.