



# LAFAYETTE ES LEAD WATER TEST RESULTS



## Initial Filter Test After Installation

	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	LAFAYETTE ELEMENTARY SCHOOL	WS- 003514	12/26/2016	1	Combo Faucet	In classroom 136 Left	FT-122016-003514-A	< 1	FT-122016-003514-B	< 1
2	LAFAYETTE ELEMENTARY SCHOOL	WS- 003491	12/26/2016	1	Combo Faucet	In resource room 140	FT-122016-003491-A	< 1	FT-122016-003491-B	< 1
3	LAFAYETTE ELEMENTARY SCHOOL	WS- 003492	12/26/2016	1	Combo Faucet	In hallway adjacent to room 141 Right	FT-122016-003492-A	< 1	FT-122016-003492-B	< 1
4	LAFAYETTE ELEMENTARY SCHOOL	WS- 003490	12/26/2016	1	Combo Faucet	In classroom 124	FT-122016-003490-A	< 1	FT-122016-003490-B	< 1
5	LAFAYETTE ELEMENTARY SCHOOL	WS- 003496	12/26/2016	1	Combo Faucet	In classroom 141 Right	FT-122016-003496-A	< 1	FT-122016-003496-B	< 1
6	LAFAYETTE ELEMENTARY SCHOOL	WS- 003502	12/26/2016	1	Combo Faucet	In classroom 145 Right	FT-122016-003502-A	< 1	FT-122016-003502-B	< 1
7	LAFAYETTE ELEMENTARY SCHOOL	WS- 003516	12/26/2016	1	Combo Faucet	In classroom 136 Right	FT-122016-003516-A	< 1	FT-122016-003516-B	< 1
8	LAFAYETTE ELEMENTARY SCHOOL	WS- 003500	12/26/2016	1	Combo Faucet	In classroom 143 Right	FT-122016-003500-A	< 1	FT-122016-003500-B	< 1
9	LAFAYETTE ELEMENTARY SCHOOL	WS- 003497	12/26/2016	1	Combo Faucet	In classroom 142 Left	FT-122016-003497-A	< 1	FT-122016-003497-B	< 1
10	LAFAYETTE ELEMENTARY SCHOOL	WS- 003510	12/26/2016	1	Combo Faucet	In classroom 130 Left	FT-122016-003510-A	< 1	FT-122016-003510-B	< 1
11	LAFAYETTE ELEMENTARY SCHOOL	WS- 003495	12/26/2016	1	Combo Faucet	In classroom 141 Left	FT-122016-003495-A	< 1	FT-122016-003495-B	< 1
12	LAFAYETTE ELEMENTARY SCHOOL	WS- 003494	12/26/2016	1	Combo Faucet	In classroom 144 Right	FT-122016-003494-A	< 1	FT-122016-003494-B	< 1
13	LAFAYETTE ELEMENTARY SCHOOL	WS- 003498	12/26/2016	1	Combo Faucet	In classroom 142 Right	FT-122016-003498-A	< 1	FT-122016-003498-B	< 1
14	LAFAYETTE ELEMENTARY SCHOOL	WS- 003503	12/26/2016	1	Combo Faucet	In classroom 135 Left	FT-122016-003503-A	< 1	FT-122016-003503-B	< 1
15	LAFAYETTE ELEMENTARY SCHOOL	WS- 003499	12/26/2016	1	Combo Faucet	In classroom 143 Left	FT-122016-003499-A	< 1	FT-122016-003499-B	< 1
16	LAFAYETTE ELEMENTARY SCHOOL	WS- 003501	12/26/2016	1	Combo Faucet	In classroom 145 Left	FT-122016-003501-A	< 1	FT-122016-003501-B	< 1
17	LAFAYETTE ELEMENTARY SCHOOL	WS- 003493	12/26/2016	1	Combo Faucet	In classroom 144 Left	FT-122016-003493-A	< 1	FT-122016-003493-B	< 1
18	LAFAYETTE ELEMENTARY SCHOOL	WS- 003508	12/26/2016	1	Combo Faucet	In classroom 132 Right	FT-122016-003508-A	< 1	FT-122016-003508-B	< 1
19	LAFAYETTE ELEMENTARY SCHOOL	WS- 003512	12/26/2016	1	Combo Faucet	In classroom 133 Right	FT-122016-003512-A	< 1	FT-122016-003512-B	< 1
20	LAFAYETTE ELEMENTARY SCHOOL	WS- 003506	12/26/2016	1	Combo Faucet	In classroom 134 Right	FT-122016-003506-A	< 1	FT-122016-003506-B	< 1
21	LAFAYETTE ELEMENTARY SCHOOL	WS- 003509	12/26/2016	1	Combo Faucet	In classroom 130 Left	FT-122016-003509-A	< 1	FT-122016-003509-B	< 1
22	LAFAYETTE ELEMENTARY SCHOOL	WS- 003511	12/26/2016	1	Combo Faucet	In classroom 133 Left	FT-122016-003511-A	< 1	FT-122016-003511-B	< 1
23	LAFAYETTE ELEMENTARY SCHOOL	WS- 003505	12/26/2016	1	Combo Faucet	In classroom 134 Left	FT-122016-003505-A	< 1	FT-122016-003505-B	< 1
24	LAFAYETTE ELEMENTARY SCHOOL	WS- 003507	12/26/2016	1	Combo Faucet	In classroom 132 Left	FT-122016-003507-A	< 1	FT-122016-003507-B	< 1
25	LAFAYETTE ELEMENTARY SCHOOL	WS- 003504	12/26/2016	1	Combo Faucet	In classroom 135 Right	FT-122016-003504-A	< 1	FT-122016-003504-B	< 1

Note :

Filter re-tests are only performed to devices that have sampling results greater than 1 ppb