



Lafayette RC Lead in Water Test Results

FY26 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005150	12/15/2025	12/15/2026	1	Food Prep Sink	In kitchenette in multipurpose room	WF-12152025-005150	2/25/2026	FT-FY26-01282026-005150-A	<2	FT-FY26-01282026-005150-B	<2
WS- 005152	9/9/2025	9/9/2026	1	Cooler	In hallway across from storage room	WF-09092025-005152	2/25/2026	FT-FY26-01282026-005152-A	<2	FT-FY26-01282026-005152-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.