



Lafayette RC Lead in Water Test Results

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005152	4/17/2024	4/17/2025	1	Cooler	In hallway across from storage room	WF-04172024-005152	3/11/2025	FT-FY25-01082025-005152-A	<2	FT-FY25-01082025-005152-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.