



Lafayette ES Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003479	6/16/2017	6/16/2018	2	Combo Fountain	In classroom 223	WF-62017-003479	11/7/2017	FT-FY18--62017-003479-A	<1	FT-FY18--62017-003479-B	<1
WS- 003480	6/16/2017	6/16/2018	2	Combo Fountain	In classroom 221	WF-62017-003480	11/7/2017	FT-FY18--62017-003480-A	<1	FT-FY18--62017-003480-B	<1
WS- 003481	6/16/2017	6/16/2018	1	Combo Fountain	In classroom 145	Right WF-62017-003481	11/7/2017	FT-FY18--62017-003481-A	<1	FT-FY18--62017-003481-B	<1
WS- 003490	10/23/2017	10/23/2018	1	Combo Faucet	In classroom 124	WF-102017-003490	11/7/2017	FT-FY18-102017-003490-A	<1	FT-FY18-102017-003490-B	<1
WS- 003492	10/23/2017	10/23/2018	1	Combo Faucet	In hallway adjacent to room 141	Right WF-102017-003492	11/7/2017	FT-FY18-102017-003492-A	<1	FT-FY18-102017-003492-B	<1
WS- 003493	10/23/2017	10/23/2018	1	Combo Faucet	In classroom 144	Left WF-102017-003493	11/7/2017	FT-FY18-102017-003493-A	<1	FT-FY18-102017-003493-B	<1
WS- 003494	10/23/2017	10/23/2018	1	Combo Faucet	In classroom 144	Right WF-102017-003494	11/7/2017	FT-FY18-102017-003494-A	1.8	FT-FY18-102017-003494-B	<1
WS- 003503	10/23/2017	10/23/2018	1	Combo Faucet	In classroom 135	Left WF-102017-003503	11/7/2017	FT-FY18-102017-003503-A	<1	FT-FY18-102017-003503-B	<1
WS- 003504	10/23/2017	10/23/2018	1	Combo Faucet	In classroom 135	Right WF-102017-003504	11/7/2017	FT-FY18-102017-003504-A	1.5	FT-FY18-102017-003504-B	<1
WS- 003505	10/23/2017	10/23/2018	1	Combo Faucet	In classroom 134	Left WF-102017-003505	11/7/2017	FT-FY18-102017-003505-A	1.3	FT-FY18-102017-003505-B	<1
WS- 003506	10/23/2017	10/23/2018	1	Combo Faucet	In classroom 134	Right WF-102017-003506	11/7/2017	FT-FY18-102017-003506-A	1.3	FT-FY18-102017-003506-B	<1
WS- 003508	10/23/2017	10/23/2018	1	Combo Faucet	In classroom 132	Right WF-102017-003508	11/7/2017	FT-FY18-102017-003508-A	1.4	FT-FY18-102017-003508-B	<1
WS- 003512	10/23/2017	10/23/2018	1	Combo Faucet	In classroom 133	Right WF-102017-003512	11/7/2017	FT-FY18-102017-003512-A	<1	FT-FY18-102017-003512-B	<1
WS- 003515	6/16/2017	6/16/2018	1	Combo Fountain	In classroom 136	Right WF-62017-003515	11/7/2017	FT-FY18--62017-003515-A	<1	FT-FY18--62017-003515-B	<1
WS- 005417	6/16/2017	6/16/2018	Basement	Cooler	In multi-purpose room	Left High WF-62017-005417	11/7/2017	FT-FY18--62017-005417-A	<1	FT-FY18--62017-005417-B	<1
WS- 005420	6/16/2017	6/16/2018	1	Cooler	In hallway across from elevator	Left High WF-62017-005420	11/7/2017	FT-FY18--62017-005420-A	<1	FT-FY18--62017-005420-B	<1
WS- 005424	6/16/2017	6/16/2018	1	Combo Fountain	In classroom 112	WF-62017-005424	11/7/2017	FT-FY18--62017-005424-A	<1	FT-FY18--62017-005424-B	<1
WS- 005428	6/16/2017	6/16/2018	1	Combo Fountain	In classroom 113	WF-62017-005428	11/7/2017	FT-FY18--62017-005428-A	<1	FT-FY18--62017-005428-B	<1
WS- 005429	6/16/2017	6/16/2018	1	Combo Fountain	In classroom 124	WF-62017-005429	11/7/2017	FT-FY18--62017-005429-A	<1	FT-FY18--62017-005429-B	<1
WS- 005433	6/16/2017	6/16/2018	1	Combo Fountain	In classroom 142	Right WF-62017-005433	11/7/2017	FT-FY18--62017-005433-A	<1	FT-FY18--62017-005433-B	<1
WS- 005436	6/16/2017	6/16/2018	1	Combo Fountain	In classroom 143	Left WF-62017-005436	11/7/2017	FT-FY18--62017-005436-A	<1	FT-FY18--62017-005436-B	<1
WS- 005441	6/16/2017	6/16/2018	1	Combo Fountain	In classroom 130	Left WF-62017-005441	11/7/2017	FT-FY18--62017-005441-A	<1	FT-FY18--62017-005441-B	<1
WS- 005442	6/16/2017	6/16/2018	1	Combo Fountain	In classroom 130	Right WF-62017-005442	11/7/2017	FT-FY18--62017-005442-A	<1	FT-FY18--62017-005442-B	<1
WS- 005446	6/16/2017	6/16/2018	1	Combo Fountain	In classroom 133	Right WF-62017-005446	11/7/2017	FT-FY18--62017-005446-A	<1	FT-FY18--62017-005446-B	<1
WS- 005449	6/16/2017	6/16/2018	1	Combo Fountain	In classroom 135	Left WF-62017-005449	11/7/2017	FT-FY18--62017-005449-A	<1	FT-FY18--62017-005449-B	<1
WS- 005451	6/16/2017	6/16/2018	1	Combo Fountain	In classroom 146	Left WF-62017-005451	11/7/2017	FT-FY18--62017-005451-A	<1	FT-FY18--62017-005451-B	<1
WS- 005453	6/16/2017	6/16/2018	1	Bottle Filler	In hallway adjacent to girls' restroom (bottle filler)	Left High WF-62017-005453	11/7/2017	FT-FY18--62017-005453-A	<1	FT-FY18--62017-005453-B	<1
WS- 005457	6/16/2017	6/16/2018	2	Cooler	In hallway adjacent to room 207	Right Low WF-62017-005457	11/7/2017	FT-FY18--62017-005457-A	<1	FT-FY18--62017-005457-B	<1
WS- 005458	6/16/2017	6/16/2018	2	Combo Fountain	In classroom 240	WF-62017-005458	11/7/2017	FT-FY18--62017-005458-A	<1	FT-FY18--62017-005458-B	<1
WS- 005459	6/16/2017	6/16/2018	2	Combo Fountain	In classroom 242	WF-62017-005459	11/7/2017	FT-FY18--62017-005459-A	<1	FT-FY18--62017-005459-B	<1
WS- 005461	6/16/2017	6/16/2018	2	Combo Fountain	In classroom 245	WF-62017-005461	11/7/2017	FT-FY18--62017-005461-A	<1	FT-FY18--62017-005461-B	<1
WS- 005465	6/16/2017	6/16/2018	2	Combo Fountain	In classroom 233	WF-62017-005465	11/7/2017	FT-FY18--62017-005465-A	<1	FT-FY18--62017-005465-B	<1
WS- 005478	6/16/2017	6/16/2018	2	Combo Fountain	In classroom 213	WF-62017-005478	11/7/2017	FT-FY18--62017-005478-A	<1	FT-FY18--62017-005478-B	<1
WS- 005479	6/16/2017	6/16/2018	2	Combo Fountain	In classroom 211	WF-62017-005479	11/7/2017	FT-FY18--62017-005479-A	<1	FT-FY18--62017-005479-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation

RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005416	Basement	Food Prep Sink	In kitchen	11/7/2017	FT-FY18-102017-005416-A	<1	FT-FY18-102017-005416-B	<1